



A Service of The City of Cincinnati

Cincinnati Public Schools - Lead Testing Results per school							
SCHOOL	SAMPLE DATE	SAMPLE TIME	SAMPLE NAME	PARAMETER CODE	AMOUNT	COMMENTS REGARDING SAMPLING PROCESS	GCWW COMMENTS/REVIEW/RECOMMENDATIONS
Aiken High School Carpe Diem Charter School	5/25/2016	6:12 AM	CPS_AIKEN_KITCHEN_CME2016-085	Lead, ppb	<1		No lead detected in samples. CPS should follow 3Ts guidelines and sample at all drinking water and cooking outlets within the school (may result in 40-45 samples per school).
Aiken High School Carpe Diem Charter School	5/25/2016	6:17 AM	CPS_AIKEN_NEARMAIN_CME2016-086	Lead, ppb	<1		
Aiken High School Carpe Diem Charter School	5/25/2016	6:21 AM	CPS_AIKEN_FARTHESTPOINT_CME2016-087	Lead, ppb	<1		

<1 ppb = below detection level. No lead was detected.