



Cincinnati Public Schools - Lead Testing Results per school							
SCHOOL	SAMPLE DATE	SAMPLE TIME	SAMPLE NAME	PARAMETER CODE	AMOUNT	COMMENTS REGARDING SAMPLING PROCESS	GCWW COMMENTS/REVIEW/RECOMMENDATIONS
Bond Hill Academy	5/12/2016	7:00 AM	CPS_BONDHILL_KITCHEN_CME2016-062	Lead, ppb	<1		No lead detected in samples. CPS should follow 3Ts guidelines and sample at all drinking water and cooking outlets within the school (may result in 40-45 samples per school).
Bond Hill Academy	5/12/2016	7:15 AM	CPS_BONDHILL_FARTHESTPOINTRM2200_CME2016-063	Lead, ppb	<1		
Bond Hill Academy	5/20/2016	7:05 AM	CPS_BONDHILL_RM1010_CME2016-061	Lead, ppb	<1		

<1 ppb = below detection level. No lead was detected.