



Cincinnati Public Schools - Lead Testing Results per school							
SCHOOL	SAMPLE DATE	SAMPLE TIME	SAMPLE NAME	PARAMETER CODE	AMOUNT	COMMENTS REGARDING SAMPLING PROCESS	GCWW COMMENTS/REVIEW/RECOMMENDATIONS
Carson School	5/25/2016	5:25 AM	CPS_CARSON_KITCHEN_DE2016-052	Lead, ppb	<1		No lead detected in samples. CPS should follow 3Ts guidelines and sample at all drinking water and cooking outlets within the school (may result in 40-45 samples per school).
Carson School	5/25/2016	5:30 AM	CPS_CARSON_RM2018_DE2016-053	Lead, ppb	<1		
Carson School	5/25/2016	5:35 AM	CPS_CARSON_RM3013_DE2016-054	Lead, ppb	<1		

<1 ppb = below detection level. No lead was detected.