



Cincinnati Public Schools - Lead Testing Results per school							
SCHOOL	SAMPLE DATE	SAMPLE TIME	SAMPLE NAME	PARAMETER CODE	AMOUNT	COMMENTS REGARDING SAMPLING PROCESS	GCWW COMMENTS/REVIEW/RECOMMENDATIONS
Chase School	5/26/2016	6:10 AM	CPS_CHASE_KITCHEN_CME2016-094	Lead, ppb	<1		Lead detected at 2 of 3 sample points. Conduct a plumbing profile to understand the material of the fixtures at sample points. Review 3Ts guidelines to understand options to reduce lead. CPS should follow 3Ts guidelines and sample at all drinking water and cooking outlets within the school (may result in 40-45 samples per school).
Chase School	5/26/2016	6:13 AM	CPS_CHASE_NEARMAIN_CME2016-094	Lead, ppb	1.13		
Chase School	5/26/2016	6:17 AM	CPS_CHASE_FARTHESTPOINT_CME2016-096	Lead, ppb	1.18		

<1 ppb = below detection level. No lead was detected.