



Cincinnati Public Schools - Lead Testing Results per school							
SCHOOL	SAMPLE DATE	SAMPLE TIME	SAMPLE NAME	PARAMETER CODE	AMOUNT	COMMENTS REGARDING SAMPLING PROCESS	GCWW COMMENTS/REVIEW/RECOMMENDATIONS
Hughes STEM High School	6/1/2016	5:50 AM	CPS_HUGHES_KITCHEN_DE2016-073	Lead, ppb	<1		No lead detected in samples. CPS should follow 3Ts guidelines and sample at all drinking water and cooking outlets within the school (may result in 40-45 samples per school).
Hughes STEM High School	6/1/2016	5:55 AM	CPS_HUGHES_RM0125_DE2016-074	Lead, ppb	<1		
Hughes STEM High School	6/1/2016	6:00 AM	CPS_HUGHES_RM3138_DE2016-075	Lead, ppb	<1		

<1 ppb = below detection level. No lead was detected.