



Cincinnati Public Schools - Lead Testing Results per school							
SCHOOL	SAMPLE DATE	SAMPLE TIME	SAMPLE NAME	PARAMETER CODE	AMOUNT	COMMENTS REGARDING SAMPLING PROCESS	GCWW COMMENTS/REVIEW/RECOMMENDATIONS
Parker Woods Montessori School	5/26/2016	6:45 AM	CPS_PARKERWOODS_KITCHEN_DE2016-070	Lead, ppb	<1		No lead detected in samples. CPS should follow 3Ts guidelines and sample at all drinking water and cooking outlets within the school (may result in 40-45 samples per school).
Parker Woods Montessori School	5/26/2016	6:50 AM	CPS_PARKERWOODS_ART1306_DE2016-071	Lead, ppb	<1		
Parker Woods Montessori School	5/26/2016	6:55 AM	CPS_PARKERWOODS_RM3401_DE2016-072	Lead, ppb	<1		

<1 ppb = below detection level. No lead was detected.