



**Cincinnati Public Schools - Lead Testing Results per school**

SCHOOL	SAMPLE DATE	SAMPLE TIME	SAMPLE NAME	PARAMETER CODE	AMOUNT	COMMENTS REGARDING SAMPLING PROCESS	GCWW COMMENTS/REVIEW/RECOMMENDATIONS
School for Creative and Performing Arts	5/25/2016	6:10 AM	CPS_SCPA_NEARMAIN_CME2016-088	Lead, ppb	<1		No lead detected in samples. CPS should follow 3Ts guidelines and sample at all drinking water and cooking outlets within the school (may result in 40-45 samples per school).
School for Creative and Performing Arts	5/25/2016	6:15 AM	CPS_SCPA_KITCHEN_CME2016-089	Lead, ppb	<1		
School for Creative and Performing Arts	5/25/2016	6:20 AM	CPS_SCPA_FARTHESTPOINT_CME2016-090	Lead, ppb	<1		

<1 ppb = below detection level. No lead was detected.