



Cincinnati Public Schools - Lead Testing Results per school

SCHOOL	SAMPLE DATE	SAMPLE TIME	SAMPLE NAME	PARAMETER CODE	AMOUNT	COMMENTS REGARDING SAMPLING PROCESS	GCWW COMMENTS/REVIEW/RECOMMENDATIONS
Taylor (Ethel M.) Academy	5/3/2016	6:10 AM	CPS_TAYLOR_MAIN_DE2016-004	Lead, ppb	10.3	CPS/incorrect sampling procedure.	Lead detected at 1 of 4 sample points. One sample was incorrectly collected. Another sample was collected. CPS should follow 3Ts guidelines and sample at all drinking water and cooking outlets within the school (may result in 40-45 samples per school).
Taylor (Ethel M.) Academy	5/3/2016	6:15 AM	CPS_TAYLOR_KTICHEN_DE2016-005	Lead, ppb	<1		
Taylor (Ethel M.) Academy	5/3/2016	6:20 AM	CPS_TAYLOR_RM311_DE2016-006	Lead, ppb	<1		
Taylor (Ethel M.) Academy	5/17/2016	5:15 AM	CPS_TAYLOR_MAINRETEST_CME2016-067	Lead, ppb	<1	Resampled.	

<1 ppb = below detection level. No lead was detected.