



Cincinnati Public Schools - Lead Testing Results per school

| SCHOOL | SAMPLE DATE | SAMPLE TIME | SAMPLE NAME | PARAMETER CODE | AMOUNT | COMMENTS REGARDING SAMPLING PROCESS | GCWW COMMENTS/REVIEW/RECOMMENDATIONS |
|-----------------|-------------|-------------|---|----------------|--------|-------------------------------------|--|
| Westwood School | 5/3/2016 | 5:40 AM | CPS_WESTWOOD_KITCHEN_DE2016-002 | Lead, ppb | 3 | | Lead detected at 1 of 4 sample points. Conduct a plumbing profile to understand the material of the fixtures at sample points. Review 3Ts guidelines to understand options to reduce lead. CPS should follow 3Ts guidelines and sample at all drinking water and cooking outlets within the school (may result in 40-45 samples per school). |
| Westwood School | 5/3/2016 | 5:45 AM | CPS_WESTWOOD_RM3048_DE2016-003 | Lead, ppb | <1 | | |
| Westwood School | 5/12/2016 | 6:45 AM | CPS_WESTWOOD_FARTHESTPOINTRM20223_CME2016-060 | Lead, ppb | <1 | | |
| Westwood School | 5/17/2016 | 5:45 AM | CPS_WESTWOOD_RM1002_DE2016-045 | Lead, ppb | <1 | | |

<1 ppb = below detection level. No lead was detected.