



Cincinnati Public Schools - Lead Testing Results per school

SCHOOL	SAMPLE DATE	SAMPLE TIME	SAMPLE NAME	PARAMETER CODE	AMOUNT	COMMENTS REGARDING SAMPLING PROCESS	GCWW COMMENTS/REVIEW/RECOMMENDATIONS
Woodford Paideia Academy	5/18/2016	6:55 AM	CPS_WOODFORD_WORKROOM1213_CME2016-052	Lead, ppb	<1		No lead detected in samples. CPS should follow 3Ts guidelines and sample at all drinking water and cooking outlets within the school (may result in 40-45 samples per school).
Woodford Paideia Academy	5/11/2016	7:00 AM	CPS_WOODFORD_KITCHEN_CME206-053	Lead, ppb	<1		
Woodford Paideia Academy	5/11/2016	7:05 AM	CPS_WOODFORD_FARTHESTPOINT_CME2016-054	Lead, ppb	<1		

<1 ppb = below detection level. No lead was detected.