



Cincinnati Public Schools - Lead Testing Results per school							
SCHOOL	SAMPLE DATE	SAMPLE TIME	SAMPLE NAME	PARAMETER CODE	AMOUNT	COMMENTS REGARDING SAMPLING PROCESS	GCWW COMMENTS/REVIEW/RECOMMENDATIONS
Douglass (Frederick) School	5/4/2016	6:00 AM	CPS_DOUGLASS_MAIN_CME2016-016	Lead, ppb	<1		No lead detected in samples. CPS should follow 3Ts guidelines and sample at all drinking water and cooking outlets within the school (may result in 40-45 samples per school).
Douglass (Frederick) School	5/4/2016	6:05 AM	CPS_DOUGLASS_KITCHEN_CME2016-017	Lead, ppb	<1		
Douglass (Frederick) School	5/4/2016	6:10 AM	CPS_DOUGLASS_FARTHESTPOINT_CME2016-018	Lead, ppb	<1		

<1 ppb = below detection level. No lead was detected.