



Cincinnati Public Schools - Lead Testing Results per school							
SCHOOL	SAMPLE DATE	SAMPLE TIME	SAMPLE NAME	PARAMETER CODE	AMOUNT	COMMENTS REGARDING SAMPLING PROCESS	GCWW COMMENTS/REVIEW/RECOMMENDATIONS
Fairview-Clifton German Language School	5/10/2016	6:35 AM	CPS_FAIRVIEW_KITCHEN_DE2016-026	Lead, ppb	<1		No lead detected in samples. CPS should follow 3Ts guidelines and sample at all drinking water and cooking outlets within the school (may result in 40-45 samples per school).
Fairview-Clifton German Language School	5/10/2016	6:40 AM	CPS_FAIRVIEW_RM3306_DE2016-027	Lead, ppb	<1		
Fairview-Clifton German Language School	5/18/2016	5:45 AM	CPS_FAIRVIEW_ARTRM1212_DE2016-049	Lead, ppb	<1		

<1 ppb = below detection level. No lead was detected.