



## Cincinnati Public Schools - Lead Testing Results per school

SCHOOL	SAMPLE DATE	SAMPLE TIME	SAMPLE NAME	PARAMETER CODE	AMOUNT	COMMENTS REGARDING SAMPLING PROCESS	GCWW COMMENTS/REVIEW/RECOMMENDATIONS
Gamble (James N.) Montessori High School	5/4/2016	6:30 AM	CPS_GAMBLE_KITCHEN_DE2016-017	Lead, ppb	7.55*	CPS/incorrect sampling procedure.	Lead detected at 4 of 4 sample points. One sample was incorrectly collected. Another sample was collected. Conduct a plumbing profile to understand the material of the fixtures at sample points. Review 3Ts guidelines to understand options to reduce lead. CPS should follow 3Ts guidelines and sample at all drinking water and cooking outlets within the school (may result in 40-45 samples per school).
Gamble (James N.) Montessori High School	5/4/2016	6:35 AM	CPS_GAMBLE_EASTWINGBOYSRR_DE2016-018	Lead, ppb	1.42		
Gamble (James N.) Montessori High School	5/17/2016	5:55 AM	CPS_GAMBLE_KITCHENRETEST_DE2016-046	Lead, ppb	4.38	Resampled.	
Gamble (James N.) Montessori High School	5/17/2016	6:00 AM	CPS_GAMBLE_OFFICE1117_DE2016-047	Lead, ppb	6.19		

\* Incorrect sampling procedure as this was not a drinking water or cooking outlet and the methodology for collecting the sample at this location was different as outlined in the USEPA 3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance Document (3Ts guidelines). Water used at this outlet may be used for cleaning purposes but would not be consumed. Sample results are shown here, but are not a drinking water or cooking outlet concern for the school.