



Cincinnati Public Schools - Lead Testing Results per school							
SCHOOL	SAMPLE DATE	SAMPLE TIME	SAMPLE NAME	PARAMETER CODE	AMOUNT	COMMENTS REGARDING SAMPLING PROCESS	GCWW COMMENTS/REVIEW/RECOMMENDATIONS
Kilgour School	4/29/2016	6:35 AM	CPS_KILGOUR_MAIN_CME2016-010	Lead, ppb	<1		No lead detected in samples. CPS should follow 3Ts guidelines and sample at all drinking water and cooking outlets within the school (may result in 40-45 samples per school).
Kilgour School	4/29/2016	6:40 AM	CPS_KILGOUR_KITCHEN_CME2016-011	Lead, ppb	<1		
Kilgour School	4/29/2016	6:45 AM	CPS_KILGOUR_FARTHESTPOINT_CME2016-012	Lead, ppb	<1		

<1 ppb = below detection level. No lead was detected.