



January 19, 2017

Cincinnati Public Schools
Cynthia Eghbalnia
2651 Burnet Avenue
Cincinnati, OH 45219

Oyler School

Dear Cynthia:

Thank you for taking the responsibility seriously to protect the health of the children by voluntarily testing the water in your school for lead!

Attached please find the results of the lead analyses performed for Oyler School by the Greater Cincinnati Water Works (GCWW). The following comments speak to the process, samples analyzed and additional steps needed to help ensure the safety of all the students within the school.

School Sampling Process and Results

GCWW and Cincinnati Public Schools (CPS) staff worked together to finalize a sampling plan for the school. The *USEPA 3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance Document (3Ts Guidelines)* is the process and guidelines used for assisting schools with testing for lead.

In December, one hundred, ninety-one (191) samples were collected from drinking fountains, sinks and cooking outlets throughout the school. Multiple sinks within the school were not initially considered for testing, however, key nearby indicators (coffee makers, drinking cups, plates, utensils, etc.) prompted additional locations to be tested in the schools. Including these sampling locations speaks to the proactive approach CPS continues to have towards understanding the water quality within the schools. The results show the following:

- 65 samples (34.03%), below the detection level (<1)
- 121 samples (63.35%), between 1ppb and 5ppb
- 5 samples (2.62%), between 5ppb and 10ppb.

Approximately sixty-six percent (65.97%) of the samples analyzed had some level of lead detection; 100% of the sample results were below the federal action level.

Fifteen parts per billion (ppb) is the federal Lead and Copper Rule action level; desired results are below 15. The federal action level of 15ppb pertains to water utilities and GCWW's review and comments are based on this action level. However, the USEPA 3Ts Guidelines document outlines practices for schools to put in place if samples are greater than 20 ppb.

While we strive to have results less than 15, we recognize that lead is a pervasive environmental contaminant, and no safe blood lead threshold has been identified in children or adults. Therefore, we provide recommendations to further reduce any lead levels discovered in your school.

Next steps

GCWW has reviewed the results from your samples and provides some next-steps comments:

1. Although well below the 15 ppb action level, there were a number of drinking water fountains that had detections of lead (13 of 50 drinking fountain locations). It is our understanding that this school was a rehabilitation project and not a brand new building. If so, consider reviewing the building plans to understand what pipes were changed/replaced; GCWW will also review plans for the school to offer additional suggestions regarding this.



2. One-hundred, twenty-six (126) sample locations had lead detections. Although lower than the 15 ppb action level, for all samples with lead detections, consider flushing the lines before using the water. Refer to the USEPA 3Ts Guidelines for more information.
3. For sinks with lead detections, as a precautionary measure, consider signage limiting the purpose of the sink ('Hand Washing Only', 'utility sink/work area only', etc.) Refer to the USEPA 3Ts Guidelines for more information and recommendations on how to further reduce the risk of lead.
4. Although a number of samples had minimum lead detections, consider completing a plumbing profile to review the fixtures in the school as some fixtures may be contributing to the lead detections in samples. If the fixtures are the source of the lead, plan to replace them. The USEPA 3Ts Guidelines outlines a great approach to creating and implementing a remediation plan. A copy of the Guidelines can be found on our website <http://www.cincinnati-oh.gov/water/assets/File/3T%20Guidance%20Manual%20for%20Schools.pdf>.


State funds are available through the new Lead Plumbing Fixture Replacement Assistance Grant Program established to provide reimbursement to eligible schools for the assessment and replacement of certain plumbing fixtures. The program is open to traditional public schools, community schools, and chartered non-public schools. Program information can be found on the Ohio Facilities Construction Commission (OFCC) Services and Programs website <http://ofcc.ohio.gov/ServicesPrograms/LeadFixtureReplacementGrants.aspx>.

5. If it hasn't occurred already, a robust communications plan is suggested. Communications plan steps are outlined in the 3Ts Guidelines. This plan will inform the school community of the sampling work the school has done to date and the steps the school will take to correct any issues discovered. GCWW employees can assist with this plan and are available to attend any school meetings to help explain our lead program, the sample results and our partnership with CPS. Sampling results will be posted on the GCWW lead.mygcww.org website.

Greater Cincinnati Water Works takes the presence of lead service lines and the removal of those service lines in our system very seriously. In addition, minimizing the exposure of lead within our preschools, schools, and daycares is one of our highest priorities under our Enhanced Lead Program. Please contact Jim Nelson at 591-6869 if you have any questions.

Thanks again for your partnership with Greater Cincinnati Water Works and your work to further understand the water quality within your building. Your extra steps and care to keep the children in our community safe are appreciated!

Sincerely,



Cathy B. Bailey
Director/Greater Cincinnati Water Works

Cc: Dr. Marilyn Crumpton, Cincinnati Health Department
Dr. Camille Jones, Cincinnati Health Department
Chuck DeJonckheere, Hamilton County Public Health
Sheila Hill-Christian, City of Cincinnati
Verna Arnette, Greater Cincinnati Water Works
Jeff Swertfeger, Greater Cincinnati Water Works
Jason DeLaet, Greater Cincinnati Water Works

Cincinnati Public School - Oyler School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
OYL1	12/8/2016	5:13:00	OYL-FL1-1042HEALTHRR-SINK-OYL1	Lead, ppb	3.24	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL2	12/8/2016	5:13:00	OYL-FL1-1045EXAM1-SINK-OYL2	Lead, ppb	2.16	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL3	12/8/2016	5:15:00	OYL-FL1-1047EXAM2-SINK-OYL3	Lead, ppb	2.77	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL4	12/8/2016	5:15:00	OYL-FL1-1048EXAM3-SINK-OYL4	Lead, ppb	4.75	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL5	12/8/2016	5:17:00	OYL-FL1-1046-SINK-OYL5	Lead, ppb	4.76	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL6	12/8/2016	5:17:00	OYL-FL1-1040HEALTH-SINK-OYL6	Lead, ppb	2.28	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL7	12/8/2016	5:17:00	OYL-FL1-1040HEALTH-DF-OYL7	Lead, ppb	<1	Less than detection level
OYL8	12/8/2016	5:33:00	OYL-FL1-1069WSTAFFRR-SINK-OYL8	Lead, ppb	3.32	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL9	12/8/2016	5:33:00	OYL-FL1-1067MSTAFFRR-SINK-OYL9	Lead, ppb	2.55	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL10	12/8/2016	5:34:00	OYL-FL1-1061STAFFWORKRM-SINK-OYL10	Lead, ppb	<1	Less than detection level
OYL11	12/8/2016	5:34:00	OYL-FL1-1061STAFFWORKRM-DF-OYL11	Lead, ppb	<1	Less than detection level
OYL12	12/8/2016	5:35:00	OYL-FL1-1091WSTAFFRR-SINK-OYL12	Lead, ppb	4.1	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

Cincinnati Public School - Oyler School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
OYL13	12/8/2016	5:35:00	OYL-FL1-1092MSTAFFRR-SINK-OYL13	Lead, ppb	3.74	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL14	12/8/2016	5:38:00	OYL-FL1-1002-SINK-OYL14	Lead, ppb	1.3	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL15	12/8/2016	5:38:00	OYL-FL1-1002-DF-OYL15	Lead, ppb	<1	Less than detection level
OYL16	12/8/2016	5:38:00	OYL-FL1-1002RR-SINK-OYL16	Lead, ppb	4.65	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL17	12/8/2016	5:40:00	OYL-FL1-1001-SINK-OYL17	Lead, ppb	1.2	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL18	12/8/2016	5:40:00	OYL-FL1-1001-DF-OYL18	Lead, ppb	<1	Less than detection level
OYL19	12/8/2016	5:40:00	OYL-FL1-1001RR-SINK-OYL19	Lead, ppb	3.39	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL20	12/8/2016	5:41:00	OYL-FL1-1005-SINK-OYL20	Lead, ppb	<1	Less than detection level
OYL21	12/8/2016	5:41:00	OYL-FL1-1005-DF-OYL21	Lead, ppb	<1	Less than detection level
OYL22	12/8/2016	5:41:00	OYL-FL1-1005RR-SINK-OYL22	Lead, ppb	4.38	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL23	12/8/2016	5:44:00	OYL-FL1-1006-SINK-OYL23	Lead, ppb	1.68	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL24	12/8/2016	5:44:00	OYL-FL1-1006-DF-OYL24	Lead, ppb	<1	Less than detection level
OYL25	12/8/2016	5:46:00	OYL-FL1-HAMPTONRM-SINK-OYL25	Lead, ppb	1.52	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL26	12/8/2016	5:46:00	OYL-FL1-HAMPTONRM-DF-OYL26	Lead, ppb	<1	Less than detection level

Cincinnati Public School - Oyler School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
OYL27	12/8/2016	5:46:00	OYL-FL1-HAMPTONRMRR-SINK-OYL27	Lead, ppb	3.09	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL28	12/8/2016	5:48:00	OYL-FL1-1102BOYSRR-LSINK-OYL28	Lead, ppb	2.97	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL29	12/8/2016	5:48:00	OYL-FL1-1102BOYSRR-MSINK-OYL29	Lead, ppb	3.86	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL30	12/8/2016	5:48:00	OYL-FL1-1102BOYSRR-RSINK-OYL30	Lead, ppb	3.9	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL31	12/8/2016	5:49:00	OYL-FL1-HALLWAYNEAR1102-LDF-OYL31	Lead, ppb	<1	Less than detection level
OYL32	12/8/2016	5:49:00	OYL-FL1-HALLWAYNEAR1102-RDF-OYL32	Lead, ppb	<1	Less than detection level
OYL33	12/8/2016	5:49:00	OYL-FL1-1106STAFFSHOWER-SINK-OYL33	Lead, ppb	3.78	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL34	12/8/2016	5:49:00	OYL-FL1-1110GIRLSRR-LSINK-OYL34	Lead, ppb	3.36	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL35	12/8/2016	5:49:00	OYL-FL1-1110GIRLSRR-MSINK-OYL35	Lead, ppb	3.1	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL36	12/8/2016	5:49:00	OYL-FL1-1110GIRLSRR-RSINK-OYL36	Lead, ppb	2.78	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL37	12/8/2016	5:52:00	OYL-FL1-1111CONCESSIONS-SINK-OYL37	Lead, ppb	1.48	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

Cincinnati Public School - Oyler School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
OYL38	12/8/2016	5:52:00	OYL-FL1-1111CONCESSIONS-DF-OYL38	Lead, ppb	1.28	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL39	12/8/2016	5:52:00	OYL-FL1-1121GYMSTORE-IM-OYL39	Lead, ppb	<1	Less than detection level
OYL40	12/8/2016	5:54:00	OYL-FL1-1008FAMILYRR-SINK-OYL40	Lead, ppb	3.23	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL41	12/8/2016	5:55:00	OYL-FL1-1010-SINK-OYL41	Lead, ppb	3.8	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL42	12/8/2016	5:55:00	OYL-FL1-1010-DF-OYL42	Lead, ppb	<1	Less than detection level
OYL43	12/8/2016	5:56:00	OYL-FL1-1917/1018BOYSRR-FLSINK-OYL43	Lead, ppb	2.59	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL44	12/8/2016	5:56:00	OYL-FL1-1917/1018BOYSRR-LSINK-OYL44	Lead, ppb	2.88	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL45	12/8/2016	5:56:00	OYL-FL1-1917/1018BOYSRR-MSINK-OYL45	Lead, ppb	2.74	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL46	12/8/2016	5:56:00	OYL-FL1-1917/1018BOYSRR-RSINK-OYL46	Lead, ppb	2.71	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL47	12/8/2016	5:56:00	OYL-FL1-1917/1018BOYSRR-FRSINK-OYL47	Lead, ppb	2.93	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL48	12/8/2016	5:58:00	OYL-FL1-1917/1020MSTAFFRR-SINK-OYL48	Lead, ppb	4.76	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

Cincinnati Public School - Oyler School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
OYL49	12/8/2016	5:59:00	OYL-FL1-1918/1022GIRLSRR-FLSINK-OYL49	Lead, ppb	2.45	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL50	12/8/2016	5:59:00	OYL-FL1-1918/1022GIRLSRR-LSINK-OYL50	Lead, ppb	2.83	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL51	12/8/2016	5:59:00	OYL-FL1-1918/1022GIRLSRR-MSINK-OYL51	Lead, ppb	2.94	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL52	12/8/2016	5:59:00	OYL-FL1-1918/1022GIRLSRR-RSINK-OYL52	Lead, ppb	3.2	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL53	12/8/2016	5:59:00	OYL-FL1-1918/1022GIRLSRR-FRSINK-OYL53	Lead, ppb	2.89	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL54	12/8/2016	5:59:00	OYL-FL1-1918/1024WSTAFFRR-SINK-OYL54	Lead, ppb	4.2	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL55	12/8/2016	6:02:00	OYL-FL1-HALLWAYNEAR1918-LDF-OYL55	Lead, ppb	<1	Less than detection level
OYL56	12/8/2016	6:02:00	OYL-FL1-HALLWAYNEAR1918-RDF-OYL56	Lead, ppb	<1	Less than detection level
OYL57	12/8/2016	6:04:00	OYL-FL1-HALLWAYNEAR1050-LDF-OYL57	Lead, ppb	<1	Less than detection level
OYL58	12/8/2016	6:04:00	OYL-FL1-HALLWAYNEAR1050-RDF-OYL58	Lead, ppb	<1	Less than detection level
OYL59	12/8/2016	6:06:00	OYL-FL1-VISION1050-SINK-OYL59	Lead, ppb	1.93	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL60	12/8/2016	6:06:00	OYL-FL1-VISION1058-SINK-OYL60	Lead, ppb	<1	Less than detection level
OYL61	12/8/2016	6:07:00	OYL-FL1-DENTAL2031-SINK-OYL61	Lead, ppb	2.02	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL62	12/8/2016	6:07:00	OYL-FL1-DENTAL2031-DF-OYL62	Lead, ppb	<1	Less than detection level
OYL63	12/8/2016	5:23:00	OYL-FL1-CAFE-COMBOLBF-OYL63	Lead, ppb	<1	Less than detection level

Cincinnati Public School - Oyler School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
OYL64	12/8/2016	5:23:00	OYL-FL1-CAFE-COMBOLDF-OYL64	Lead, ppb	<1	Less than detection level
OYL65	12/8/2016	5:23:00	OYL-FL1-CAFE-RDF-OYL65	Lead, ppb	<1	Less than detection level
OYL66	12/8/2016	5:24:00	OYL-KIT-WASHRM-HANDSINK-OYL66	Lead, ppb	1.25	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL67	12/8/2016	5:24:00	OYL-KIT-WASHRM-LUTILITYSINK-OYL67	Lead, ppb	3.09	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL68	12/8/2016	5:24:00	OYL-KIT-WASHRM-RUTILITYSINK-OYL68	Lead, ppb	2.28	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL69	12/8/2016	5:25:00	OYL-KIT-STOCKPOT-LFILLER-OYL69	Lead, ppb	1.38	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL70	12/8/2016	5:25:00	OYL-KIT-STOCKPOT-RFILLER-OYL70	Lead, ppb	1.63	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL71	12/8/2016	5:26:00	OYL-KIT-NEARSERVELINE-HANDSINK-OYL71	Lead, ppb	3.84	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL72	12/8/2016	5:26:00	OYL-KIT-2TUB-UTILITYSINK-OYL72	Lead, ppb	2.92	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL73	12/8/2016	5:26:00	OYL-KIT-NEAR2TUB-HANDSINK-OYL73	Lead, ppb	3.74	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL74	12/8/2016	5:28:00	OYL-KIT-1TUBPRODUCE-UTILITYSINK-OYL74	Lead, ppb	2.17	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

Cincinnati Public School - Oyler School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
OYL75	12/8/2016	5:28:00	OYL-KIT-1034STAFFRR-SINK-OYL75	Lead, ppb	3.88	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL76	12/8/2016	6:09:00	OYL-FL1-1200RR-SINK-OYL76	Lead, ppb	<1	Less than detection level
OYL77	12/8/2016	6:10:00	OYL-FL1-1200LAUNDRYRM-UTILITY-SINK-OYL77	Lead, ppb	<1	Less than detection level
OYL78	12/8/2016	6:17:00	OYL-FL1-1220INFANTNEARDIAPERSTAT-SINK-OYL78	Lead, ppb	<1	Less than detection level
OYL79	12/8/2016	6:17:00	OYL-FL1-1220INFANTNEARFRIDGE-SINK-OYL79	Lead, ppb	<1	Less than detection level
OYL80	12/8/2016	6:17:00	OYL-FL1-1220INFANTKIDSLOW-SINK-OYL80	Lead, ppb	<1	Less than detection level
OYL81	12/8/2016	6:17:00	OYL-FL1-1220INFANTISLAND-SINK-OYL81	Lead, ppb	<1	Less than detection level
OYL82	12/8/2016	6:19:00	OYL-FL1-1230TODDNEARDIAPERSTAT-SINK-OYL82	Lead, ppb	<1	Less than detection level
OYL83	12/8/2016	6:19:00	OYL-FL1-1230TODDKIDSLOW-LSINK-OYL83	Lead, ppb	<1	Less than detection level
OYL84	12/8/2016	6:19:00	OYL-FL1-1230TODDKIDSLOW-RSINK-OYL84	Lead, ppb	<1	Less than detection level
OYL85	12/8/2016	6:19:00	OYL-FL1-1230TODDNEARFRIDGE-SINK-OYL85	Lead, ppb	1.64	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL86	12/8/2016	6:19:00	OYL-FL1-1230TODDISLAND-SINK-OYL86	Lead, ppb	<1	Less than detection level
OYL87	12/8/2016	6:19:00	OYL-FL1-1230TODDRR-SINK-OYL87	Lead, ppb	<1	Less than detection level
OYL88	12/8/2016	6:24:00	OYL-FL1-1240PKRR-LSINK-OYL88	Lead, ppb	<1	Less than detection level
OYL89	12/8/2016	6:24:00	OYL-FL1-1240PKRR-RSINK-OYL89	Lead, ppb	<1	Less than detection level
OYL90	12/8/2016	6:24:00	OYL-FL1-1240PKKIDSLOW-LSINK-OYL90	Lead, ppb	<1	Less than detection level
OYL91	12/8/2016	6:24:00	OYL-FL1-1240PKKIDSLOW-RSINK-OYL91	Lead, ppb	1.39	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL92	12/8/2016	6:24:00	OYL-FL1-1240PKISLAND-SINK-OYL92	Lead, ppb	<1	Less than detection level
OYL93	12/8/2016	6:24:00	OYL-FL1-1240PKNEARFRIDGE-SINK-OYL93	Lead, ppb	<1	Less than detection level
OYL94	12/8/2016	5:16:00	OYL-FL2-2040-SINK-OYL94	Lead, ppb	5.88	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL95	12/8/2016	5:17:00	OYL-FL2-2040-DF-OYL95	Lead, ppb	<1	Less than detection level
OYL96	12/8/2016	5:22:00	OYL-FL2-2039FRONTDESK-SINK-OYL96	Lead, ppb	5.25	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

Cincinnati Public School - Oyler School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
OYL97	12/8/2016	5:26:00	OYL-FL2-2039BACKLEFTWALL-LSINK-OYL97	Lead, ppb	<1	Less than detection level
OYL98	12/8/2016	5:27:00	OYL-FL2-2039BACKLEFTWALL-RSINK-OYL98	Lead, ppb	2.96	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL99	12/8/2016	5:22:00	OYL-FL2-2039FRONTLEFTWALL-FLSINK-OYL99	Lead, ppb	1.64	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL100	12/8/2016	5:23:00	OYL-FL2-2039FRONTLEFTWALL-LSINK-OYL100	Lead, ppb	<1	Less than detection level
OYL101	12/8/2016	5:50:00	OYL-FL3-3006FRONTRIGHTOUTSIDEDESK-RSINK-OYL101	Lead, ppb	3.6	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL102	12/8/2016	5:24:00	OYL-FL2-2039FRONTLEFTWALL-RSINK-OYL102	Lead, ppb	<1	Less than detection level
OYL103	12/8/2016	5:25:00	OYL-FL2-2039FRONTLEFTWALL-FRSINK-OYL103	Lead, ppb	<1	Less than detection level
OYL104	12/8/2016	5:28:00	OYL-FL2-HALLWAYNEAR2034-LDF-OYL104	Lead, ppb	<1	Less than detection level
OYL105	12/8/2016	5:29:00	OYL-FL2-HALLWAYNEAR2034-RDF-OYL105	Lead, ppb	<1	Less than detection level
OYL106	12/8/2016	5:31:00	OYL-FL2-2032-SINK-OYL106	Lead, ppb	1.37	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL107	12/8/2016	5:32:00	OYL-FL2-2032-DF-OYL107	Lead, ppb	<1	Less than detection level
OYL108	12/8/2016	5:33:00	OYL-FL2-2030-SINK-OYL108	Lead, ppb	1.33	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL109	12/8/2016	5:34:00	OYL-FL2-2030-DF-OYL109	Lead, ppb	<1	Less than detection level
OYL110	12/8/2016	5:36:00	OYL-FL2-2027STAFFWORK-SINK-OYL110	Lead, ppb	<1	Less than detection level
OYL111	12/8/2016	5:37:00	OYL-FL2-2027STAFFWORK-DF-OYL111	Lead, ppb	<1	Less than detection level
OYL112	12/8/2016	5:39:00	OYL-FL2-2911/2022GIRLSRR-FLSINK-OYL112	Lead, ppb	2.86	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL113	12/8/2016	5:40:00	OYL-FL2-2911/2022GIRLSRR-LSINK-OYL113	Lead, ppb	3.17	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

Cincinnati Public School - Oyler School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
OYL114	12/8/2016	5:41:00	OYL-FL2-2911/2022GIRLSRR-MSINK-OYL114	Lead, ppb	3.08	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL115	12/8/2016	5:42:00	OYL-FL2-2911/2022GIRLSRR-RSINK-OYL115	Lead, ppb	2.59	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL116	12/8/2016	5:43:00	OYL-FL2-2911/2022GIRLSRR-FRSINK-OYL116	Lead, ppb	2.68	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL117	12/8/2016	5:44:00	OYL-FL2-2911/2024WSTAFFRR-SINK-OYL117	Lead, ppb	3.22	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL118	12/8/2016	5:45:00	OYL-FL2-2910/2018BOYSRR-FLSINK-OYL118	Lead, ppb	2.59	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL119	12/8/2016	5:46:00	OYL-FL2-2910/2018BOYSRR-LSINK-OYL119	Lead, ppb	2.44	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL120	12/8/2016	5:47:00	OYL-FL2-2910/2018BOYSRR-MSINK-OYL120	Lead, ppb	2.46	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL121	12/8/2016	5:48:00	OYL-FL2-2910/2018BOYSRR-RSINK-OYL121	Lead, ppb	2.48	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL122	12/8/2016	5:49:00	OYL-FL2-2910/2018BOYSRR-FRSINK-OYL122	Lead, ppb	2.43	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL123	12/8/2016	5:49:00	OYL-FL2-2910/2020MSTAFFRR-SINK-OYL123	Lead, ppb	4.03	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

Cincinnati Public School - Oyler School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
OYL124	12/8/2016	5:51:00	OYL-FL2-2025MUSIC-SINK-OYL124	Lead, ppb	<1	Less than detection level
OYL125	12/8/2016	5:52:00	OYL-FL2-2025MUSIC-DF-OYL125	Lead, ppb	<1	Less than detection level
OYL126	12/8/2016	5:55:00	OYL-FL2-2017ART-LSINK-OYL126	Lead, ppb	1.1	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL127	12/8/2016	5:56:00	OYL-FL2-2017ART-LDF-OYL127	Lead, ppb	<1	Less than detection level
OYL128	12/8/2016	5:57:00	OYL-FL2-2017ART-MSINK-OYL128	Lead, ppb	1.08	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL129	12/8/2016	5:58:00	OYL-FL2-2017ART-MDF-OYL129	Lead, ppb	1.37	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL130	12/8/2016	5:59:00	OYL-FL2-2017ART-RSINK-OYL130	Lead, ppb	1.52	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL131	12/8/2016	6:00:00	OYL-FL2-2017ART-RDF-OYL131	Lead, ppb	1.23	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL132	12/8/2016	6:01:00	OYL-FL2-HALLWAYNEAR2017-LDF-OYL132	Lead, ppb	<1	Less than detection level
OYL133	12/8/2016	6:02:00	OYL-FL2-HALLWAYNEAR2017-RDF-OYL133	Lead, ppb	<1	Less than detection level
OYL134	12/8/2016	6:03:00	OYL-FL2-2013-SINK-OYL134	Lead, ppb	2.35	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL135	12/8/2016	6:03:00	OYL-FL2-2013-DF-OYL135	Lead, ppb	1.27	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL136	12/8/2016	6:04:00	OYL-FL2-2013RR2015-SINK-OYL136	Lead, ppb	9.77	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

Cincinnati Public School - Oyler School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
OYL137	12/8/2016	6:05:00	OYL-FL2-2010-SINK-OYL137	Lead, ppb	1.39	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL138	12/8/2016	6:06:00	OYL-FL2-2010-DF-OYL138	Lead, ppb	1.21	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL139	12/8/2016	6:09:00	OYL-FL2-2009-SINK-OYL139	Lead, ppb	2.22	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL140	12/8/2016	6:09:00	OYL-FL2-2009-DF-OYL140	Lead, ppb	1.09	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL141	12/8/2016	6:08:00	OYL-FL2-2007-SINK-OYL141	Lead, ppb	1.65	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL142	12/8/2016	6:09:00	OYL-FL2-2007-DF-OYL142	Lead, ppb	1.18	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL143	12/8/2016	6:11:00	OYL-FL2-2005-SINK-OYL143	Lead, ppb	1.61	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL144	12/8/2016	6:11:00	OYL-FL2-2005-DF-OYL144	Lead, ppb	1.09	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL145	12/8/2016	6:10:00	OYL-FL2-2006-SINK-OYL145	Lead, ppb	4.65	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL146	12/8/2016	6:11:00	OYL-FL2-2006-DF-OYL146	Lead, ppb	1.18	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

Cincinnati Public School - Oyler School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
OYL147	12/8/2016	6:13:00	OYL-FL2-2004-SINK-OYL147	Lead, ppb	1.34	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL148	12/8/2016	6:13:00	OYL-FL2-2004-DF-OYL148	Lead, ppb	1.15	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL149	12/8/2016	6:12:00	OYL-FL2-2003-SINK-OYL149	Lead, ppb	3.25	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL150	12/8/2016	6:13:00	OYL-FL2-2003-DF-OYL150	Lead, ppb	<1	Less than detection level
OYL151	12/8/2016	6:15:00	OYL-FL2-2001-SINK-OYL151	Lead, ppb	2.47	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL152	12/8/2016	6:15:00	OYL-FL2-2001-DF-OYL152	Lead, ppb	1.21	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL153	12/8/2016	6:15:00	OYL-FL2-2002-SINK-OYL153	Lead, ppb	2.25	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL154	12/8/2016	6:16:00	OYL-FL2-2002-DF-OYL154	Lead, ppb	1.31	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL155	12/8/2016	5:28:00	OYL-FL3-3018-SINK-OYL155	Lead, ppb	<1	Less than detection level
OYL156	12/8/2016	5:28:00	OYL-FL3-3018-DF-OYL156	Lead, ppb	<1	Less than detection level
OYL157	12/8/2016	5:33:00	OYL-FL3-3016-SINK-OYL157	Lead, ppb	1.28	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL158	12/8/2016	5:33:00	OYL-FL3-3016-DF-OYL158	Lead, ppb	<1	Less than detection level

Cincinnati Public School - Oyler School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
OYL159	12/8/2016	5:39:00	OYL-FL3-3911/3012GIRLSRR-FLSINK-OYL159	Lead, ppb	2.68	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL160	12/8/2016	5:39:00	OYL-FL3-3911/3012GIRLSRR-LSINK-OYL160	Lead, ppb	2.52	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL161	12/8/2016	5:40:00	OYL-FL3-3911/3012GIRLSRR-MSINK-OYL161	Lead, ppb	2.63	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL162	12/8/2016	5:40:00	OYL-FL3-3911/3012GIRLSRR-RSINK-OYL162	Lead, ppb	2.85	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL163	12/8/2016	5:41:00	OYL-FL3-3911/3012GIRLSRR-FRSINK-OYL163	Lead, ppb	2.48	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL164	12/8/2016	5:36:00	OYL-FL3-3911/3014WSTAFFRR-SINK-OYL164	Lead, ppb	2.79	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL165	12/8/2016	5:44:00	OYL-FL3-3910/3008BOUYSRR-FLSINK-OYL165	Lead, ppb	2.44	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL166	12/8/2016	5:44:00	OYL-FL3-3910/3008BOUYSRR-LSINK-OYL166	Lead, ppb	2.47	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL167	12/8/2016	5:45:00	OYL-FL3-3910/3008BOUYSRR-MSINK-OYL167	Lead, ppb	2.33	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL168	12/8/2016	5:45:00	OYL-FL3-3910/3008BOUYSRR-RSINK-OYL168	Lead, ppb	2.56	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

Cincinnati Public School - Oyler School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
OYL169	12/8/2016	5:46:00	OYL-FL3-3910/3008BOUYSTRR-FRSINK-OYL169	Lead, ppb	2.91	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL170	12/8/2016	5:47:00	OYL-FL3-3910/3010MSTAFFRR-SINK-OYL170	Lead, ppb	3.21	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL171	12/8/2016	6:03:00	OYL-FL3-3015FRONT-SINK-OYL171	Lead, ppb	1.5	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL172	12/8/2016	6:03:00	OYL-FL3-3015FRONT-DF-OYL172	Lead, ppb	<1	Less than detection level
OYL173	12/8/2016	6:04:00	OYL-FL3-3015BACK-SINK-OYL173	Lead, ppb	1.96	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL174	12/8/2016	6:04:00	OYL-FL3-3015BACK-DF-OYL174	Lead, ppb	1.3	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL175	12/8/2016	5:23:00	OYL-FL3-HALLWAYNEAR3011-LDF-OYL175	Lead, ppb	<1	Less than detection level
OYL176	12/8/2016	5:23:00	OYL-FL3-HALLWAYNEAR3011-RDF-OYL176	Lead, ppb	<1	Less than detection level
OYL177	12/8/2016	5:25:00	OYL-FL3-3011-SINK-OYL177	Lead, ppb	2.6	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL178	12/8/2016	5:25:00	OYL-FL3-3011-DF-OYL178	Lead, ppb	<1	Less than detection level
OYL179	12/8/2016	5:20:00	OYL-FL3-3009-SINK-OYL179	Lead, ppb	1.12	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL180	12/8/2016	5:20:00	OYL-FL3-3009-DF-OYL180	Lead, ppb	<1	Less than detection level
OYL181	12/8/2016	5:52:00	OYL-FL3-HALLWAYNEAR3002-LDF-OYL181	Lead, ppb	<1	Less than detection level
OYL182	12/8/2016	5:53:00	OYL-FL3-HALLWAYNEAR3002-RDF-OYL182	Lead, ppb	<1	Less than detection level
OYL183	12/8/2016	5:56:00	OYL-FL3-3002LEFTWALL-FLSINK-OYL183	Lead, ppb	3.63	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

Cincinnati Public School - Oyler School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
OYL184	12/8/2016	5:57:00	OYL-FL3-3002LEFTWALL-LSINK-OYL184	Lead, ppb	7.64	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL185	12/8/2016	5:57:00	OYL-FL3-3002LEFTWALL-MSINK-OYL185	Lead, ppb	4.37	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL186	12/8/2016	5:58:00	OYL-FL3-3002LEFTWALL-RSINK-OYL186	Lead, ppb	8.5	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL187	12/8/2016	5:58:00	OYL-FL3-3002LEFTWALL-FRSINK-OYL187	Lead, ppb	4.63	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL188	12/8/2016	5:59:00	OYL-FL3-3002BACKWALL-LSINK-OYL188	Lead, ppb	2.51	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL189	12/8/2016	5:59:00	OYL-FL3-3002BACKWALL-RSINK-OYL189	Lead, ppb	1.56	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL190	12/8/2016	5:51:00	OYL-FL3-3004-SINK-OYL190	Lead, ppb	3.38	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
OYL191	12/8/2016	5:49:00	OYL-FL3-3006FRONTDESK-SINK-OYL191	Lead, ppb	2.97	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.