



Cincinnati Public Schools - Lead Testing Results per school							
SCHOOL	SAMPLE DATE	SAMPLE TIME	SAMPLE NAME	PARAMETER CODE	AMOUNT	COMMENTS REGARDING SAMPLING PROCESS	GCWW COMMENTS/REVIEW/RECOMMENDATIONS
Silverton Paideia Academy	5/11/2016	6:25 AM	CPS_SILVERTON_KITCHEN_CME2016-050	Lead, ppb	3.82		Lead detected at 1 of 3 sample points. Conduct a plumbing profile to understand the material of the fixtures at sample points. Review 3Ts guidelines to understand options to reduce lead. CPS should follow 3Ts guidelines and sample at all drinking water and cooking outlets within the school (may result in 40-45 samples per school).
Silverton Paideia Academy	5/11/2016	6:35 AM	CPS_SILVERTON_FARTHESTPOINT_CME2016-051	Lead, ppb	<1		
Silverton Paideia Academy	5/19/2016	6:15 AM	CPS_SILVERTON_RM1135_CME2016-049	Lead, ppb	<1		

<1 ppb = below detection level. No lead was detected.