



**Cincinnati Public Schools - Lead Testing Results per school**

SCHOOL	SAMPLE DATE	SAMPLE TIME	SAMPLE NAME	PARAMETER CODE	AMOUNT	COMMENTS REGARDING SAMPLING PROCESS	GCWW COMMENTS/REVIEW/RECOMMENDATIONS
Spencer Education Center	5/25/2016	6:40 AM	CPS_SPENCER_KITCHEN_CME2016-091	Lead, ppb	11.6		Lead detected at 3 of 3 sample points. Conduct a plumbing profile to understand the material of the fixtures at sample points. Review 3Ts guidelines to understand options to reduce lead. CPS should follow 3T guidelines and sample at all drinking water and cooking outlets within the school (may result in 40-45 samples per school).
Spencer Education Center	5/25/2016	6:45 AM	CPS_SPENCER_NEARRM111_CME2016-092	Lead, ppb	2.54		
Spencer Education Center	5/25/2016	6:50 AM	CPS_SPENCER_NEARRM208_CME3016-093	Lead, ppb	8.03		