



October 28, 2016

**Gamble Montessori
High School**

Cincinnati Public Schools
Cynthia Eghbalnia
2651 Burnet Avenue
Cincinnati, OH 45219

Dear Cynthia:

Attached please find the results of the lead analyses performed for Gamble Montessori High School by the Greater Cincinnati Water Works (GCWW). The following comments speak to the process, samples analyzed and additional steps needed to help ensure the safety of all the students within the school.

School Sampling Process and Results

GCWW and Cincinnati Public Schools (CPS) staff worked together to finalize a sampling plan for the school. The *USEPA 3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance Document (3Ts Guidelines)* is the process and guidelines used for assisting schools with testing for lead.

Early October, eighty-seven (87) samples were collected from drinking fountains and sinks throughout the school. Multiple sinks within the school were not initially considered for testing, however, key nearby indicators (coffee makers, drinking cups, plates, utensils, etc.) prompted these locations to be tested. Including these sampling locations speaks to the proactive approach CPS continues to have towards understanding the water quality within the schools.

Five additional locations were not sampled [duplicate (1), sample location did not exist (1), utility sink (2), and sink not working (1)]. The results show the following:

- 17 samples (19.54%), below the detection level (<1)
- 41 samples (47.12%), between 1ppb and 5ppb
- 21 samples (24.14%), between 5ppb and 10ppb
- 4 samples (4.60%), between 10ppb and 15ppb
- 4 samples (4.60%) greater than 15ppb.

Eighty percent (80.46%) of the samples analyzed had some level of lead detection.

Fifteen parts per billion (ppb) is the federal Lead and Copper Rule action level; desired results are below 15. The federal action level of 15ppb pertains to water utilities and GCWW's review and comments are based on this action level. However, the USEPA 3Ts Guidelines document outlines practices for schools to put in place if samples are greater than 20 ppb.

While we strive to have results less than 15, we recognize that lead is a pervasive environmental contaminant, and no safe blood lead threshold has been identified in children or adults. Therefore, we provide recommendations to further reduce any lead levels discovered at drinking water and cooking outlets.



Next steps

GCWW has reviewed the results from your samples and provides some next-steps comments:

1. For results greater than 15 ppb, consider immediate remedies such as taking the sample location out of service until a more defined plan can be created. Refer to the 3Ts Guidelines that suggest shutting off or disconnecting problem outlets until the problem is resolved.
2. Although lower than the 15 ppb action level, for samples with lead detections, consider flushing the lines before using the water. Refer to the USEPA 3Ts Guidelines for more information.
3. Consider completing a plumbing profile to review the fixtures in the school as some fixtures may be contributing to the lead detections in samples. If the fixtures are the source of the lead, plan to replace them. The USEPA 3Ts Guidelines outlines a great approach to creating and implementing a remediation plan. A copy of the Guidelines can be found on our website <http://www.cincinnati-oh.gov/water/assets/File/3T%20Guidance%20Manual%20for%20Schools.pdf>.

State funds are available through the new Lead Plumbing Fixture Replacement Assistance Grant Program established to provide reimbursement to eligible schools for the assessment and replacement of certain plumbing fixtures. The program is open to traditional public schools, community schools, and chartered non-public schools. Program information can be found on the Ohio Facilities Construction Commission (OFCC) Services and Programs website <http://ofcc.ohio.gov/ServicesPrograms/LeadFixtureReplacementGrants.aspx>.

4. If it hasn't occurred already, a robust communications plan is suggested. Communications plan steps are outlined in the 3Ts Guidelines. This plan will inform the school community of the sampling work the school has done to date and the steps the school will take to correct any issues discovered. GCWW employees can assist with this plan and are available to attend any school meetings to help explain our lead program, the sample results and our partnership with CPS. Sampling results will be posted on the GCWW lead.mygcww.org website with other school sampling results.

Greater Cincinnati Water Works takes the presence of lead service lines and the removal of those service lines in our system very seriously. In addition, minimizing the exposure of lead within our preschools, schools, and daycares is one of our highest priorities under our Enhanced Lead Program. We look forward to our continued partnership with Cincinnati Public Schools. Our resources are available to assist in many ways. Please contact Jim Nelson at 591-6869 to discuss how we can assist with next steps within your school.

Sincerely,



Cathy B. Bailey
Director/Greater Cincinnati Water Works

Cc: Dr. Marilyn Crumpton, Cincinnati Health Department
Dr. Camille Jones, Cincinnati Health Department
Chuck DeJonckheere, Hamilton County Public Health
Sheila Hill-Christian, City of Cincinnati
Verna Arnette, Greater Cincinnati Water Works
Jeff Swertfeger, Greater Cincinnati Water Works



Cincinnati Public Schools - Gamble (James N.) Montessori High School- Lead Testing Results

SAMPLE #	SCHOOL	SAMPLE DATE	SAMPLE TIME	SAMPLE NAME	PARAMETER CODE	LEAD, PPB	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
GAM1	Gamble Montessori High School	10/6/2016	6:28	GAM-BASEMENT-KITCHEN-FRUITSSINK	Lead, ppb	2.21	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM2	Gamble Montessori High School	10/6/2016	6:28	GAM-BASEMENT-KITCHEN-STOCKPOT	Lead, ppb	<1	Less than detection level
GAM3	Gamble Montessori High School	10/6/2016	6:30	GAM-BASEMENT-KITCHENBYSTOCKPOT-SINK	Lead, ppb	5.06	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM4	Gamble Montessori High School	10/6/2016	6:30	GAM-BASEMENT-KITCHEN-LWASHSINK	Lead, ppb	<1	Less than detection level
GAM5	Gamble Montessori High School	10/6/2016	6:30	GAM-BASEMENT-KITCHEN-RWASHSINK	Lead, ppb	9.41	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM6	Gamble Montessori High School	10/6/2016	6:32	GAM-BASEMENT-KITCHEN-UTILITYSINK	Lead, ppb	<1	Less than detection level
GAM7	Gamble Montessori High School	10/6/2016	6:32	GAM-BASEMENT-KITCHENBYUTILITYSINK-SINK	Lead, ppb	2.93	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM8	Gamble Montessori High School	10/6/2016	6:33	GAM-BASEMENT-0018-SINK	Lead, ppb	27.5	Above 15ppb federal action level and 20ppb level identified by USEPA to trigger schools to take action to reduce lead. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).



Cincinnati Public Schools - Gamble (James N.) Montessori High School- Lead Testing Results

SAMPLE #	SCHOOL	SAMPLE DATE	SAMPLE TIME	SAMPLE NAME	PARAMETER CODE	LEAD, PPB	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
GAM9	Gamble Montessori High School	10/6/2016	6:34	GAM-BASEMENT-NEATCASHIER-SINK	Lead, ppb	17.6	Results are above 15ppb federal action level. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
GAM10	Gamble Montessori High School	10/6/2016	6:35	GAM-BASEMENT-CAFETERIA-COMBODF	Lead, ppb	<1	Less than detection level
GAM11	Gamble Montessori High School	10/6/2016	6:35	GAM-BASEMENT-CAFETERIA-COMBOBF	Lead, ppb	<1	Less than detection level
GAM12	Gamble Montessori High School	10/6/2016	6:35	GAM-BASEMENT-CAFETERIA-DF	Lead, ppb	6.57	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM13	Gamble Montessori High School	10/6/2016	6:40	GAM-BASEMENT-BOYSRR0022-LSINK	Lead, ppb	6.92	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM14	Gamble Montessori High School	10/6/2016	6:40	GAM-BASEMENT-BOYSRR0022-RSINK	Lead, ppb	2.79	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM15	Gamble Montessori High School	10/6/2016	6:40	GAM-BASEMENT-GIRLSRR0023-LSINK	Lead, ppb	4.21	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM16	Gamble Montessori High School	10/6/2016	6:41	GAM-BASEMENT-GIRLSRR0023-MSINK	Lead, ppb	2.47	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM17	Gamble Montessori High School	10/6/2016	6:41	GAM-BASEMENT-GIRLSRR0023-RSINK	Lead, ppb	4.52	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.



Cincinnati Public Schools - Gamble (James N.) Montessori High School- Lead Testing Results

SAMPLE #	SCHOOL	SAMPLE DATE	SAMPLE TIME	SAMPLE NAME	PARAMETER CODE	LEAD, PPB	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
GAM18	Gamble Montessori High School	10/7/2016	7:08	GAM-BASEMENT-JANITRESS-SINK	Lead, ppb	3.08	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM19	Gamble Montessori High School	10/6/2016	6:40	GAM-BASEMENT-KITCHENRR-LSINK	Lead, ppb	3.72	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM20	Gamble Montessori High School	10/6/2016	6:40	GAM-BASEMENT-KITCHENRR-RSINK	Lead, ppb	2.97	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM21	Gamble Montessori High School	10/6/2016	6:42	GAM-BASEMENT-HALLWAYBYKITCHEN-DF	Lead, ppb	1.36	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM22	Gamble Montessori High School	10/6/2016	6:46	GAM-BASEMENT-WLOCKER-SINK	Lead, ppb	<1	Less than detection level
GAM23	Gamble Montessori High School	10/6/2016	6:46	GAM-BASEMENT-WLOCKERRR-SINK	Lead, ppb	<1	Less than detection level
GAM24	Gamble Montessori High School	10/6/2016	6:46	GAM-BASEMENT-WLOCKERHANDYCAPRR-SINK	Lead, ppb	<1	Less than detection level
GAM25	Gamble Montessori High School	10/6/2016	6:48	GAM-BASEMENT-LAUNDRY-SINK	Lead, ppb	2.1	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM26	Gamble Montessori High School	10/6/2016	6:49	GAM-BASEMENT-MLOCKER-ICEMACHINE	Lead, ppb	<1	Less than detection level
GAM27	Gamble Montessori High School	10/6/2016	N/A	GAM-BASEMENT-MLOCKERRR-LSINK	Lead, ppb	N/A	Does not exist. Only one sink in locker room.
GAM28	Gamble Montessori High School	10/6/2016	6:51	GAM-BASEMENT-MLOCKERRR-RSINK	Lead, ppb	<1	Less than detection level



Cincinnati Public Schools - Gamble (James N.) Montessori High School- Lead Testing Results

SAMPLE #	SCHOOL	SAMPLE DATE	SAMPLE TIME	SAMPLE NAME	PARAMETER CODE	LEAD, PPB	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
GAM29	Gamble Montessori High School	10/6/2016	6:58	GAM-FL1-BOYSRR1105-LSINK	Lead, ppb	1.29	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM30	Gamble Montessori High School	10/6/2016	6:58	GAM-FL1-BOYSRR1105-RSINK	Lead, ppb	1.98	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM31	Gamble Montessori High School	10/6/2016	6:59	GAM-FL1-HALLWAYNEAR1106-DF	Lead, ppb	1.29	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM32	Gamble Montessori High School	10/6/2016	7:00	GAM-FL1-GIRLSRR1108-LSINK	Lead, ppb	<1	Less than detection level
GAM33	Gamble Montessori High School	10/6/2016	7:00	GAM-FL1-GIRLSRR1108-MSINK	Lead, ppb	1.5	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM34	Gamble Montessori High School	10/6/2016	7:01	GAM-FL1-GIRLSRR1108-RSINK	Lead, ppb	1.23	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM35	Gamble Montessori High School	10/6/2016	N/A	GAM-FL1-HALLWAYNEAR1110-DF	Lead, ppb	N/A	Not sampled; duplicate of GAM31
GAM36	Gamble Montessori High School	10/6/2016	7:03	GAM-FL1-1111-SINK	Lead, ppb	<1	Less than detection level
GAM37	Gamble Montessori High School	10/6/2016	7:04	GAM-FL1-HALLWAYNEAR1114-DF	Lead, ppb	<1	Less than detection level
GAM38	Gamble Montessori High School	10/6/2016	7:06	GAM-FL1-1033RR-SINK	Lead, ppb	3.35	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.



Cincinnati Public Schools - Gamble (James N.) Montessori High School- Lead Testing Results

SAMPLE #	SCHOOL	SAMPLE DATE	SAMPLE TIME	SAMPLE NAME	PARAMETER CODE	LEAD, PPB	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
GAM39	Gamble Montessori High School	10/6/2016	7:07	GAM-FL1-MAINOFFICELRR-SINK	Lead, ppb	6.92	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM40	Gamble Montessori High School	10/6/2016	7:07	GAM-FL1-MAINOFFICERRR-SINK	Lead, ppb	1.25	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM41	Gamble Montessori High School	10/6/2016	6:54	GAM-FL1-1021RR-SINK	Lead, ppb	14	Lead detected; less than 15ppb action level. Although not above the action level, work swiftly to reduce lead levels at this location. Consider flushing water before use. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM42	Gamble Montessori High School	10/6/2016	6:54	GAM-FL1-1023RR-SINK	Lead, ppb	2.98	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM43	Gamble Montessori High School	10/6/2016	6:54	GAM-FL1-1025COACHOFFICERR-SINK	Lead, ppb	2.76	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM44	Gamble Montessori High School	10/6/2016	7:08	GAM-FL1-GYM-DF	Lead, ppb	<1	Less than detection level
GAM45	Gamble Montessori High School	10/6/2016	7:08	GAM-FL1-HALLWAYNEARGYM-DF	Lead, ppb	<1	Less than detection level
GAM46	Gamble Montessori High School	10/6/2016	7:12	GAM-FL1-GIRLSRR-FLSINK	Lead, ppb	6.03	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM47	Gamble Montessori High School	10/6/2016	7:12	GAM-FL1-GIRLSRR-LSINK	Lead, ppb	<1	Less than detection level



Cincinnati Public Schools - Gamble (James N.) Montessori High School- Lead Testing Results

SAMPLE #	SCHOOL	SAMPLE DATE	SAMPLE TIME	SAMPLE NAME	PARAMETER CODE	LEAD, PPB	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
GAM48	Gamble Montessori High School	10/6/2016	7:13	GAM-FL1-GIRLSRR-RSINK	Lead, ppb	2.24	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM49	Gamble Montessori High School	10/6/2016	7:13	GAM-FL1-GIRLSRR-FRSINK	Lead, ppb	1.06	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM50	Gamble Montessori High School	10/6/2016	7:14	GAM-FL1-BOYSRR-LSINK	Lead, ppb	<1	Less than detection level
GAM51	Gamble Montessori High School	10/6/2016	7:14	GAM-FL1-BOYSRR-RSINK	Lead, ppb	2.18	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM52	Gamble Montessori High School	10/6/2016	7:15	GAM-FL1-1117-SINK	Lead, ppb	7.31	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM53	Gamble Montessori High School	10/6/2016	7:16	GAM-FL1-1056-SINK	Lead, ppb	2.56	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM54	Gamble Montessori High School	10/6/2016	7:17	GAM-FL1-1068DESK-FRONT-SINK	Lead, ppb	14	Lead detected; less than 15ppb action level. Although not above the action level, work swiftly to reduce lead levels at this location. Consider flushing water before use. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM55	Gamble Montessori High School	10/6/2016	7:17	GAM-FL1-1068DESK-BACKSINK	Lead, ppb	4.44	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.



Cincinnati Public Schools - Gamble (James N.) Montessori High School- Lead Testing Results

SAMPLE #	SCHOOL	SAMPLE DATE	SAMPLE TIME	SAMPLE NAME	PARAMETER CODE	LEAD, PPB	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
GAM56	Gamble Montessori High School	10/6/2016	7:18	GAM-FL1-1068SCIENCESTORAGE-SINK	Lead, ppb	88.4	Above 15ppb federal action level and 20ppb level identified by USEPA to trigger schools to take action to reduce lead. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
GAM57	Gamble Montessori High School	10/6/2016	7:18	GAM-FL1-1068-CORNERSINK	Lead, ppb	13.4	Lead detected; less than 15ppb action level. Although not above the action level, work swiftly to reduce lead levels at this location. Consider flushing water before use. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM58	Gamble Montessori High School	10/6/2016	7:19	GAM-FL1-1121-SINK	Lead, ppb	5.68	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM59	Gamble Montessori High School	10/6/2016	7:19	GAM-FL1-HALLWAYNEAR1122-DF	Lead, ppb	1.27	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM60	Gamble Montessori High School	10/6/2016	7:20	GAM-FL1-1122DESK-BACKSINK	Lead, ppb	6.6	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM61	Gamble Montessori High School	10/6/2016	7:22	GAM-FL1-1122-CORNERSINK	Lead, ppb	4.14	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM62	Gamble Montessori High School	10/6/2016	7:26	GAM-FL1-1123-SINK	Lead, ppb	2.52	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.



Cincinnati Public Schools - Gamble (James N.) Montessori High School- Lead Testing Results

SAMPLE #	SCHOOL	SAMPLE DATE	SAMPLE TIME	SAMPLE NAME	PARAMETER CODE	LEAD, PPB	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
GAM63	Gamble Montessori High School	10/6/2016	7:26	GAM-FL1-1123-DF	Lead, ppb	4.02	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM64	Gamble Montessori High School	10/6/2016	7:27	GAM-FL1-1124DESK-FRONT-SINK	Lead, ppb	31.5	Above 15ppb federal action level and 20ppb level identified by USEPA to trigger schools to take action to reduce lead. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
GAM65	Gamble Montessori High School	10/6/2016	7:28	GAM-FL1-1124DESK-BACK-SINK	Lead, ppb	4.96	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM66	Gamble Montessori High School	10/7/2016	6:45	GAM-FL1-HALLWAYNEAR1126-DF	Lead, ppb	1.03	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM67	Gamble Montessori High School	10/7/2016	6:47	GAM-FL1-1126-CORNER-SINK	Lead, ppb	8.42	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM68	Gamble Montessori High School	10/7/2016	6:47	GAM-FL1-1126-WINDOWS-SINK	Lead, ppb	6.27	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM69	Gamble Montessori High School	10/7/2016	6:48	GAM-FL1-1127-SINK	Lead, ppb	7.58	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.



Cincinnati Public Schools - Gamble (James N.) Montessori High School- Lead Testing Results

SAMPLE #	SCHOOL	SAMPLE DATE	SAMPLE TIME	SAMPLE NAME	PARAMETER CODE	LEAD, PPB	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
GAM70	Gamble Montessori High School	10/7/2016	6:48	GAM-FL1-1127-DF	Lead, ppb	7.64	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM71	Gamble Montessori High School	10/7/2016	6:49	GAM-FL1-1130-SINK	Lead, ppb	9.04	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM72	Gamble Montessori High School	10/7/2016	6:49	GAM-FL1-1130-DF	Lead, ppb	4.93	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM73	Gamble Montessori High School	10/7/2016	7:06	GAM-FL2-2201-SINK	Lead, ppb	8.87	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM74	Gamble Montessori High School	10/7/2016	7:06	GAM-FL2-2202-SINK	Lead, ppb	8.56	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM75	Gamble Montessori High School	10/7/2016	7:05	GAM-FL2-2203-SINK	Lead, ppb	8.25	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM76	Gamble Montessori High School	10/7/2016	7:04	GAM-FL2-2204-DESK-FRONT SINK	Lead, ppb	6.08	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM77	Gamble Montessori High School	10/7/2016	7:22	GAM-FL2-2204DESK-BACKSINK	Lead, ppb	10.8	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.



Cincinnati Public Schools - Gamble (James N.) Montessori High School- Lead Testing Results

SAMPLE #	SCHOOL	SAMPLE DATE	SAMPLE TIME	SAMPLE NAME	PARAMETER CODE	LEAD, PPB	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
GAM78	Gamble Montessori High School	10/7/2016	7:21	GAM-FL2-HALLWAYNEAR2204-DF	Lead, ppb	4.1	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM79	Gamble Montessori High School	10/7/2016	7:20	GAM-FL2-2205-FRONTLSINK	Lead, ppb	1.42	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM80	Gamble Montessori High School	10/7/2016	7:00	GAM-FL2-2205-FRONTRSINK	Lead, ppb	2.14	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM81	Gamble Montessori High School	10/7/2016	6:57	GAM-FL2-2205-BACKLSINK	Lead, ppb	6.77	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM82	Gamble Montessori High School	10/7/2016	6:57	GAM-FL2-2205-BACKMSINK	Lead, ppb	5.16	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM83	Gamble Montessori High School	10/7/2016	6:57	GAM-FL2-2205-BACKRSINK	Lead, ppb	5.19	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM84	Gamble Montessori High School	10/7/2016	6:56	GAM-FL2-BOYSRR-LSINK	Lead, ppb	4.77	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM85	Gamble Montessori High School	10/7/2016	6:56	GAM-FL2-BOYSRR-RSINK	Lead, ppb	1.56	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.



Cincinnati Public Schools - Gamble (James N.) Montessori High School- Lead Testing Results

SAMPLE #	SCHOOL	SAMPLE DATE	SAMPLE TIME	SAMPLE NAME	PARAMETER CODE	LEAD, PPB	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
GAM86	Gamble Montessori High School	10/7/2016	6:54	GAM-FL2-GIRLSRR-LSINK	Lead, ppb	3.39	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM87	Gamble Montessori High School	10/7/2016	6:54	GAM-FL2-GIRLSRR-RSINK	Lead, ppb	4.49	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM88	Gamble Montessori High School	10/7/2016	6:53	GAM-FL2-TEACHERMENSRR-SINK	Lead, ppb	3.47	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
GAM89	Gamble Montessori High School	10/7/2016	6:53	GAM-FL2-TEACHERWOMENSRR-SINK	Lead, ppb	3.04	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
				GAM-BASEMENT-CUSTODIAN-SINK		N/A	Identified during walk through. Not sampled; utility sink.
				GAM-BASEMENT-CUSTODIAN-UTILITIESINK		N/A	Identified during walk through. Not sampled; utility sink.
				GAM-FL1-1122DESK-FRONT-SINK		N/A	Not working.