



May 25, 2018

Cincinnati Public Schools  
Cynthia Eghbalnia  
2651 Burnet Avenue  
Cincinnati, OH 45219

**Parker Woods  
Montessori School**

Dear Cynthia:

Thank you for taking the responsibility seriously to protect the health of the children by voluntarily testing the water in your school for lead!

Attached please find the results of the lead analyses performed for Parker Woods Montessori School by the Greater Cincinnati Water Works (GCWW). The following comments speak to the process, samples analyzed and additional steps needed to help ensure the safety of all the students within the school.

**School Sampling Process and Results**

GCWW and Cincinnati Public Schools (CPS) staff worked together to finalize a sampling plan for the school. The *USEPA 3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance Document (3Ts Guidelines)* is the process and guidelines used for assisting schools with testing for lead.

In January, one hundred, sixty-three (163) samples were collected from drinking fountains, sinks and cooking outlets throughout the school. Multiple sinks within the schools were not initially considered for testing, however, key nearby indicators (coffee makers, drinking cups, plates, utensils, etc.) prompted additional locations to be tested in the schools. Including these sampling locations speaks to the proactive approach CPS continues to have towards understanding the water quality within the schools. Seven additional locations were not sampled. The results show the following:

- 132 samples (80.99%), below the detection level (<1)
- 25 samples (15.34%), between 1ppb and 5ppb
- 4 samples (2.45%), between 5ppb and 10ppb
- 1 sample (0.61%), between 10ppb and 15ppb
- 1 sample (0.61%), greater than 15ppb.

Ninety-nine percent (99.39%) of the results were below the detection level or below the federal action level.

Fifteen parts per billion (ppb) is the federal Lead and Copper Rule action level; desired results are below 15. The federal action level of 15ppb pertains to water utilities and GCWW's review and comments are based on this action level. However, the USEPA 3Ts Guidelines document outlines practices for schools to put in place if samples are greater than 20 ppb.

While we strive to have results less than 15, we recognize that lead is a pervasive environmental contaminant, and no safe blood lead threshold has been identified in children or adults. Therefore, we provide recommendations to further reduce any lead levels discovered in your school.



### Next steps

GCWW has reviewed the results from your samples and provides some next-steps comments.

1. Good news! The majority of the drinking fountains and bottle fillers had no lead detections. Two locations, PWM-FL1-1308-DF-PWM65 and PWM-FL3-3418-DF-PWM143, had lead detections. To lower these levels, flush the line (let the water run) before use. No further action is suggested.
2. One location had a lead detection greater than 15ppb, PWM-FL1-1103-SINK-PWM28. This location is a sink and it is assumed by the name that it is not used as a drinking water or cooking outlet. However, consider an immediate remedy such as taking the sample location out of service until a more defined plan can be created or post a sign limiting the use at this location. Refer to the USEPA 3Ts Guidelines for more information and suggestions on signage. After the location is out of service, work to reduce the lead level by first removing and cleaning the aerator as particles may be trapped on the aerator and contributing to the lead detection. Consider resampling after the cleaning.
3. Seven (7) of the eleven (11) sample locations in the kitchen had lead detections. Most of these locations had low lead levels. Flush the line before use if using these locations for food and drink preparation. No further action is suggested.
4. Other sinks had low lead detections. Based on the names, these are not used for drinking water or cooking purposes.
  - a. Lead is not an issue for body contact such as bathing, showering, and washing hands.
  - a. To lower the lead levels, consider removing and cleaning the aerator. Particles may be trapped on the aerator and contributing to the lead level.
  - b. If the locations with lead detections are not used on a regular basis, then the infrequent use may be contributing to the lead detections.
5. Sinks in the boys and girls locker rooms were not sampled. If these locations are not used regularly, they may yield high lead levels when sampled, given their infrequent use. Consider posting signs (hand washing only, not for drinking purposes, etc.) to limit the purpose of the sinks.
6. Review how water is being used within your facility. Again, if water is not used on a regular basis at some of these locations, again, the infrequent use at the outlet may be contributing to the lead detections. Signage at these locations may be helpful (hand washing only, science class purposes only-no drinking, etc.).
7. If it hasn't occurred already, a robust communications plan is suggested. Communications plan steps are outlined in the 3Ts Guidelines. This plan will inform the school community of the sampling work the school has done to date and the steps the school will take to correct any issues discovered. GCWW employees can assist with this plan and are available to attend any school meetings to help explain our lead program, the sample results and our partnership with your school. Suggestions for language and a letter template can be provided if needed. Sampling results will be posted on the GCWW [lead.mygcww.org](http://lead.mygcww.org) website with other school sampling results.

Greater Cincinnati Water Works takes the presence of lead service lines and the removal of those service lines in our system very seriously. In addition, minimizing the exposure of lead within our preschools, schools, and daycares is one of our highest priorities under our Enhanced Lead Program. Please contact Jim Nelson at 591-6869 if you have any questions.

Thanks again for your partnership with Greater Cincinnati Water Works and your work to further understand the water quality within your building. Your extra steps and care to keep the children in our community safe are appreciated!

Sincerely,

A handwritten signature in black ink that reads "Cathy B. Bailey". The signature is written in a cursive style with a light blue rectangular highlight behind it.

Cathy B. Bailey  
Director/Greater Cincinnati Water Works

Cc: Dr. Marilyn Crumpton, Cincinnati Health Department  
Dr. Camille Jones, Cincinnati Health Department  
Chuck DeJonckheere, Hamilton County Public Health  
Patrick Duhaney, City of Cincinnati  
Verna Arnette, Greater Cincinnati Water Works  
Jeff Swertfeger, Greater Cincinnati Water Works  
Jason DeLaet, Greater Cincinnati Water Works  
James Nelson, Greater Cincinnati Water Works

**Cincinnati Public Schools - Parker Woods Montessori - Lead Testing Results**

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
PWM1	1/12/2018	5:09	PWM-FL1-1201MAILRM-SINK-PWM1	Lead, ppb	<1	Less than detection level
PWM2	1/12/2018	5:09	PWM-FL1-1201MAILRM-DF-PWM2	Lead, ppb	<1	Less than detection level
PWM3	1/12/2018	5:10	PWM-FL1-1201MAILRM-IM-PWM3	Lead, ppb	<1	Less than detection level
PWM4	1/12/2018	5:10	PWM-FL1-HALLNEAR1212LRR-SINK-PWM4	Lead, ppb	<1	Less than detection level
PWM5	1/12/2018	5:10	PWM-FL1-HALLNEAR1212RRR-SINK-PWM5	Lead, ppb	<1	Less than detection level
PWM6	1/12/2018	5:11	PWM-FL1-1204HEALTH-SINK-PWM6	Lead, ppb	<1	Less than detection level
PWM7	1/12/2018	5:11	PWM-FL1-1204HEALTH-DF-PWM7	Lead, ppb	<1	Less than detection level
PWM8	1/12/2018	5:11	PWM-FL1-1204HEALTHRR-SINK-PWM8	Lead, ppb	<1	Less than detection level
PWM9	1/12/2018	5:16	PMW-FL1-1202WKRM-SINK-PWM9	Lead, ppb	4.83	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PWM10	1/12/2018	5:16	PMW-FL1-1202WKRM-DF-PWM10	Lead, ppb	<1	Less than detection level
PWM11	1/12/2018	5:17	PWM-FL1-1102-SINK-PWM11	Lead, ppb	<1	Less than detection level
PWM12	1/12/2018	5:17	PWM-FL1-1102-DF-PWM12	Lead, ppb	<1	Less than detection level
PWM13	1/12/2018	5:17	PWM-FL1-1102RR-SINK-PWM13	Lead, ppb	<1	Less than detection level
PWM14	1/12/2018	5:18	PWM-FL1-1104-SINK-PWM14	Lead, ppb	<1	Less than detection level
PWM15	1/12/2018	5:18	PWM-FL1-1104-DF-PWM15	Lead, ppb	<1	Less than detection level
PWM16	1/12/2018	5:18	PWM-FL1-1104RR-SINK-PWM16	Lead, ppb	<1	Less than detection level
PWM17	1/12/2018	5:21	PWM-FL1-ELA1106-SINK-PWM17	Lead, ppb	<1	Less than detection level
PWM18	1/12/2018	5:21	PWM-FL1-ELA1106-DF-PWM18	Lead, ppb	<1	Less than detection level
PWM19	1/12/2018	5:22	PWM-FL1-1108-SINK-PWM19	Lead, ppb	<1	Less than detection level
PWM20	1/12/2018	5:22	PWM-FL1-1108-DF-PWM20	Lead, ppb	<1	Less than detection level
PWM21	1/12/2018	5:22	PWM-FL1-1108RR-SINK-PWM21	Lead, ppb	<1	Less than detection level
PWM22	1/12/2018	5:24	PWM-FL1-1107-SINK-PWM22	Lead, ppb	<1	Less than detection level
PWM23	1/12/2018	5:24	PWM-FL1-1107-DF-PWM23	Lead, ppb	<1	Less than detection level
PWM24	1/12/2018	5:24	PWM-FL1-1107RR-SINK-PWM24	Lead, ppb	<1	Less than detection level
PWM25	1/12/2018	5:25	PWM-FL1-1105-SINK-PWM25	Lead, ppb	<1	Less than detection level
PWM26	1/12/2018	5:25	PWM-FL1-1105-DF-PWM26	Lead, ppb	<1	Less than detection level
PWM27	1/12/2018	5:25	PWM-FL1-1105RR-SINK-PWM27	Lead, ppb	<1	Less than detection level

**Cincinnati Public Schools - Parker Woods Montessori - Lead Testing Results**

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
PWM28	1/12/2018	5:25	PWM-FL1-1103-SINK-PWM28	Lead, ppb	24.7	Above 15ppb federal action level and the 20ppb trigger level to take action as explained in the USEPA 3Ts Guidelines for schools. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
PWM29	1/12/2018	5:27	PWM-FL1-1103-DF-PWM29	Lead, ppb	<1	Less than detection level
PWM30	1/12/2018	5:27	PWM-FL1-1103RR-SINK-PWM30	Lead, ppb	<1	Less than detection level
PWM31	1/12/2018	5:27	PWM-FL1-1101-SINK-PWM31	Lead, ppb	1.93	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PWM32	1/12/2018	5:28	PWM-FL1-1101-DF-PWM32	Lead, ppb	<1	Less than detection level
PWM33	1/12/2018	5:28	PWM-FL1-1101RR-SINK-PWM33	Lead, ppb	<1	Less than detection level
PWM34	1/12/2018	5:28	PWM-FL1GYM-1226PEOFFRR-SINK-PWM34	Lead, ppb	3.71	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PWM35	1/12/2018	5:38	PWM-KIT-NEARSERVE-HANDSINK-PWM35	Lead, ppb	<1	Less than detection level
PWM36	1/12/2018	5:39	PWM-KIT-2TUB-SINK-PWM36	Lead, ppb	<1	Less than detection level
PWM37	1/12/2018	5:39	PWM-KIT-STOCKPOT-LFILLER-PWM37	Lead, ppb	<1	Less than detection level
PWM38	1/12/2018	5:40	PWM-KIT-STOCKPOT-RFILLER-PWM38	Lead, ppb	1.25	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PWM39	1/12/2018	5:40	PWM-KIT-NEAR1320-HANDSINK-PWM39	Lead, ppb	2.53	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PWM40	1/12/2018	5:40	PWM-KIT-NEARCOOL1TUB-SINK-PWM40	Lead, ppb	<1	Less than detection level
PWM41	1/12/2018	5:43	PWM-KIT-UNDERHOOD1TUB-SINK-PWM41	Lead, ppb	1.5	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

**Cincinnati Public Schools - Parker Woods Montessori - Lead Testing Results**

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
PWM42	1/12/2018	5:43	PWM-KIT-DISHRM-HANDSINK-PWM42	Lead, ppb	1.85	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PWM43	1/12/2018	5:44	PWM-KIT-DISHRM3TUB-LSINK-PWM43	Lead, ppb	<1	Less than detection level
PWM44	1/12/2018	5:44	PWM-KIT-DISHRM3TUB-RSINK-PWM44	Lead, ppb	1.21	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PWM45	1/12/2018	5:45	PWM-KIT-1323STAFFRR-SINK-PWM45	Lead, ppb	1.26	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PWM46	1/12/2018	5:46	PWM-FL1-1311LIBRARY-SINK-PWM46	Lead, ppb	7.39	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PWM47	1/12/2018	5:46	PWM-FL1-1311LIBRARY-DF-PWM47	Lead, ppb	<1	Less than detection level
PWM48	1/12/2018	5:50	PWM-FL1-B&GRRNEARCAFELSTAT-LSINK-PWM48	Lead, ppb	<1	Less than detection level
PWM49	1/12/2018	5:50	PWM-FL1-B&GRRNEARCAFELSTAT-MSINK-PWM49	Lead, ppb	<1	Less than detection level
PWM50	1/12/2018	5:50	PWM-FL1-B&GRRNEARCAFELSTAT-RSINK-PWM50	Lead, ppb	<1	Less than detection level
PWM51	1/12/2018	5:51	PWM-FL1-B&GRRNEARCAFEMSTAT-LSINK-PWM51	Lead, ppb	<1	Less than detection level
PWM52	1/12/2018	5:51	PWM-FL1-B&GRRNEARCAFEMSTAT-MSINK-PWM52	Lead, ppb	<1	Less than detection level
PWM53	1/12/2018	5:51	PWM-FL1-B&GRRNEARCAFEMSTAT-RSINK-PWM53	Lead, ppb	<1	Less than detection level
PWM54	1/12/2018	5:52	PWM-FL1-B&GRRNEARCAFERSTAT-LSINK-PWM54	Lead, ppb	<1	Less than detection level
PWM55	1/12/2018	5:52	PWM-FL1-B&GRRNEARCAFERSTAT-MSINK-PWM55	Lead, ppb	<1	Less than detection level
PWM56	1/12/2018	5:52	PWM-FL1-B&GRRNEARCAFERSTAT-RSINK-PWM56	Lead, ppb	<1	Less than detection level
PWM57	1/12/2018	5:10	PWM-FL1-B&GRRNEARCAFE-LDF-PWM57	Lead, ppb	<1	Less than detection level
PWM58	1/12/2018	5:11	PWM-FL1-B&GRRNEARCAFE-RDF-PWM58	Lead, ppb	<1	Less than detection level
PWM59	1/12/2018	5:12	PWM-FL1-1305MUSIC-SINK-PWM59	Lead, ppb	<1	Less than detection level
PWM60	1/12/2018	5:12	PWM-FL1-1305MUSIC-DF-PWM60	Lead, ppb	<1	Less than detection level
PWM61	1/12/2018	5:13	PWM-FL1-1306ART-LSINK-PWM61	Lead, ppb	<1	Less than detection level
PWM62	1/12/2018	5:14	PWM-FL1-1306ART-LDF-PWM62	Lead, ppb	<1	Less than detection level
PWM63	1/12/2018	5:15	PWM-FL1-1306ART-RSINK-PWM63	Lead, ppb	<1	Less than detection level

### Cincinnati Public Schools - Parker Woods Montessori - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
PWM64	1/12/2018	5:16	PWM-FL1-1308-SINK-PWM64	Lead, ppb	10.6	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PWM65	1/12/2018	5:17	PWM-FL1-1308-DF-PWM65	Lead, ppb	3.63	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PWM66	1/12/2018	5:18	PWM-FL1-1422-SINK-PWM66	Lead, ppb	1.05	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PWM67	1/12/2018	5:19	PWM-FL1-1422-DF-PWM67	Lead, ppb	<1	Less than detection level
PWM68	1/12/2018	5:20	PWM-FL1-1422RR-SINK-PWM68	Lead, ppb	<1	Less than detection level
PWM69	1/12/2018	5:21	PWM-FL1-HALLNEAR1422RR-SINK-PWM69	Lead, ppb	<1	Less than detection level
PWM70	1/12/2018	5:22	PWM-FL1-HALLNEAR1406LRR-SINK-PWM70	Lead, ppb	<1	Less than detection level
PWM71	1/12/2018	5:23	PWM-FL1-HALLNEAR1406MRR-SINK-PWM71	Lead, ppb	<1	Less than detection level
PWM72	1/12/2018	5:24	PWM-FL1-HALLNEAR1406RRR-SINK-PWM72	Lead, ppb	<1	Less than detection level
PWM73	1/12/2018	5:26	PWM-FL1-HALLNEAR1403HANDWASH-LSINK-PWM73	Lead, ppb	<1	Less than detection level
PWM74	1/12/2018	5:27	PWM-FL1-HALLNEAR1403HANDWASH-RSINK-PWM74	Lead, ppb	<1	Less than detection level
PWM75	1/12/2018	5:28	PWM-FL1-1403-SINK-PWM75	Lead, ppb	<1	Less than detection level
PWM76	1/12/2018	5:29	PWM-FL1-1403-DF-PWM76	Lead, ppb	<1	Less than detection level
PWM77	1/12/2018	5:30	PWM-FL1-1401-SINK-PWM77	Lead, ppb	<1	Less than detection level
PWM78	1/12/2018	5:31	PWM-FL1-1401-DF-PWM78	Lead, ppb	<1	Less than detection level
PWM79	1/12/2018	5:32	PWM-FL1-1402-SINK-PWM79	Lead, ppb	1.54	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PWM80	1/12/2018	5:33	PWM-FL1-1402-DF-PWM80	Lead, ppb	<1	Less than detection level
PWM81	1/12/2018	5:35	PWM-FL1-1406-SINK-PWM81	Lead, ppb	2.61	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PWM82	1/12/2018	5:36	PWM-FL1-1406-DF-PWM82	Lead, ppb	<1	Less than detection level
PWM83	1/12/2018	5:37	PWM-FL1-HALLNEAR1410-LDF-PWM83	Lead, ppb	<1	Less than detection level
PWM84	1/12/2018	5:38	PWM-FL1-HALLNEAR1410-RDF-PWM84	Lead, ppb	<1	Less than detection level

### Cincinnati Public Schools - Parker Woods Montessori - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
PWM85	1/12/2018	5:38	PWM-FL1-1410WKRM-SINK-PWM85	Lead, ppb	<1	Less than detection level
PWM86	1/12/2018	5:39	PWM-FL1-1410WKRM-DF-PWM86	Lead, ppb	<1	Less than detection level
PWM87	1/12/2018	5:40	PWM-FL1-1414-SINK-PWM87	Lead, ppb	<1	Less than detection level
PWM88	1/12/2018	5:41	PWM-FL1-1414-DF-PWM88	Lead, ppb	<1	Less than detection level
PWM89	1/12/2018	5:42	PWM-FL1-1418-SINK-PWM89	Lead, ppb	<1	Less than detection level
PWM90	1/12/2018	5:43	PWM-FL1-1418-DF-PWM90	Lead, ppb	<1	Less than detection level
PWM91	1/12/2018	5:44	PWM-FL1-1419-SINK-PWM91	Lead, ppb	<1	Less than detection level
PWM92	1/12/2018	5:45	PWM-FL1-1419-DF-PWM92	Lead, ppb	<1	Less than detection level
PWM93	1/12/2018	5:47	PWM-FL1-1417-SINK-PWM93	Lead, ppb	<1	Less than detection level
PWM94	1/12/2018	5:48	PWM-FL1-1417-DF-PWM94	Lead, ppb	<1	Less than detection level
PWM95	1/12/2018	5:49	PWM-FL1-HALLNEAR1414HANDWASH-LSINK-PWM95	Lead, ppb	<1	Less than detection level
PWM96	1/12/2018	5:50	PWM-FL1-HALLNEAR1414HANDWASH-RSINK-PWM96	Lead, ppb	<1	Less than detection level
PWM97	1/12/2018	5:52	PWM-FL1-HALLNEAR1413LRR-SINK-PWM97	Lead, ppb	<1	Less than detection level
PWM98	1/12/2018	5:51	PWM-FL1-HALLNEAR1413RRR-SINK-PWM98	Lead, ppb	1.02	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PWM99	1/12/2018	5:54	PWM-FL2-2402-SINK-PWM99	Lead, ppb	1.22	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PWM100	1/12/2018	5:55	PWM-FL2-2402-DF-PWM100	Lead, ppb	<1	Less than detection level
PWM101	1/12/2018	5:56	PWM-FL2-2406-SINK-PWM101	Lead, ppb	<1	Less than detection level
PWM102	1/12/2018	5:57	PWM-FL2-2406-DF-PWM102	Lead, ppb	<1	Less than detection level
PWM103	1/12/2018	5:58	PWM-FL2-2410-SINK-PWM103	Lead, ppb	3.22	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PWM104	1/12/2018	5:59	PWM-FL2-2410-DF-PWM104	Lead, ppb	<1	Less than detection level
PWM105	1/12/2018	6:00	PWM-FL2-2414-SINK-PWM105	Lead, ppb	1.14	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PWM106	1/12/2018	6:01	PWM-FL2-2414-DF-PWM106	Lead, ppb	<1	Less than detection level



### Cincinnati Public Schools - Parker Woods Montessori - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
PWM107	1/12/2018	6:02	PWM-FL2-2418-SINK-PWM107	Lead, ppb	4.68	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PWM108	1/12/2018	6:03	PWM-FL2-2418-DF-PWM108	Lead, ppb	<1	Less than detection level
PWM109	1/12/2018	6:04	PWM-FL2-2419-SINK-PWM109	Lead, ppb	<1	Less than detection level
PWM110	1/12/2018	6:05	PWM-FL2-2419-DF-PWM110	Lead, ppb	<1	Less than detection level
PWM111	1/12/2018	6:06	PWM-FL2-HALLNEAR2414HANDWASH-LSINK-PWM111	Lead, ppb	<1	Less than detection level
PWM112	1/12/2018	6:07	PWM-FL2-HALLNEAR2414HANDWASH-RSINK-PWM112	Lead, ppb	<1	Less than detection level
PWM113	1/12/2018	5:53	PWM-FL2-STAFFRRNEAR2414-SINK-PWM113	Lead, ppb	1.29	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PWM114	1/12/2018	5:55	PWM-FL2-2417-SINK-PWM114	Lead, ppb	<1	Less than detection level
PWM115	1/12/2018	5:56	PWM-FL2-2417-DF-PWM115	Lead, ppb	<1	Less than detection level
PWM116	1/12/2018	5:56	PWM-FL2-HALLNEAR2417-LDF-PWM116	Lead, ppb	<1	Less than detection level
PWM117	1/12/2018	5:56	PWM-FL2-HALLNEAR2417-RDF-PWM117	Lead, ppb	<1	Less than detection level
PWM118	1/12/2018	5:58	PWM-FL2-HALLNEAR2410FLRR-SINK-PWM118	Lead, ppb	1.07	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PWM119	1/12/2018	5:59	PWM-FL2-HALLNEAR2410LRR-SINK-PWM119	Lead, ppb	<1	Less than detection level
PWM120	1/12/2018	6:00	PWM-FL2-HALLNEAR2410MRR-SINK-PWM120	Lead, ppb	<1	Less than detection level
PWM121	1/12/2018	6:01	PWM-FL2-HALLNEAR2410RRR-SINK-PWM121	Lead, ppb	<1	Less than detection level
PWM122	1/12/2018	6:02	PWM-FL2-HALLNEAR2410FRRR-SINK-PWM122	Lead, ppb	<1	Less than detection level
PWM123	1/12/2018	6:03	PWM-FL2-HALLNEAR2406HANDWASH-LSINK-PWM123	Lead, ppb	<1	Less than detection level
PWM124	1/12/2018	6:03	PWM-FL2-HALLNEAR2406HANDWASH-RSINK-PWM124	Lead, ppb	<1	Less than detection level
PWM125	1/12/2018	6:04	PWM-FL2-2403-SINK-PWM125	Lead, ppb	<1	Less than detection level
PWM126	1/12/2018	6:04	PWM-FL2-2403-DF-PWM126	Lead, ppb	<1	Less than detection level
PWM127	1/12/2018	6:06	PWM-FL2-2401-SINK-PWM127	Lead, ppb	<1	Less than detection level
PWM128	1/12/2018	6:06	PWM-FL2-2401-DF-PWM128	Lead, ppb	<1	Less than detection level
PWM129	1/12/2018	5:29	PWM-FL3-3402-SINK-PWM129	Lead, ppb	1.25	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PWM130	1/12/2018	5:29	PWM-FL3-3402-DF-PWM130	Lead, ppb	<1	Less than detection level

**Cincinnati Public Schools - Parker Woods Montessori - Lead Testing Results**

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
PWM131	1/12/2018	5:30	PWM-FL3-3406FRONTDESK-SINK-PWM131	Lead, ppb	<1	Less than detection level
PWM132	1/12/2018	5:31	PWM-FL3-3406LWALL-LSINK-PWM132	Lead, ppb	5.4	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PWM133	1/12/2018	5:32	PWM-FL3-3406LWALL-RSINK-PWM133	Lead, ppb	3.38	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PWM134	1/12/2018	5:33	PWM-FL3-3406BWALL-FLSINK-PWM134	Lead, ppb	7.06	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PWM135	1/12/2018	5:34	PWM-FL3-3406BWALL-LSINK-PWM135	Lead, ppb	<1	Less than detection level
PWM136	1/12/2018	5:34	PWM-FL3-3406BWALL-RSINK-PWM136	Lead, ppb	5.37	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PWM137	1/12/2018	5:36	PWM-FL3-3410WKRM-SINK-PWM137	Lead, ppb	<1	Less than detection level
PWM138	1/12/2018	5:36	PWM-FL3-3410WKRM-DF-PWM138	Lead, ppb	<1	Less than detection level
PWM139	1/12/2018	5:36	PWM-FL3-3410WKRM-IM-PWM139	Lead, ppb	<1	Less than detection level
PWM140	1/12/2018	5:39	PWM-FL3-3414-SINK-PWM140	Lead, ppb	<1	Less than detection level
PWM141	1/12/2018	5:39	PWM-FL3-3414-DF-PWM141	Lead, ppb	<1	Less than detection level
PWM142	1/12/2018	5:42	PWM-FL3-3418-SINK-PWM142	Lead, ppb	<1	Less than detection level
PWM143	1/12/2018	5:42	PWM-FL3-3418-DF-PWM143	Lead, ppb	3.33	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PWM144	1/12/2018	5:43	PWM-FL3-3419-SINK-PWM144	Lead, ppb	<1	Less than detection level
PWM145	1/12/2018	5:43	PWM-FL3-3419-DF-PWM145	Lead, ppb	<1	Less than detection level
PWM146	1/12/2018	5:45	PWM-FL3-HALLNEAR3414HANDWASH-LSINK-PWM146	Lead, ppb	<1	Less than detection level
PWM147	1/12/2018	5:45	PWM-FL3-HALLNEAR3414HANDWASH-RSINK-PWM147	Lead, ppb	<1	Less than detection level
PWM148	1/12/2018	5:47	PWM-FL3-STAFFRRNEAR3414-SINK-PWM148	Lead, ppb	<1	Less than detection level
PWM149	1/12/2018	5:48	PWM-FL3-3417-SINK-PWM149	Lead, ppb	4.18	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

### Cincinnati Public Schools - Parker Woods Montessori - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
PWM150	1/12/2018	5:48	PWM-FL3-3417-DF-PWM150	Lead, ppb	<1	Less than detection level
PWM151	1/12/2018	5:50	PWM-FL3-HALLNEAR3417-LDF-PWM151	Lead, ppb	<1	Less than detection level
PWM152	1/12/2018	5:50	PWM-FL3-HALLNEAR3417-RDF-PWM152	Lead, ppb	<1	Less than detection level
PWM153	1/12/2018	5:27	PWM-FL3-HALLNEAR3410FLRR-SINK-PWM153	Lead, ppb	2.12	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PWM154	1/12/2018	5:26	PWM-FL3-HALLNEAR3410LRR-SINK-PWM154	Lead, ppb	<1	Less than detection level
PWM155	1/12/2018	5:25	PWM-FL3-HALLNEAR3410MRR-SINK-PWM155	Lead, ppb	<1	Less than detection level
PWM156	1/12/2018	5:24	PWM-FL3-HALLNEAR3410RRR-SINK-PWM156	Lead, ppb	<1	Less than detection level
PWM157	1/12/2018	5:23	PWM-FL3-HALLNEAR3410FRRR-SINK-PWM157	Lead, ppb	<1	Less than detection level
PWM158	1/12/2018	5:19	PWM-FL3-HALLNEAR3406HANDWASH-LSINK-PWM158	Lead, ppb	<1	Less than detection level
PWM159	1/12/2018	5:19	PWM-FL3-HALLNEAR3406HANDWASH-RSINK-PWM159	Lead, ppb	<1	Less than detection level
PWM160	1/12/2018	5:17	PWM-FL3-3403-SINK-PWM160	Lead, ppb	<1	Less than detection level
PWM161	1/12/2018	5:17	PWM-FL3-3403-DF-PWM161	Lead, ppb	<1	Less than detection level
PWM162	1/12/2018	5:15	PWM-FL3-3401-SINK-PWM162	Lead, ppb	<1	Less than detection level
PWM163	1/12/2018	5:15	PWM-FL3-3401-DF-PWM163	Lead, ppb	<1	Less than detection level
N/A	N/A	N/A	PWM-GYM-BOYSLOCK-LSINK	Lead, ppb	N/A	Not sampled; out of service at the time of walkthrough.
N/A	N/A	N/A	PWM-GYM-BOYSLOCK-MSINK	Lead, ppb	N/A	Not sampled; out of service at the time of walkthrough.
N/A	N/A	N/A	PWM-GYM-BOYSLOCK-RSINK	Lead, ppb	N/A	Not sampled; out of service at the time of walkthrough.
N/A	N/A	N/A	PWM-GYM-GIRLSLOCK-LSINK	Lead, ppb	N/A	Not sampled; out of service at the time of walkthrough.
N/A	N/A	N/A	PWM-GYM-GIRLSLOCK-MSINK	Lead, ppb	N/A	Not sampled; out of service at the time of walkthrough.
N/A	N/A	N/A	PWM-GYM-GIRLSLOCK-RSINK	Lead, ppb	N/A	Not sampled; out of service at the time of walkthrough.
N/A	N/A	N/A	PWM-FL3-3406BWALL-FRSINK	Lead, ppb	N/A	Not sampled; out of service at the time of walkthrough.