



April 17, 2017

Cincinnati Public Schools
Cynthia Eghbalnia
2651 Burnet Avenue
Cincinnati, OH 45219

Academy of World Languages

Dear Cynthia:

Thank you for taking the responsibility seriously to protect the health of the children by voluntarily testing the water in your school for lead!

Attached please find the results of the lead analyses performed for the Academy of World Languages by the Greater Cincinnati Water Works (GCWW). The following comments speak to the process, samples analyzed and additional steps needed to help ensure the safety of all the students within the school.

School Sampling Process and Results

GCWW and Cincinnati Public Schools (CPS) staff worked together to finalize a sampling plan for the school. The *USEPA 3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance Document (3Ts Guidelines)* is the process and guidelines used for assisting schools with testing for lead.

In February, one hundred, fifty-six (156) samples were collected from drinking fountains, sinks and cooking outlets throughout the school. Multiple sinks within the schools were not initially considered for testing, however, key nearby indicators (coffee makers, drinking cups, plates, utensils, etc.) prompted additional locations to be tested in the schools. Including these sampling locations speaks to the proactive approach CPS continues to have towards understanding the water quality within the schools. The results show the following:

- 125 samples (80.13%), below the detection level (<1)
- 25 samples (16.03%), between 1ppb and 5ppb
- 5 samples (3.2%), between 5ppb and 10ppb
- 0 samples (0%) between 10ppb and 15ppb
- 1 samples (.64%) greater than 15ppb.

Ninety-nine percent (99.36%) of the sample results were below the detection level or below the federal action level.

Fifteen parts per billion (ppb) is the federal Lead and Copper Rule action level; desired results are below 15. The federal action level of 15ppb pertains to water utilities and GCWW's review and comments are based on this action level. However, the USEPA 3Ts Guidelines document outlines practices for schools to put in place if samples are greater than 20 ppb.

While we strive to have results less than 15, we recognize that lead is a pervasive environmental contaminant, and no safe blood lead threshold has been identified in children or adults. Therefore, we provide recommendations to further reduce any lead levels discovered in your school.



Next steps

GCWW has reviewed the results from your samples and provides some next-steps comments.

1. Five (5) of the forty-six (46) drinking fountains had lead detections (but below the federal action level). Consider flushing the line (letting the water run) before use.
2. Eight (8) of the twelve (12) sample locations in the kitchen had lead detections, however, all were below the federal action level. Again, consider flushing the line (letting the water run) before use.
3. A sink on the first floor, sample # AWL-FL1-1002RR-SINK-AWL14, had a lead result greater than 15ppb. Assuming by the name that this is not a drinking water or cooking outlet, consider posting a sign above the location limiting the purpose of the sink ('hand washing only', 'work sink only'). Posting a sign will deter students and staff from potentially using the sink to fill a water bottle, etc.
4. Some other sample locations had lead detections, many of them were low results. For these samples with lead detections, as an added precaution, consider posting signs at sink locations indicating 'hand washing only' (or other specific purposes) as these locations should not to be used as drinking water or cooking outlets. Refer to the USEPA 3Ts Guidelines for more information and suggestions on signage.
5. Review how water is being used within your facility. If water is not used on a regular basis at some of these outlets, the infrequent use at the outlet may be contributing to the lead detections. Again, signage at these locations may be helpful (hand washing only, etc.).
6. One sample location, AWL-OUTSIDE-DF, was off for the season and will be tested when in normal use.
7. Consider completing a plumbing profile to review the fixtures in the school as some fixtures may be contributing to the lead detections in samples. If the fixtures are the source of the lead, plan to replace them. The USEPA 3Ts Guidelines outlines a great approach to creating and implementing a remediation plan. A copy of the Guidelines can be found on our website <http://www.cincinnati-oh.gov/water/assets/File/3T%20Guidance%20Manual%20for%20Schools.pdf>.

State funds are available through the new Lead Plumbing Fixture Replacement Assistance Grant Program established to provide reimbursement to eligible schools for the assessment and replacement of certain plumbing fixtures. The Program was established in House Bill 390 to provide \$12,000,000 in funding to eligible schools to reimburse for the sampling and replacement of drinking fountains, water coolers, plumbing fixtures, and limited connected piping. Schools built before 1990 can apply for reimbursement up to \$15,000 for sampling of eligible fixtures and the material costs to replace those fixtures if they are identified as being over the federal action level for lead. The program is open to traditional public schools, community schools, and chartered non-public schools. Program information can be found on the Ohio Facilities Construction Commission (OFCC) Services and Programs website <http://ofcc.ohio.gov/ServicesPrograms/LeadFixtureReplacementGrants.aspx>.

8. A number of the lead detections were low detections. For the sample locations with lead detections, we have known and learned from other schools (that are participating in this program) that cleaning the faucet and aerator may reduce the lead levels. This is due to the cleaning that removes trapped particles on the aerator. Cleaning may help reduce the lead levels further and may prove to be more helpful than a complete plumbing profile. Follow-up sampling at these locations can occur if you choose to clean the faucet and aerator. GCWW can assist with this.

9. If it hasn't occurred already, a robust communications plan is suggested. Communications plan steps are outlined in the 3Ts Guidelines. This plan will inform the school community of the sampling work the school has done to date and the steps the school will take to correct any issues discovered. GCWW employees can assist with this plan and are available to attend any school meetings to help explain our lead program, the sample results and our partnership with your school. Suggestions for language and a letter template can be provided if needed. Sampling results will be posted on the GCWW lead.mycgww.org website with other school sampling results.

Greater Cincinnati Water Works takes the presence of lead service lines and the removal of those service lines in our system very seriously. In addition, minimizing the exposure of lead within our preschools, schools, and daycares is one of our highest priorities under our Enhanced Lead Program. Please contact Jim Nelson at 591-6869 if you have any questions.

Thanks again for your partnership with Greater Cincinnati Water Works and your work to further understand the water quality within your building. Your extra steps and care to keep the children in our community safe are appreciated!

Sincerely,

A handwritten signature in cursive script that reads "Cathy B. Bailey".

Cathy B. Bailey
Director/Greater Cincinnati Water Works

Cc: Dr. Marilyn Crumpton, Cincinnati Health Department
Dr. Camille Jones, Cincinnati Health Department
Chuck DeJonckheere, Hamilton County Public Health
Sheila Hill-Christian, City of Cincinnati
Verna Arnette, Greater Cincinnati Water Works
Jeff Swertfeger, Greater Cincinnati Water Works
Jason DeLaet, Greater Cincinnati Water Works

Cincinnati Public Schools - Academy of World Languages - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	LOCATION	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/ RECOMMENDATIONS REGARDING RESULTS
AWL1	2/16/2017	6:16:00	AWL-FL1-1009FRONTDESK-SINK-AWL1	Lead, ppb	3.1	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
AWL2	2/16/2017	6:17:00	AWL-FL1-1009LWALL-LSINK-AWL2	Lead, ppb	3.3	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
AWL3	2/16/2017	6:18:00	AWL-FL1-1009LWALL-RSINK-AWL3	Lead, ppb	8.69	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
AWL4	2/16/2017	6:19:00	AWL-FL1-1009RWALL-LSINK-AWL4	Lead, ppb	1.47	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
AWL5	2/16/2017	6:20:00	AWL-FL1-1009RWALL-RSINK-AWL5	Lead, ppb	2.3	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
AWL6	2/16/2017	6:21:00	AWL-FL1-1012WORKRM-SINK-AWL6	Lead, ppb	5.55	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
AWL7	2/16/2017	6:22:00	AWL-FL1-1008-SINK-AWL7	Lead, ppb	<1	Less than detection level
AWL8	2/16/2017	6:22:00	AWL-FL1-1008-DF-AWL8	Lead, ppb	<1	Less than detection level
AWL9	2/16/2017	6:24:00	AWL-FL1-1007-SINK-AWL9	Lead, ppb	<1	Less than detection level
AWL10	2/16/2017	6:24:00	AWL-FL1-1007-DF-AWL10	Lead, ppb	<1	Less than detection level
AWL11	2/16/2017	6:34:00	AWL-FL1-1001-SINK-AWL11	Lead, ppb	<1	Less than detection level
AWL12	2/16/2017	6:26:00	AWL-FL1-1006-SINK-AWL12	Lead, ppb	<1	Less than detection level
AWL13	2/16/2017	6:26:00	AWL-FL1-1006-DF-AWL13	Lead, ppb	<1	Less than detection level

Cincinnati Public Schools - Academy of World Languages - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	LOCATION	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
AWL14	2/16/2017	6:32:00	AWL-FL1-1002RR-SINK-AWL14	Lead, ppb	22.2	Above 15ppb federal action level and the 20ppb trigger level to take action as explained in the USEPA 3Ts Guidelines for schools. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
AWL15	2/16/2017	6:31:00	AWL-FL1-1003RR-SINK-AWL15	Lead, ppb	<1	Less than detection level
AWL16	2/16/2017	6:30:00	AWL-FL1-1004RR-SINK-AWL16	Lead, ppb	<1	Less than detection level
AWL17	2/16/2017	6:29:00	AWL-FL1-1005-SINK-AWL17	Lead, ppb	<1	Less than detection level
AWL18	2/16/2017	6:29:00	AWL-FL1-1005-DF-AWL18	Lead, ppb	<1	Less than detection level
AWL19	2/16/2017	6:26:00	AWL-FL2-2027PEOFFRR-SINK-AWL19	Lead, ppb	<1	Less than detection level
AWL20	2/16/2017	6:27:00	AWL-FL2-2026GIRLSLOCK-LDF-AWL20	Lead, ppb	<1	Less than detection level
AWL21	2/16/2017	6:27:00	AWL-FL2-2026GIRLSLOCK-RDF-AWL21	Lead, ppb	<1	Less than detection level
AWL22	2/16/2017	6:28:00	AWL-FL2-2026GIRLSLOCK-LSINK-AWL22	Lead, ppb	1.71	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
AWL23	2/16/2017	6:28:00	AWL-FL2-2026GIRLSLOCK-MSINK-AWL23	Lead, ppb	<1	Less than detection level
AWL24	2/16/2017	6:28:00	AWL-FL2-2026GIRLSLOCK-RSINK-AWL24	Lead, ppb	<1	Less than detection level
AWL25	2/16/2017	6:30:00	AWL-FL2-2025BOYSLOCK-LDF-AWL25	Lead, ppb	<1	Less than detection level
AWL26	2/16/2017	6:30:00	AWL-FL2-2025BOYSLOCK-RDF-AWL26	Lead, ppb	<1	Less than detection level
AWL27	2/16/2017	6:31:00	AWL-FL2-2025BOYSLOCK-LSINK-AWL27	Lead, ppb	<1	Less than detection level
AWL28	2/16/2017	6:31:00	AWL-FL2-2025BOYSLOCK-RSINK-AWL28	Lead, ppb	<1	Less than detection level
AWL29	2/16/2017	5:10:00	AWL-KIT-2019STAFFRR-SINK-AWL29	Lead, ppb	<1	Less than detection level
AWL30	2/22/2017	6:28:00	AWL-KIT-STOCKPOT-LFILLER-AWL30	Lead, ppb	6.75	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
AWL31	2/22/2017	6:28:00	AWL-KIT-STOCKPOT-MFILLER-AWL31	Lead, ppb	2.67	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

Cincinnati Public Schools - Academy of World Languages - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	LOCATION	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
AWL32	2/22/2017	6:30:00	AWL-KIT-STOCKPOT-RFILLER-AWL32	Lead, ppb	5.34	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
AWL33	2/22/2017	6:30:00	AWL-KIT-ISLANDTABLE-SINK-AWL33	Lead, ppb	2.58	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
AWL34	2/22/2017	6:30:00	AWL-KIT-NEAROFF-HANDSINK-AWL34	Lead, ppb	<1	Less than detection level
AWL35	2/22/2017	6:32:00	AWL-KIT-NEARSERVLIN-HANDSINK-AWL35	Lead, ppb	<1	Less than detection level
AWL36	2/22/2017	6:32:00	AWL-KIT-2TUB-SINK-AWL36	Lead, ppb	2.45	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
AWL37	2/22/2017	6:34:00	AWL-KIT-NEAR2TUB-HANDSINK-AWL37	Lead, ppb	3.77	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
AWL38	2/22/2017	6:32:00	AWL-KIT-DISHRM-HANDSINK-AWL38	Lead, ppb	1.75	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
AWL39	2/22/2017	6:34:00	AWL-KIT-DISHRM3TUB-LSINK-AWL39	Lead, ppb	2.93	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
AWL40	2/22/2017	6:34:00	AWL-KIT-DISHRM3TUB-RSINK-AWL40	Lead, ppb	<1	Less than detection level
AWL41	2/16/2017	5:21:00	AWL-FL2-CAFE-LCOMBODF-AWL41	Lead, ppb	3.7	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
AWL42	2/16/2017	5:21:00	AWL-FL2-CAFE-LCOMBOBF-AWL42	Lead, ppb	2.84	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
AWL43	2/16/2017	5:21:00	AWL-FL2-CAFE-RDF-AWL43	Lead, ppb	<1	Less than detection level
AWL44	2/16/2017	5:22:00	AWL-FL2-2008COMMUNITYRM-SINK-AWL44	Lead, ppb	<1	Less than detection level
AWL45	2/16/2017	5:25:00	AWL-FL2-2031-SINK-AWL45	Lead, ppb	<1	Less than detection level

Cincinnati Public Schools - Academy of World Languages - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	LOCATION	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/ RECOMMENDATIONS REGARDING RESULTS
AWL46	2/16/2017	5:25:00	AWL-FL2-2031-DF-AWL46	Lead, ppb	<1	Less than detection level
AWL47	2/16/2017	5:27:00	AWL-FL2-2010GIRLSRR-LSINK-AWL47	Lead, ppb	<1	Less than detection level
AWL48	2/16/2017	5:27:00	AWL-FL2-2010GIRLSRR-MSINK-AWL48	Lead, ppb	<1	Less than detection level
AWL49	2/16/2017	5:27:00	AWL-FL2-2010GIRLSRR-RSINK-AWL49	Lead, ppb	<1	Less than detection level
AWL50	2/16/2017	5:28:00	AWL-FL2-HALLWAYNEAR2010-LDF-AWL50	Lead, ppb	<1	Less than detection level
AWL51	2/16/2017	5:28:00	AWL-FL2-HALLWAYNEAR2010-RDF-AWL51	Lead, ppb	<1	Less than detection level
AWL52	2/16/2017	5:31:00	AWL-FL2-2009BOYSRR-LSINK-AWL52	Lead, ppb	<1	Less than detection level
AWL53	2/16/2017	5:31:00	AWL-FL2-2009BOYSRR-MSINK-AWL53	Lead, ppb	<1	Less than detection level
AWL54	2/16/2017	5:31:00	AWL-FL2-2009BOYSRR-RSINK-AWL54	Lead, ppb	<1	Less than detection level
AWL55	2/16/2017	5:34:00	AWL-FL2-2033ART-LSINK-AWL55	Lead, ppb	<1	Less than detection level
AWL56	2/16/2017	5:34:00	AWL-FL2-2033ART-MSINK-AWL56	Lead, ppb	<1	Less than detection level
AWL57	2/16/2017	5:34:00	AWL-FL2-2033ART-RSINK-AWL57	Lead, ppb	<1	Less than detection level
AWL58	2/16/2017	5:37:00	AWL-FL2-2006RR-SINK-AWL58	Lead, ppb	<1	Less than detection level
AWL59	2/16/2017	5:37:00	AWL-FL2-2005-SINK-AWL59	Lead, ppb	<1	Less than detection level
AWL60	2/16/2017	5:41:00	AWL-FL2-2050WORKRM-SINK-AWL60	Lead, ppb	<1	Less than detection level
AWL61	2/16/2017	5:41:00	AWL-FL2-2055UNIRR-SINK-AWL61	Lead, ppb	1.03	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
AWL62	2/16/2017	5:42:00	AWL-FL2-2053HEALTH-SINK-AWL62	Lead, ppb	<1	Less than detection level
AWL63	2/16/2017	5:46:00	AWL-FL2-2039STAFFRR-SINK-AWL63	Lead, ppb	<1	Less than detection level
AWL64	2/16/2017	5:46:00	AWL-FL2-2038STAFFRR-SINK-AWL64	Lead, ppb	<1	Less than detection level
AWL65	2/16/2017	5:48:00	AWL-FL2-2057-SINK-AWL65	Lead, ppb	<1	Less than detection level
AWL66	2/16/2017	5:48:00	AWL-FL2-2057-DF-AWL66	Lead, ppb	<1	Less than detection level
AWL67	2/16/2017	5:48:00	AWL-FL2-2057RR-SINK-AWL67	Lead, ppb	<1	Less than detection level
AWL68	2/16/2017	5:50:00	AWL-FL2-2102-SINK-AWL68	Lead, ppb	<1	Less than detection level
AWL69	2/16/2017	5:50:00	AWL-FL2-2102-DF-AWL69	Lead, ppb	<1	Less than detection level
AWL70	2/16/2017	5:50:00	AWL-FL2-2102RR-SINK-AWL70	Lead, ppb	<1	Less than detection level
AWL71	2/16/2017	5:55:00	AWL-FL2-2100-SINK-AWL71	Lead, ppb	<1	Less than detection level
AWL72	2/16/2017	5:55:00	AWL-FL2-2100-DF-AWL72	Lead, ppb	<1	Less than detection level
AWL73	2/16/2017	5:56:00	AWL-FL2-HALLWAYNEAR2094-SINK-AWL73	Lead, ppb	<1	Less than detection level
AWL74	2/16/2017	5:56:00	AWL-FL2-HALLWAYNEAR2094-DF-AWL74	Lead, ppb	<1	Less than detection level

Cincinnati Public Schools - Academy of World Languages - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	LOCATION	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
AWL75	2/16/2017	5:58:00	AWL-FL2-2059-SINK-AWL75	Lead, ppb	1.07	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
AWL76	2/16/2017	5:58:00	AWL-FL2-2059-DF-AWL76	Lead, ppb	<1	Less than detection level
AWL77	2/16/2017	5:58:00	AWL-FL2-2059RR-SINK-AWL77	Lead, ppb	<1	Less than detection level
AWL78	2/16/2017	6:00:00	AWL-FL2-2094RR-SINK-AWL78	Lead, ppb	<1	Less than detection level
AWL79	2/16/2017	6:00:00	AWL-FL2-2093RR-SINK-AWL79	Lead, ppb	<1	Less than detection level
AWL80	2/16/2017	6:00:00	AWL-FL2-2092RR-SINK-AWL80	Lead, ppb	<1	Less than detection level
AWL81	2/16/2017	6:04:00	AWL-FL2-2098-SINK-AWL81	Lead, ppb	<1	Less than detection level
AWL82	2/16/2017	6:04:00	AWL-FL2-2098-DF-AWL82	Lead, ppb	<1	Less than detection level
AWL83	2/16/2017	6:05:00	AWL-FL2-2097-SINK-AWL83	Lead, ppb	<1	Less than detection level
AWL84	2/16/2017	6:05:00	AWL-FL2-2097-DF-AWL84	Lead, ppb	<1	Less than detection level
AWL85	2/16/2017	6:06:00	AWL-FL2-2091RR-SINK-AWL85	Lead, ppb	<1	Less than detection level
AWL86	2/16/2017	6:07:00	AWL-FL2-2087-SINK-AWL86	Lead, ppb	<1	Less than detection level
AWL87	2/16/2017	6:07:00	AWL-FL2-2087-DF-AWL87	Lead, ppb	<1	Less than detection level
AWL88	2/16/2017	6:09:00	AWL-FL2-2089RR-SINK-AWL88	Lead, ppb	<1	Less than detection level
AWL89	2/16/2017	6:09:00	AWL-FL2-2088RR-SINK-AWL89	Lead, ppb	<1	Less than detection level
AWL90	2/16/2017	6:10:00	AWL-FL2-2061-SINK-AWL90	Lead, ppb	<1	Less than detection level
AWL91	2/16/2017	6:10:00	AWL-FL2-2061-DF-AWL91	Lead, ppb	<1	Less than detection level
AWL92	2/16/2017	6:10:00	AWL-FL2-2061RR-SINK-AWL92	Lead, ppb	<1	Less than detection level
AWL93	2/16/2017	6:14:00	AWL-FL2-2084-SINK-AWL93	Lead, ppb	<1	Less than detection level
AWL94	2/16/2017	6:15:00	AWL-FL2-2086-SINK-AWL94	Lead, ppb	<1	Less than detection level
AWL95	2/16/2017	6:15:00	AWL-FL2-2086-DF-AWL95	Lead, ppb	<1	Less than detection level
AWL96	2/16/2017	6:16:00	AWL-FL2-2085-SINK-AWL96	Lead, ppb	1.93	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
AWL97	2/16/2017	6:16:00	AWL-FL2-2085-DF-AWL97	Lead, ppb	<1	Less than detection level
AWL98	2/16/2017	6:17:00	AWL-FL2-2063-SINK-AWL98	Lead, ppb	<1	Less than detection level
AWL99	2/16/2017	6:17:00	AWL-FL2-2063-DF-AWL99	Lead, ppb	<1	Less than detection level
AWL100	2/16/2017	6:17:00	AWL-FL2-2063RR-SINK-AWL100	Lead, ppb	<1	Less than detection level

Cincinnati Public Schools - Academy of World Languages - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	LOCATION	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/ RECOMMENDATIONS REGARDING RESULTS
AWL101	2/16/2017	6:19:00	AWL-FL2-2081-SINK-AWL101	Lead, ppb	5.79	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
AWL102	2/16/2017	6:19:00	AWL-FL2-2081-DF-AWL102	Lead, ppb	2.05	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
AWL103	2/16/2017	6:21:00	AWL-FL2-2080-SINK-AWL103	Lead, ppb	1.07	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
AWL104	2/16/2017	6:21:00	AWL-FL2-2080-DF-AWL104	Lead, ppb	<1	Less than detection level
AWL105	2/16/2017	6:22:00	AWL-FL2-2079-SINK-AWL105	Lead, ppb	<1	Less than detection level
AWL106	2/16/2017	6:22:00	AWL-FL2-2079-DF-AWL106	Lead, ppb	<1	Less than detection level
AWL107	2/16/2017	6:23:00	AWL-FL2-2078-SINK-AWL107	Lead, ppb	<1	Less than detection level
AWL108	2/16/2017	6:23:00	AWL-FL2-2078-DF-AWL108	Lead, ppb	<1	Less than detection level
AWL109	2/16/2017	5:11:00	AWL-FL2-2077RR-SINK-AWL109	Lead, ppb	<1	Less than detection level
AWL110	2/16/2017	5:12:00	AWL-FL2-2076RR-SINK-AWL110	Lead, ppb	<1	Less than detection level
AWL111	2/16/2017	5:13:00	AWL-FL2-2075RR-SINK-AWL111	Lead, ppb	<1	Less than detection level
AWL112	2/16/2017	5:17:00	AWL-FL2-2074RR-SINK-AWL112	Lead, ppb	<1	Less than detection level
AWL113	2/16/2017	5:16:00	AWL-FL2-2073RR-SINK-AWL113	Lead, ppb	<1	Less than detection level
AWL114	2/16/2017	5:15:00	AWL-FL2-2072RR-SINK-AWL114	Lead, ppb	<1	Less than detection level
AWL115	2/16/2017	5:19:00	AWL-FL2-2071-SINK-AWL115	Lead, ppb	<1	Less than detection level
AWL116	2/16/2017	5:19:00	AWL-FL2-2071-DF-AWL116	Lead, ppb	<1	Less than detection level
AWL117	2/16/2017	5:21:00	AWL-FL2-2070-SINK-AWL117	Lead, ppb	1.4	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
AWL118	2/16/2017	5:21:00	AWL-FL2-2070-DF-AWL118	Lead, ppb	<1	Less than detection level
AWL119	2/16/2017	5:23:00	AWL-FL2-2069WORKRM-SINK-AWL119	Lead, ppb	<1	Less than detection level
AWL120	2/16/2017	5:25:00	AWL-FL2-2068-SINK-AWL120	Lead, ppb	<1	Less than detection level
AWL121	2/16/2017	5:25:00	AWL-FL2-2068-DF-AWL121	Lead, ppb	<1	Less than detection level
AWL122	2/16/2017	5:31:00	AWL-FL2-2067-SINK-AWL122	Lead, ppb	<1	Less than detection level
AWL123	2/16/2017	5:31:00	AWL-FL2-2067-DF-AWL123	Lead, ppb	<1	Less than detection level

Cincinnati Public Schools - Academy of World Languages - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	LOCATION	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/ RECOMMENDATIONS REGARDING RESULTS
AWL124	2/16/2017	5:28:00	AWL-FL2-2065-SINK-AWL124	Lead, ppb	<1	Less than detection level
AWL125	2/16/2017	5:28:00	AWL-FL2-2065-DF-AWL125	Lead, ppb	<1	Less than detection level
AWL126	2/16/2017	5:28:00	AWL-FL2-2065RR-SINK-AWL126	Lead, ppb	<1	Less than detection level
AWL127	2/16/2017	5:36:00	AWL-FL3-3004-SINK-AWL127	Lead, ppb	<1	Less than detection level
AWL128	2/16/2017	5:36:00	AWL-FL3-3004-DF-AWL128	Lead, ppb	<1	Less than detection level
AWL129	2/16/2017	5:38:00	AWL-FL3-3006-SINK-AWL129	Lead, ppb	1.87	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
AWL130	2/16/2017	5:38:00	AWL-FL3-3006-DF-AWL130	Lead, ppb	<1	Less than detection level
AWL131	2/16/2017	5:40:00	AWL-FL3-3008-SINK-AWL131	Lead, ppb	<1	Less than detection level
AWL132	2/16/2017	5:40:00	AWL-FL3-3008-DF-AWL132	Lead, ppb	<1	Less than detection level
AWL133	2/16/2017	5:42:00	AWL-FL3-3007-SINK-AWL133	Lead, ppb	<1	Less than detection level
AWL134	2/16/2017	5:44:00	AWL-FL3-3010-SINK-AWL134	Lead, ppb	<1	Less than detection level
AWL135	2/16/2017	5:44:00	AWL-FL3-3010-DF-AWL135	Lead, ppb	<1	Less than detection level
AWL136	2/16/2017	5:46:00	AWL-FL3-3011-SINK-AWL136	Lead, ppb	<1	Less than detection level
AWL137	2/16/2017	5:46:00	AWL-FL3-3011-DF-AWL137	Lead, ppb	<1	Less than detection level
AWL138	2/16/2017	5:48:00	AWL-FL3-3012-SINK-AWL138	Lead, ppb	<1	Less than detection level
AWL139	2/16/2017	5:48:00	AWL-FL3-3012-DF-AWL139	Lead, ppb	2.54	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
AWL140	2/16/2017	5:50:00	AWL-FL3-3013RR-SINK-AWL140	Lead, ppb	<1	Less than detection level
AWL141	2/16/2017	5:53:00	AWL-FL3-3014RR-SINK-AWL141	Lead, ppb	<1	Less than detection level
AWL142	2/16/2017	5:54:00	AWL-FL3-3016RR-SINK-AWL142	Lead, ppb	<1	Less than detection level
AWL143	2/16/2017	5:56:00	AWL-FL3-3017RR-SINK-AWL143	Lead, ppb	<1	Less than detection level
AWL144	2/16/2017	5:57:00	AWL-FL3-3018RR-SINK-AWL144	Lead, ppb	<1	Less than detection level
AWL145	2/16/2017	5:59:00	AWL-FL3-3019RR-SINK-AWL145	Lead, ppb	<1	Less than detection level
AWL146	2/16/2017	5:59:00	AWL-FL3-3022-SINK-AWL146	Lead, ppb	<1	Less than detection level
AWL147	2/16/2017	6:01:00	AWL-FL3-3022-DF-AWL147	Lead, ppb	<1	Less than detection level
AWL148	2/16/2017	6:01:00	AWL-FL3-3023-SINK-AWL148	Lead, ppb	<1	Less than detection level
AWL149	2/16/2017	6:04:00	AWL-FL3-3023-DF-AWL149	Lead, ppb	<1	Less than detection level

Cincinnati Public Schools - Academy of World Languages - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	LOCATION	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
AWL150	2/16/2017	6:04:00	AWL-FL3-3025-SINK-AWL150	Lead, ppb	1.84	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
AWL151	2/16/2017	6:05:00	AWL-FL3-3025-DF-AWL151	Lead, ppb	<1	Less than detection level
AWL152	2/16/2017	9:52:00	AWL-FL3-3027-SINK-AWL152	Lead, ppb	1.45	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
AWL153	2/16/2017	6:05:00	AWL-FL3-3027-DF-AWL153	Lead, ppb	<1	Less than detection level
AWL154	2/16/2017	6:07:00	AWL-FL3-3028-SINK-AWL154	Lead, ppb	1.98	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
AWL155	2/16/2017	6:07:00	AWL-FL3-3028-DF-AWL155	Lead, ppb	2.73	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
AWL156	2/16/2017	6:09:00	AWL-FL3-3024-SINK-AWL156	Lead, ppb	<1	Less than detection level
N/A	N/A	N/A	AWL-OUTSIDE-DF	N/A	N/A	Off for the season, will test when on and in normal use.