



April 13, 2018

Cincinnati Public Schools
Cynthia Eghbalnia
2651 Burnet Avenue
Cincinnati, OH 45219

**Academy of World
Languages Resample**

Dear Cynthia:

A sample from one location was collected in a resample round of lead analyses for Academy of World Languages School. Greater Cincinnati Water works (GCWW) analyzed the samples and compared the results.

School Sampling Results

The USEPA 3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance Document (3Ts Guidelines) is the process and guidelines used for assisting schools with testing for lead. Sample results are below.

Cincinnati Public Schools - Academy of World Languages					
Lead Testing Results-Resamples					
SAMPLE	Initial 1st Draw sample Date 2/16/17 Lead, ppb	Changes made after first round of sampling	1st Draw sample Date 10/11/17 Lead, ppb	30 second flush sample Date 10/11/17 Lead, ppb	60 second flush sample Date 10/11/17 Lead, ppb
AWL-FL1-1002RR-SINK-AWL14	22.2	Cleaned aerator; flushed the lines	<1	<1	<1

Changes made and Next Steps


For the location in the resample round, the aerator was cleaned and the line was flushed. This greatly reduced the lead levels at this location; no further action is suggested.

Your work and changes in the school continue to improve the water quality for the students and staff. Your decisions and actions throughout this process speak to your care and commitment to ensure students and staff remain safe and healthy

Thanks again for your partnership with Greater Cincinnati Water Works and your work to further understand the water quality within your building. Your extra steps and care to keep the children in our community safe are appreciated!



Sincerely,

A handwritten signature in black ink that reads "Cathy B. Bailey". The signature is written in a cursive style with a light grey rectangular background behind it.

Cathy B. Bailey
Director/Greater Cincinnati Water Works

Cc: Dr. Marilyn Crumpton, Cincinnati Health Department
Dr. Camille Jones, Cincinnati Health Department
Chuck DeJonckheere, Hamilton County Public Health
Patrick Duhaney, City of Cincinnati
Verna Arnette, Greater Cincinnati Water Works
Jeff Swertfeger, Greater Cincinnati Water Works
Jason DeLaet, Greater Cincinnati Water Works