



April 18, 2017

Cincinnati Public Schools  
Cynthia Eghbalnia  
2651 Burnet Avenue  
Cincinnati, OH 45219

## Bond Hill Academy

Dear Cynthia:

Thank you for taking the responsibility seriously to protect the health of the children by voluntarily testing the water in your school for lead!

Attached please find the results of the lead analyses performed for Bond Hill Academy by the Greater Cincinnati Water Works (GCWW). The following comments speak to the process, samples analyzed and additional steps needed to help ensure the safety of all the students within the school.

### **School Sampling Process and Results**

GCWW and Cincinnati Public Schools (CPS) staff worked together to finalize a sampling plan for the school. The *USEPA 3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance Document (3Ts Guidelines)* is the process and guidelines used for assisting schools with testing for lead.

In March, one hundred, seventeen (117) samples were collected from drinking fountains, sinks and cooking outlets throughout the school. Multiple sinks within the schools were not initially considered for testing, however, key nearby indicators (coffee makers, drinking cups, plates, utensils, etc.) prompted additional locations to be tested in the schools. Including these sampling locations speaks to the proactive approach CPS continues to have towards understanding the water quality within the schools. One sample location was out of service during the sampling process. The results show the following:

- 86 samples (73.5%), below the detection level (<1)
- 31 samples (26.5%), between 1ppb and 5ppb
- 0 samples (0%), between 5ppb and 10ppb
- 0 samples (0%) between 10ppb and 15ppb
- 0 samples (0%) greater than 15ppb.

One hundred percent (100%) of the sample results were below the detection level or below the federal action level.

Fifteen parts per billion (ppb) is the federal Lead and Copper Rule action level; desired results are below 15. The federal action level of 15ppb pertains to water utilities and GCWW's review and comments are based on this action level. However, the USEPA 3Ts Guidelines document outlines practices for schools to put in place if samples are greater than 20 ppb.

While we strive to have results less than 15, we recognize that lead is a pervasive environmental contaminant, and no safe blood lead threshold has been identified in children or adults. Therefore, we provide recommendations to further reduce any lead levels discovered in your school.



## Next steps

Great news! All samples were either below the detection level or below the federal action level of 15ppb and below the 20ppb trigger level outlined in the 3Ts Guidelines for schools to take action to reduce lead. Although below these levels, there were some low lead detections. The following comments speak to how you can lower the lead levels and reduce the risk of lead in your school.

1. Three (3) of the drinking fountains had low lead detections. Consider flushing the line (letting the water run) before use.
2. Five (5) of nine (9) sample locations in the kitchen had low lead detections. Consider flushing the line (letting the water run) before use.
3. Some of the sinks had low lead detections. It is assumed by the name that these are not drinking water or cooking outlets. Consider posting a sign above the location limiting the purpose of the sink ('hand washing only', 'work sink only'). Posting a sign will deter students and staff from potentially using the sink to fill a water bottle, etc.
4. Consider completing a plumbing profile to review the fixtures in the school as some fixtures may be contributing to the lead detections in samples. If the fixtures are the source of the lead, plan to replace them. The USEPA 3Ts Guidelines outlines a great approach to creating and implementing a remediation plan. A copy of the Guidelines can be found on our website <http://www.cincinnati-oh.gov/water/assets/File/3T%20Guidance%20Manual%20for%20Schools.pdf>.

State funds are available through the new Lead Plumbing Fixture Replacement Assistance Grant Program established to provide reimbursement to eligible schools for the assessment and replacement of certain plumbing fixtures. The Program was established in House Bill 390 to provide \$12,000,000 in funding to eligible schools to reimburse for the sampling and replacement of drinking fountains, water coolers, plumbing fixtures, and limited connected piping. Schools built before 1990 can apply for reimbursement up to \$15,000 for sampling of eligible fixtures and the material costs to replace those fixtures if they are identified as being over the federal action level for lead. The program is open to traditional public schools, community schools, and chartered non-public schools. Program information can be found on the Ohio Facilities Construction Commission (OFCC) Services and Programs website <http://ofcc.ohio.gov/ServicesPrograms/LeadFixtureReplacementGrants.aspx>.

5. A number of the lead detections were low detections. For the sample locations with lead detections, we have known and learned from other schools (that are participating in this program) that cleaning the faucet and aerator may reduce the lead levels. This is due to the cleaning that removes trapped particles on the aerator. Cleaning may help reduce the lead levels further and may prove to be more helpful than a complete plumbing profile. Follow-up sampling at these locations can occur if you choose to clean the faucet and aerator. GCWW can assist with this.
6. If it hasn't occurred already, a robust communications plan is suggested. Communications plan steps are outlined in the 3Ts Guidelines. This plan will inform the school community of the sampling work the school has done to date and the steps the school will take to correct any issues discovered. GCWW employees can assist with this plan and are available to attend any school meetings to help explain our lead program, the sample results and our partnership with your school. Suggestions for language and a letter template can be provided if needed. Sampling results will be posted on the GCWW [lead.mygcww.org](http://lead.mygcww.org) website with other school sampling results.

Greater Cincinnati Water Works takes the presence of lead service lines and the removal of those service lines in our system very seriously. In addition, minimizing the exposure of lead within our preschools, schools, and daycares is one of our highest priorities under our Enhanced Lead Program. Please contact Jim Nelson at 591-6869 if you have any questions.

Thanks again for your partnership with Greater Cincinnati Water Works and your work to further understand the water quality within your building. Your extra steps and care to keep the children in our community safe are appreciated!

Sincerely,

A handwritten signature in black ink that reads "Cathy B. Bailey". The signature is written in a cursive style with a large initial 'C' and a long, sweeping underline.

Cathy B. Bailey  
Director/Greater Cincinnati Water Works

Cc: Dr. Marilyn Crumpton, Cincinnati Health Department  
Dr. Camille Jones, Cincinnati Health Department  
Chuck DeJonckheere, Hamilton County Public Health  
Sheila Hill-Christian, City of Cincinnati  
Verna Arnette, Greater Cincinnati Water Works  
Jeff Swertfeger, Greater Cincinnati Water Works  
Jason DeLaet, Greater Cincinnati Water Works

### Cincinnati Public Schools - Bond Hill Academy - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
BOND1	3/3/2017	7:03:00	BOND-FL1-0109HEALTH-SINK-BOND1	Lead, ppb	<1	Less than detection level
BOND2	3/3/2017	7:03:00	BOND-FL1-0109HEALTH-DF-BOND2	Lead, ppb	<1	Less than detection level
BOND3	3/3/2017	7:03:00	BOND-FL1-0109HEALTHRR-SINK-BOND3	Lead, ppb	<1	Less than detection level
BOND4	3/3/2017	7:02:00	BOND-FL1-0106STAFFRM-SINK-BOND4	Lead, ppb	<1	Less than detection level
BOND5	3/3/2017	7:02:00	BOND-FL1-0106STAFFRM-DF-BOND5	Lead, ppb	<1	Less than detection level
BOND6	3/3/2017	7:02:00	BOND-FL1-0106STAFFRMRR-SINK-BOND6	Lead, ppb	<1	Less than detection level
BOND7	3/3/2017	7:01:00	BOND-FL1-0111STAFFRM-SINK-BOND7	Lead, ppb	<1	Less than detection level
BOND8	3/3/2017	7:01:00	BOND-FL1-0111STAFFRM-DF-BOND8	Lead, ppb	<1	Less than detection level
BOND9	3/3/2017	6:57:00	BOND-FL1-1210-SINK-BOND9	Lead, ppb	<1	Less than detection level
BOND10	3/3/2017	6:57:00	BOND-FL1-1210-DF-BOND10	Lead, ppb	<1	Less than detection level
BOND11	3/3/2017	6:57:00	BOND-FL1-1200-SINK-BOND11	Lead, ppb	<1	Less than detection level
BOND12	3/3/2017	6:56:00	BOND-FL1-1253BOYSRR-SINK-BOND12	Lead, ppb	<1	Less than detection level
BOND13	3/3/2017	6:56:00	BOND-FL1-1252GIRLSRR-SINK-BOND13	Lead, ppb	<1	Less than detection level
BOND14	3/3/2017	6:56:00	BOND-FL1-1251HANDYRR-SINK-BOND14	Lead, ppb	<1	Less than detection level
BOND15	3/3/2017	6:56:00	BOND-FL1-1240-SINK-BOND15	Lead, ppb	1.41	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
BOND16	3/3/2017	6:56:00	BOND-FL1-1240-DF-BOND16	Lead, ppb	<1	Less than detection level
BOND17	3/3/2017	6:55:00	BOND-FL1-1230-SINK-BOND17	Lead, ppb	1.08	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
BOND18	3/3/2017	6:55:00	BOND-FL1-1230-DF-BOND18	Lead, ppb	<1	Less than detection level

### Cincinnati Public Schools - Bond Hill Academy - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
BOND19	3/3/2017	6:54:00	BOND-FL1-1220-SINK-BOND19	Lead, ppb	3.02	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
BOND20	3/3/2017	6:54:00	BOND-FL1-1220-DF-BOND20	Lead, ppb	<1	Less than detection level
BOND21	3/3/2017	6:53:00	BOND-FL1-1120-SINK-BOND21	Lead, ppb	3.39	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
BOND22	3/3/2017	6:53:00	BOND-FL1-1120-DF-BOND22	Lead, ppb	<1	Less than detection level
BOND23	3/3/2017	6:52:00	BOND-FL1-1130-SINK-BOND23	Lead, ppb	1.52	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
BOND24	3/3/2017	6:52:00	BOND-FL1-1130-DF-BOND24	Lead, ppb	<1	Less than detection level
BOND25	3/3/2017	6:51:00	BOND-FL1-1100-SINK-BOND25	Lead, ppb	<1	Less than detection level
BOND26	3/3/2017	6:51:00	BOND-FL1-1140-SINK-BOND26	Lead, ppb	<1	Less than detection level
BOND27	3/3/2017	6:51:00	BOND-FL1-1140-DF-BOND27	Lead, ppb	<1	Less than detection level
BOND28	3/3/2017	6:46:00	BOND-FL1-1151HANDYRR-SINK-BOND28	Lead, ppb	<1	Less than detection level
BOND29	3/3/2017	6:46:00	BOND-FL1-1152GIRLSRR-SINK-BOND29	Lead, ppb	<1	Less than detection level
BOND30	3/3/2017	6:46:00	BOND-FL1-1153BOYSRR-SINK-BOND30	Lead, ppb	<1	Less than detection level
BOND31	3/3/2017	6:44:00	BOND-FL1-1110-SINK-BOND31	Lead, ppb	1.09	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
BOND32	3/3/2017	6:44:00	BOND-FL1-1110-DF-BOND32	Lead, ppb	<1	Less than detection level

**Cincinnati Public Schools - Bond Hill Academy - Lead Testing Results**

<b>SAMPLE #</b>	<b>SAMPLE DATE</b>	<b>SAMPLE TIME</b>	<b>SAMPLE</b>	<b>PARAMETER CODE</b>	<b>AMOUNT</b>	<b>GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS</b>
BOND33	3/3/2017	6:43:00	BOND-FL1-1050-SINK-BOND33	Lead, ppb	1.71	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
BOND34	3/3/2017	6:43:00	BOND-FL1-1050-DF-BOND34	Lead, ppb	<1	Less than detection level
BOND35	3/3/2017	6:43:00	BOND-FL1-1050RR-SINK-BOND35	Lead, ppb	<1	Less than detection level
BOND36	3/3/2017	6:42:00	BOND-FL1-1040-SINK-BOND36	Lead, ppb	<1	Less than detection level
BOND37	3/3/2017	6:42:00	BOND-FL1-1040-DF-BOND37	Lead, ppb	<1	Less than detection level
BOND38	3/3/2017	6:42:00	BOND-FL1-1040RR-SINK-BOND38	Lead, ppb	<1	Less than detection level
BOND39	3/3/2017	6:35:00	BOND-FL1-1030-SINK-BOND39	Lead, ppb	<1	Less than detection level
BOND40	3/3/2017	6:35:00	BOND-FL1-1030-DF-BOND40	Lead, ppb	<1	Less than detection level
BOND41	3/3/2017	6:35:00	BOND-FL1-1030RR-SINK-BOND41	Lead, ppb	<1	Less than detection level
BOND42	3/3/2017	6:34:00	BOND-FL1-1010-SINK-BOND42	Lead, ppb	<1	Less than detection level
BOND43	3/3/2017	6:34:00	BOND-FL1-1010-DF-BOND43	Lead, ppb	<1	Less than detection level
BOND44	3/3/2017	6:33:00	BOND-FL1-1011RR-SINK-BOND44	Lead, ppb	3.63	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
BOND45	3/3/2017	6:32:00	BOND-FL1-HALLWAYNEAR1010-DF-BOND45	Lead, ppb	2.37	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
BOND46	3/3/2017	6:32:00	BOND-FL1-1020-SINK-BOND46	Lead, ppb	3.14	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

**Cincinnati Public Schools - Bond Hill Academy - Lead Testing Results**

<b>SAMPLE #</b>	<b>SAMPLE DATE</b>	<b>SAMPLE TIME</b>	<b>SAMPLE</b>	<b>PARAMETER CODE</b>	<b>AMOUNT</b>	<b>GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS</b>
BOND47	3/3/2017	6:32:00	BOND-FL1-1020-DF-BOND47	Lead, ppb	<1	Less than detection level
BOND48	3/3/2017	6:32:00	BOND-FL1-1020RR-SINK-BOND48	Lead, ppb	<1	Less than detection level
BOND49	3/3/2017	6:31:00	BOND-FL1-0200FAMILY-SINK-BOND49	Lead, ppb	3.09	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
BOND50	3/3/2017	6:31:00	BOND-FL1-0200FAMILY-DF-BOND50	Lead, ppb	1.33	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
BOND51	3/3/2017	6:30:00	BOND-FL1-0201COMMRM-SINK-BOND51	Lead, ppb	<1	Less than detection level
BOND52	3/3/2017	6:30:00	BOND-FL1-0201COMMRM-DF-BOND52	Lead, ppb	<1	Less than detection level
BOND53	3/3/2017	6:29:00	BOND-FL1-0203STAFFRM-SINK-BOND53	Lead, ppb	4.37	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
BOND54	3/3/2017	6:29:00	BOND-FL1-0203STAFFRM-DF-BOND54	Lead, ppb	1.99	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
BOND55	3/3/2017	6:28:00	BOND-FL1-0308BOYSRR-LSINK-BOND55	Lead, ppb	<1	Less than detection level
BOND56	3/3/2017	6:28:00	BOND-FL1-0308BOYSRR-RSINK-BOND56	Lead, ppb	<1	Less than detection level
BOND57	3/3/2017	6:27:00	BOND-FL1-0309GIRLSRR-LSINK-BOND57	Lead, ppb	<1	Less than detection level
BOND58	3/3/2017	6:27:00	BOND-FL1-0309GIRLSRR-MSINK-BOND58	Lead, ppb	<1	Less than detection level
BOND59	3/3/2017	6:27:00	BOND-FL1-0309GIRLSRR-RSINK-BOND59	Lead, ppb	<1	Less than detection level
BOND60	3/3/2017	6:22:00	BOND-FL1-CAFE-LCOMBODF-BOND60	Lead, ppb	<1	Less than detection level

### Cincinnati Public Schools - Bond Hill Academy - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
BOND61	3/3/2017	6:22:00	BOND-FL1-CAFE-LCOMBOBF-BOND61	Lead, ppb	<1	Less than detection level
BOND62	3/3/2017	6:22:00	BOND-FL1-CAFE-RDF-BOND62	Lead, ppb	<1	Less than detection level
BOND63	3/3/2017	6:21:00	BOND-FL1-KITSTOCKPOT-LFILLER-BOND63	Lead, ppb	2.67	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
BOND64	3/3/2017	6:21:00	BOND-FL1-KITSTOCKPOT-RFILLER-BOND64	Lead, ppb	1.24	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
BOND65	3/3/2017	6:20:00	BOND-FL1-KITNEARSTOCKPOT-HANDSINK-BOND65	Lead, ppb	<1	Less than detection level
BOND66	3/3/2017	6:20:00	BOND-FL1-KITISLAND1TUB-SINK-BOND66	Lead, ppb	2.47	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
BOND67	3/3/2017	6:19:00	BOND-FL1-KIT2TUB-SINK-BOND67	Lead, ppb	2.41	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
BOND68	3/3/2017	6:19:00	BOND-FL1-KITDISHRM3TUB-LSINK-BOND68	Lead, ppb	<1	Less than detection level
BOND69	3/3/2017	6:14:00	BOND-FL1-KITDISHRM3TUB-RSINK-BOND69	Lead, ppb	1.08	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.



### Cincinnati Public Schools - Bond Hill Academy - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
BOND70	3/3/2017	6:14:00	BOND-FL1-KIT0409STAFFLOCKRR-SINK-BOND70	Lead, ppb	<1	Less than detection level
BOND71	3/3/2017	6:13:00	BOND-FL1-KITNEAR0409-HANDSINK-BOND71	Lead, ppb	<1	Less than detection level
BOND72	3/3/2017	6:08:00	BOND-FL1-HALLWAYNEARGYM-DF-BOND72	Lead, ppb	<1	Less than detection level
BOND73	3/3/2017	6:08:00	BOND-FL1-0502PEOFFRR-SINK-BOND73	Lead, ppb	<1	Less than detection level
BOND74	3/3/2017	6:08:00	BOND-FL1-0505GIRLSLOCK-SINK-BOND74	Lead, ppb	<1	Less than detection level
BOND75	3/3/2017	6:07:00	BOND-FL1-0507BOYSLOCK-SINK-BOND75	Lead, ppb	<1	Less than detection level
BOND76	3/3/2017	6:07:00	BOND-FL1-0500GYM-LDF-BOND76	Lead, ppb	<1	Less than detection level
BOND77	3/3/2017	6:44:00	BOND-FL1-0500GYM-RDF-BOND77	Lead, ppb	<1	Less than detection level
BOND78	3/3/2017	6:45:00	BOND-FL2-2010-SINK-BOND78	Lead, ppb	2.37	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
BOND79	3/3/2017	6:49:00	BOND-FL2-2030-SINK-BOND79	Lead, ppb	1.98	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
BOND80	3/3/2017	6:10:00	BOND-FL2-2040-SINK-BOND80	Lead, ppb	<1	Less than detection level
BOND81	3/3/2017	6:51:00	BOND-FL2-2100-SINK-BOND81	Lead, ppb	<1	Less than detection level
BOND82	3/3/2017	6:51:00	BOND-FL2-2060LWALL-SINK-BOND82	Lead, ppb	3.01	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
BOND83	3/3/2017	6:51:00	BOND-FL2-2060RWALL-SINK-BOND83	Lead, ppb	<1	Less than detection level

### Cincinnati Public Schools - Bond Hill Academy - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
BOND84	3/3/2017	6:52:00	BOND-FL2-2060BWALL-LSINK-BOND84	Lead, ppb	2.08	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
BOND85	3/3/2017	6:52:00	BOND-FL2-2060BWALL-RSINK-BOND85	Lead, ppb	<1	Less than detection level
BOND86	3/3/2017	6:58:00	BOND-FL2-2080STAFFRM-SINK-BOND86	Lead, ppb	1.51	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
BOND87	3/3/2017	6:26:00	BOND-FL2-2210-SINK-BOND87	Lead, ppb	1.1	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
BOND88	3/3/2017	6:26:00	BOND-FL2-2210-DF-BOND88	Lead, ppb	<1	Less than detection level
BOND89	3/3/2017	6:28:00	BOND-FL2-2200-SINK-BOND89	Lead, ppb	<1	Less than detection level
BOND90	3/3/2017	6:29:00	BOND-FL2-2251HANDYRR-SINK-BOND90	Lead, ppb	<1	Less than detection level
BOND91	3/3/2017	6:30:00	BOND-FL2-2252GIRLSRR-SINK-BOND91	Lead, ppb	<1	Less than detection level
BOND92	3/3/2017	6:31:00	BOND-FL2-2253BOYSRR-SINK-BOND92	Lead, ppb	<1	Less than detection level
BOND93	3/3/2017	6:32:00	BOND-FL2-2240-SINK-BOND93	Lead, ppb	<1	Less than detection level
BOND94	3/3/2017	6:32:00	BOND-FL2-2240-DF-BOND94	Lead, ppb	<1	Less than detection level
BOND95	3/3/2017	6:33:00	BOND-FL2-2230-SINK-BOND95	Lead, ppb	1.85	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
BOND96	3/3/2017	6:33:00	BOND-FL2-2230-DF-BOND96	Lead, ppb	<1	Less than detection level

**Cincinnati Public Schools - Bond Hill Academy - Lead Testing Results**

<b>SAMPLE #</b>	<b>SAMPLE DATE</b>	<b>SAMPLE TIME</b>	<b>SAMPLE</b>	<b>PARAMETER CODE</b>	<b>AMOUNT</b>	<b>GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS</b>
BOND97	3/3/2017	6:35:00	BOND-FL2-2220-SINK-BOND97	Lead, ppb	1.32	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
BOND98	3/3/2017	6:35:00	BOND-FL2-2220-DF-BOND98	Lead, ppb	<1	Less than detection level
BOND99	3/3/2017	6:12:00	BOND-FL2-2120-SINK-BOND99	Lead, ppb	<1	Less than detection level
BOND100	3/3/2017	6:12:00	BOND-FL2-2120-DF-BOND100	Lead, ppb	<1	Less than detection level
BOND101	3/3/2017	6:14:00	BOND-FL2-2130-SINK-BOND101	Lead, ppb	<1	Less than detection level
BOND102	3/3/2017	6:14:00	BOND-FL2-2130-DF-BOND102	Lead, ppb	<1	Less than detection level
BOND103	3/3/2017	6:16:00	BOND-FL2-2140-SINK-BOND103	Lead, ppb	<1	Less than detection level
BOND104	3/3/2017	6:16:00	BOND-FL2-2140-DF-BOND104	Lead, ppb	<1	Less than detection level
BOND105	3/3/2017	6:18:00	BOND-FL2-2151HANDYRR-SINK-BOND105	Lead, ppb	<1	Less than detection level
BOND106	3/3/2017	6:19:00	BOND-FL2-2152GIRLSRR-SINK-BOND106	Lead, ppb	<1	Less than detection level
BOND107	3/3/2017	6:20:00	BOND-FL2-2153BOYSRR-SINK-BOND107	Lead, ppb	<1	Less than detection level
BOND108	3/3/2017	6:22:00	BOND-FL2-2110-SINK-BOND108	Lead, ppb	<1	Less than detection level
BOND109	3/3/2017	6:22:00	BOND-FL2-2110-DF-BOND109	Lead, ppb	<1	Less than detection level
BOND110	3/3/2017	6:55:00	BOND-FL2-2050MUSIC-SINK-BOND110	Lead, ppb	2.88	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
BOND111	3/3/2017	6:47:00	BOND-FL2-2002BOYSRR-SINK-BOND111	Lead, ppb	<1	Less than detection level
BOND112	3/3/2017	6:46:00	BOND-FL2-2001GIRLSRR-SINK-BOND112	Lead, ppb	<1	Less than detection level
BOND113	3/3/2017	6:41:00	BOND-FL2-HALLWAYNEAR2001-LDF-BOND113	Lead, ppb	<1	Less than detection level
BOND114	3/3/2017	6:41:00	BOND-FL2-HALLWAYNEAR2001-RDF-BOND114	Lead, ppb	<1	Less than detection level



**Cincinnati Public Schools - Bond Hill Academy - Lead Testing Results**

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
BOND115	3/3/2017	6:39:00	BOND-FL2-2020ART-LSINK-BOND115	Lead, ppb	3.99	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
BOND116	3/3/2017	6:39:00	BOND-FL2-2020ART-MSINK-BOND116	Lead, ppb	3.56	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
BOND117	3/3/2017	6:39:00	BOND-FL2-2020ART-RSINK-BOND117	Lead, ppb	2.97	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
N/A	N/A	N/A	BOND-FL2-2060FRONTDESK-SINK	N/A	N/A	Not sampled. Was off at the time of walkthrough.