



April 20, 2018

## Chase School

Cincinnati Public Schools  
Cynthia Eghbalnia  
2651 Burnet Avenue  
Cincinnati, OH 45219

Dear Cynthia:

Thank you for taking the responsibility seriously to protect the health of the children by voluntarily testing the water in your school for lead!

Attached please find the results of the lead analyses performed for Chase School by the Greater Cincinnati Water Works (GCWW). The following comments speak to the process, samples analyzed and additional steps needed to help ensure the safety of all the students within the school.

### **School Sampling Process and Results**

GCWW and Cincinnati Public Schools (CPS) staff worked together to finalize a sampling plan for the school. The *USEPA 3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance Document (3Ts Guidelines)* is the process and guidelines used for assisting schools with testing for lead.

In October, one hundred, eight (108) samples were collected from drinking fountains, sinks and cooking outlets throughout the school. Multiple sinks within the schools were not initially considered for testing, however, key nearby indicators (coffee makers, drinking cups, plates, utensils, etc.) prompted additional locations to be tested in the schools. Including these sampling locations speaks to the proactive approach CPS continues to have towards understanding the water quality within the schools. The results show the following:

- 66 samples (61.11%), below the detection level (<1)
- 30 samples (27.77%), between 1ppb and 5ppb
- 10 samples (9.26%), between 5ppb and 10ppb
- 1 sample (0.93%), between 10ppb and 15ppb
- 1 sample (0.93%), greater than 15ppb.

Ninety-nine percent (99%) of the results were below the detection level or below the federal action level.

Fifteen parts per billion (ppb) is the federal Lead and Copper Rule action level; desired results are below 15. The federal action level of 15ppb pertains to water utilities and GCWW's review and comments are based on this action level. However, the USEPA 3Ts Guidelines document outlines practices for schools to put in place if samples are greater than 20 ppb.

While we strive to have results less than 15, we recognize that lead is a pervasive environmental contaminant, and no safe blood lead threshold has been identified in children or adults. Therefore, we provide recommendations to further reduce any lead levels discovered in your school.



### Next steps


GCWW has reviewed the results from your samples and provides some next-steps comments.

1. Great news! There were no lead detections at the drinking fountain and bottle filler locations. No further action is suggested.
2. One location, CHAS-FL1-1021-SINK-CHAS36, had a high lead level. Based on the sample name, it is assumed this is not a drinking water or cooking outlet. Although the location is not used for this purpose, consider immediate remedies such as taking the sample location out of service until a more defined plan can be created OR post a sign above the location limiting the purpose of the sink ('hand washing only', 'work sink only'). Posting a sign will deter students and staff from potentially using the sink to fill a water bottle, etc. For more information, refer to the 3Ts Guidelines that suggest shutting off or disconnecting problem outlets until the problem is resolved. After removing the location from operation, start with
  - a. Removing and cleaning the aerator. Particles may be trapped on the aerator and contributing to the lead level. Consider resampling.
  - b. Flush the line and resample. If the resample shows a reduced lead level, then the infrequent use at this location may be contributing to the lead level. At that time, posting the sign may be helpful in deterring drinking water use.
3. There were thirteen (13) sample locations in the kitchen, staff cafeteria, and cafeteria. Two (2) locations had very low lead detections. A brief flush of the line (letting the water run) before use may reduce the level; no other actions are suggested.
4. Some locations in the gym locker room had higher lead levels, but still below the federal action level. Infrequent use may be the cause of these lead detections. Lead is not an issue for body contact such as bathing, showering, and washing hands.
5. All locations in a science room (samples CHAS77 through CHAS81) had lead detections. Again, infrequent may be the cause of the lead detections. If there is a chance that these locations might be used for drinking purposes, consider posting signs to deter students and staff from potentially using the sinks to fill a water bottle, etc.
6. Several other sinks had lead detections. Based on the names, these are not used for drinking water or cooking purposes.
  - a. Lead is not an issue for body contact such as bathing, showering, and washing hands.
  - b. Cleaning the aerators at these locations may lower the lead levels.
  - c. If the locations with lead detections are not used on a regular basis, then the infrequent use may be contributing to the lead detections.
7. Review how water is being used within your facility. If water is not used on a regular basis at some of these locations, the infrequent use at the outlet may be contributing to the lead detections. Signage at these locations may be helpful (hand washing only, science class purposes only-no drinking, etc.).
8. If it hasn't occurred already, a robust communications plan is suggested. Communications plan steps are outlined in the 3Ts Guidelines. This plan will inform the school community of the sampling work the school has done to date and the steps the school will take to correct any issues discovered. GCWW employees can assist with this plan and are available to attend any school meetings to help explain our lead program, the sample results and our partnership with your school. Suggestions for language and a letter template can be provided if needed. Sampling results will be posted on the GCWW [lead.mygcww.org](http://lead.mygcww.org) website with other school sampling results.

Greater Cincinnati Water Works takes the presence of lead service lines and the removal of those service lines in our system very seriously. In addition, minimizing the exposure of lead within our preschools, schools, and daycares is one of our highest priorities under our Enhanced Lead Program. Please contact Jim Nelson at 591-6869 if you have any questions.

Thanks again for your partnership with Greater Cincinnati Water Works and your work to further understand the water quality within your building. Your extra steps and care to keep the children in our community safe are appreciated!

Sincerely,

A handwritten signature in black ink that reads "Cathy B. Bailey". The signature is written in a cursive, flowing style.

Cathy B. Bailey  
Director/Greater Cincinnati Water Works

Cc: Dr. Marilyn Crumpton, Cincinnati Health Department  
Dr. Camille Jones, Cincinnati Health Department  
Chuck DeJonckheere, Hamilton County Public Health  
Patrick Duhaney, City of Cincinnati  
Verna Arnette, Greater Cincinnati Water Works  
Jeff Swertfeger, Greater Cincinnati Water Works  
Jason DeLaet, Greater Cincinnati Water Works  
James Nelson, Greater Cincinnati Water Works

### Cincinnati Public Schools - Chase School - Lead Testing Results

Sample #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
CHAS1	10/27/2017	5:37	CHAS-FL1-KITSTAFFRNEAR1120-SINK-CHAS1	Lead, ppb	<1	Less than detection level
CHAS2	10/27/2017	5:38	CHAS-FL1-KITDISHRM3TUB-LSINK-CHAS2	Lead, ppb	<1	Less than detection level
CHAS3	10/27/2017	5:38	CHAS-FL1-KITDISHRM3TUB-RSINK-CHAS3	Lead, ppb	<1	Less than detection level
CHAS4	10/27/2017	5:39	CHAS-FL1-KITDISHRM-HANDSINK-CHAS4	Lead, ppb	1.12	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
CHAS5	10/27/2017	5:40	CHAS-FL1-KITNEARSERVE-HANDSINK-CHAS5	Lead, ppb	<1	Less than detection level
CHAS6	10/27/2017	5:41	CHAS-FL1-KITSTOCKPOT-FILLER-CHAS6	Lead, ppb	<1	Less than detection level
CHAS7	10/27/2017	5:42	CHAS-FL1-KITNEARSTOCKPOT-HANDSINK-CHAS7	Lead, ppb	<1	Less than detection level
CHAS8	10/27/2017	5:43	CHAS-FL1-KIT1TUB-SINK-CHAS8	Lead, ppb	<1	Less than detection level
CHAS9	10/27/2017	5:43	CHAS-FL1-KIT2TUB-SINK-CHAS9	Lead, ppb	<1	Less than detection level
CHAS10	10/27/2017	5:49	CHAS-FL1-RRNEAR1100-LSINK-CHAS10	Lead, ppb	<1	Less than detection level
CHAS11	10/27/2017	5:49	CHAS-FL1-RRNEAR1100-MSINK-CHAS11	Lead, ppb	<1	Less than detection level
CHAS12	10/27/2017	5:49	CHAS-FL1-RRNEAR1100-RSINK-CHAS12	Lead, ppb	<1	Less than detection level
CHAS13	10/27/2017	5:50	CHAS-FL1-1112STAFFCAFE-SINK-CHAS13	Lead, ppb	1.56	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
CHAS14	10/27/2017	5:51	CHAS-FL1-CAFE-LDF-CHAS14	Lead, ppb	<1	Less than detection level
CHAS15	10/27/2017	5:51	CHAS-FL1-CAFE-RCOMBODF-CHAS15	Lead, ppb	<1	Less than detection level
CHAS16	10/27/2017	5:51	CHAS-FL1-CAFE-RCOMBOBF-CHAS16	Lead, ppb	<1	Less than detection level
CHAS17	10/27/2017	5:54	CHAS-FL1-1110ART-LSINK-CHAS17	Lead, ppb	<1	Less than detection level
CHAS18	10/27/2017	5:54	CHAS-FL1-1110ART-RSINK-CHAS18	Lead, ppb	1.3	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
CHAS19	10/27/2017	5:55	CHAS-FL1-RRNEAR1110-FLSINK-CHAS19	Lead, ppb	<1	Less than detection level
CHAS20	10/27/2017	5:55	CHAS-FL1-RRNEAR1110-LSINK-CHAS20	Lead, ppb	<1	Less than detection level
CHAS21	10/27/2017	5:55	CHAS-FL1-RRNEAR1110-RSINK-CHAS21	Lead, ppb	<1	Less than detection level
CHAS22	10/27/2017	5:55	CHAS-FL1-RRNEAR1110-FRSINK-CHAS22	Lead, ppb	<1	Less than detection level

### Cincinnati Public Schools - Chase School - Lead Testing Results

Sample #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
CHAS23	10/27/2017	5:56	CHAS-FL1-PEOFF1101RR-SINK-CHAS23	Lead, ppb	1.09	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
CHAS24	10/27/2017	5:57	CHAS-FL1-GYMBOYSLOCK-LSINK-CHAS24	Lead, ppb	6.9	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
CHAS25	10/27/2017	5:57	CHAS-FL1-GYMBOYSLOCK-RSINK-CHAS25	Lead, ppb	3.12	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
CHAS26	10/27/2017	5:57	CHAS-FL1-GYMGIRLSLOCK-LSINK-CHAS26	Lead, ppb	8.37	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
CHAS27	10/27/2017	5:57	CHAS-FL1-GYMGIRLSLOCK-RSINK-CHAS27	Lead, ppb	8.5	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
CHAS28	10/27/2017	5:58	CHAS-FL1-GYM-LDF-CHAS28	Lead, ppb	<1	Less than detection level
CHAS29	10/27/2017	5:58	CHAS-FL1-GYM-RDF-CHAS29	Lead, ppb	<1	Less than detection level
CHAS30	10/27/2017	5:59	CHAS-FL1-FAMILYRRNEAR1018-SINK-CHAS30	Lead, ppb	<1	Less than detection level
CHAS31	10/27/2017	6:02	CHAS-FL1-MO1002MAILRM-SINK-CHAS31	Lead, ppb	<1	Less than detection level
CHAS32	10/27/2017	6:02	CHAS-FL1-MOSTAFFRRNEAR1012-SINK-CHAS32	Lead, ppb	<1	Less than detection level
CHAS33	10/27/2017	6:04	CHAS-FL1-MO1014HEALTH-SINK-CHAS33	Lead, ppb	1.41	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
CHAS34	10/27/2017	6:04	CHAS-FL1-MO1014HEALTH-DF-CHAS34	Lead, ppb	<1	Less than detection level
CHAS35	10/27/2017	6:04	CHAS-FL1-MO1014HEALTHRR-SINK-CHAS35	Lead, ppb	5.91	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

### Cincinnati Public Schools - Chase School - Lead Testing Results

Sample #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
CHAS36	10/27/2017	6:05	CHAS-FL1-1021-SINK-CHAS36	Lead, ppb	21.1	Library Office/Work Room Sink. Above 15ppb federal action level and the 20ppb trigger level to take action as explained in the USEPA 3Ts Guidelines for schools. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
CHAS37	10/27/2017	6:06	CHAS-FL1-1222-SINK-CHAS37	Lead, ppb	<1	Less than detection level
CHAS38	10/27/2017	6:06	CHAS-FL1-1222-DF-CHAS38	Lead, ppb	<1	Less than detection level
CHAS39	10/27/2017	6:11	CHAS-FL1-1222RR-SINK-CHAS39	Lead, ppb	<1	Less than detection level
CHAS40	10/27/2017	6:12	CHAS-FL1-1226-SINK-CHAS40	Lead, ppb	<1	Less than detection level
CHAS41	10/27/2017	6:12	CHAS-FL1-1226-DF-CHAS41	Lead, ppb	<1	Less than detection level
CHAS42	10/27/2017	6:12	CHAS-FL1-1226RR-SINK-CHAS42	Lead, ppb	<1	Less than detection level
CHAS43	10/27/2017	6:14	CHAS-FL1-1220-SINK-CHAS43	Lead, ppb	2.58	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
CHAS44	10/27/2017	6:14	CHAS-FL1-1228-SINK-CHAS44	Lead, ppb	<1	Less than detection level
CHAS45	10/27/2017	6:14	CHAS-FL1-1228-DF-CHAS45	Lead, ppb	<1	Less than detection level
CHAS46	10/27/2017	6:14	CHAS-FL1-1228RR-SINK-CHAS46	Lead, ppb	<1	Less than detection level
CHAS47	10/27/2017	6:17	CHAS-FL1-1224-SINK-CHAS47	Lead, ppb	1.31	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
CHAS48	10/27/2017	6:17	CHAS-FL1-1224-DF-CHAS48	Lead, ppb	<1	Less than detection level
CHAS49	10/27/2017	6:17	CHAS-FL1-1224RR-SINK-CHAS49	Lead, ppb	<1	Less than detection level
CHAS50	10/27/2017	6:20	CHAS-FL1-STAFFRRNEAR1212-SINK-CHAS50	Lead, ppb	<1	Less than detection level
CHAS51	10/27/2017	6:20	CHAS-FL1-NEAR1300LRR-SINK-CHAS51	Lead, ppb	2.28	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
CHAS52	10/27/2017	6:20	CHAS-FL1-NEAR1300MRR-SINK-CHAS52	Lead, ppb	<1	Less than detection level

### Cincinnati Public Schools - Chase School - Lead Testing Results

Sample #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
CHAS53	10/27/2017	6:20	CHAS-FL1-NEAR1300RRR-SINK-CHAS53	Lead, ppb	<1	Less than detection level
CHAS54	10/27/2017	6:21	CHAS-FL1-1304-SINK-CHAS54	Lead, ppb	2.49	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
CHAS55	10/27/2017	6:27	CHAS-FL1-1304-DF-CHAS55	Lead, ppb	<1	Less than detection level
CHAS56	10/27/2017	6:23	CHAS-FL1-1302-SINK-CHAS56	Lead, ppb	<1	Less than detection level
CHAS57	10/27/2017	5:40	CHAS-FL1-1302-DF-CHAS57	Lead, ppb	<1	Less than detection level
CHAS58	10/27/2017	5:41	CHAS-FL1-1300-SINK-CHAS58	Lead, ppb	2.8	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
CHAS59	10/27/2017	5:42	CHAS-FL1-1301-SINK-CHAS59	Lead, ppb	9.4	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
CHAS60	10/27/2017	5:44	CHAS-FL1-1301-DF-CHAS60	Lead, ppb	<1	Less than detection level
CHAS61	10/27/2017	5:46	CHAS-FL1-1303-SINK-CHAS61	Lead, ppb	3.63	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
CHAS62	10/27/2017	5:47	CHAS-FL1-1303-DF-CHAS62	Lead, ppb	<1	Less than detection level
CHAS63	10/27/2017	5:49	CHAS-FL1-NEAR1209LRR-SINK-CHAS63	Lead, ppb	<1	Less than detection level
CHAS64	10/27/2017	5:50	CHAS-FL1-NEAR1209MRR-SINK-CHAS64	Lead, ppb	<1	Less than detection level
CHAS65	10/27/2017	5:51	CHAS-FL1-NEAR1209RRR-SINK-CHAS65	Lead, ppb	<1	Less than detection level
CHAS66	10/27/2017	5:53	CHAS-FL1-1204-SINK-CHAS66	Lead, ppb	2.31	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
CHAS67	10/27/2017	5:55	CHAS-FL1-1204-DF-CHAS67	Lead, ppb	<1	Less than detection level
CHAS68	10/27/2017	5:57	CHAS-FL1-1202-SINK-CHAS68	Lead, ppb	1.59	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
CHAS69	10/27/2017	5:56	CHAS-FL1-1202-DF-CHAS69	Lead, ppb	<1	Less than detection level

### Cincinnati Public Schools - Chase School - Lead Testing Results

Sample #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
CHAS70	10/27/2017	5:58	CHAS-FL1-1200-SINK-CHAS70	Lead, ppb	1.08	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
CHAS71	10/27/2017	5:59	CHAS-FL1-1201-SINK-CHAS71	Lead, ppb	3.92	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
CHAS72	10/27/2017	6:00	CHAS-FL1-1201-DF-CHAS72	Lead, ppb	<1	Less than detection level
CHAS73	10/27/2017	6:01	CHAS-FL1-1203-SINK-CHAS73	Lead, ppb	2.18	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
CHAS74	10/27/2017	6:01	CHAS-FL1-1203-DF-CHAS74	Lead, ppb	<1	Less than detection level
CHAS75	10/27/2017	6:03	CHAS-FL1-1210WORKRM-SINK-CHAS75	Lead, ppb	1.96	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
CHAS76	10/27/2017	6:02	CHAS-FL1-1210WORKRM-DF-CHAS76	Lead, ppb	<1	Less than detection level
CHAS77	10/27/2017	6:07	CHAS-FL2-2403FRONTDESK-SINK-CHAS77	Lead, ppb	7.63	Science Room. Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
CHAS78	10/27/2017	6:08	CHAS-FL2-2403LWALL-LSINK-CHAS78	Lead, ppb	2.41	Science Room. Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
CHAS79	10/27/2017	6:09	CHAS-FL2-2403LWALL-RSINK-CHAS79	Lead, ppb	9.12	Science Room. Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.



### Cincinnati Public Schools - Chase School - Lead Testing Results

Sample #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
CHAS80	10/27/2017	6:10	CHAS-FL2-2403RWALL-LSINK-CHAS80	Lead, ppb	12.7	Science Room. Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
CHAS81	10/27/2017	6:10	CHAS-FL2-2403RWALL-RSINK-CHAS81	Lead, ppb	4.76	Science Room. Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
CHAS82	10/27/2017	6:13	CHAS-FL2-2401-SINK-CHAS82	Lead, ppb	1.49	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
CHAS83	10/27/2017	6:12	CHAS-FL2-2401-DF-CHAS83	Lead, ppb	<1	Less than detection level
CHAS84	10/27/2017	6:14	CHAS-FL2-2400-SINK-CHAS84	Lead, ppb	2.26	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
CHAS85	10/27/2017	6:15	CHAS-FL2-2400-DF-CHAS85	Lead, ppb	<1	Less than detection level
CHAS86	10/27/2017	6:16	CHAS-FL2-2402-SINK-CHAS86	Lead, ppb	2.99	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
CHAS87	10/27/2017	6:17	CHAS-FL2-2402-DF-CHAS87	Lead, ppb	<1	Less than detection level
CHAS88	10/27/2017	6:18	CHAS-FL2-2404-SINK-CHAS88	Lead, ppb	5.8	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
CHAS89	10/27/2017	6:19	CHAS-FL2-2404-DF-CHAS89	Lead, ppb	<1	Less than detection level
CHAS90	10/27/2017	6:20	CHAS-FL2-NEAR2400LRR-SINK-CHAS90	Lead, ppb	<1	Less than detection level
CHAS91	10/27/2017	6:21	CHAS-FL2-NEAR2400MRR-SINK-CHAS91	Lead, ppb	<1	Less than detection level
CHAS92	10/27/2017	6:22	CHAS-FL2-NEAR2400RRR-SINK-CHAS92	Lead, ppb	<1	Less than detection level

### Cincinnati Public Schools - Chase School - Lead Testing Results

Sample #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
CHAS93	10/27/2017	6:24	CHAS-FL2-2410WORKRM-SINK-CHAS93	Lead, ppb	1.51	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
CHAS94	10/27/2017	6:27	CHAS-FL2-NEAR2420LRR-SINK-CHAS94	Lead, ppb	1.11	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
CHAS95	10/27/2017	6:28	CHAS-FL2-NEAR2420MRR-SINK-CHAS95	Lead, ppb	<1	Less than detection level
CHAS96	10/27/2017	6:29	CHAS-FL2-NEAR2420RRR-SINK-CHAS96	Lead, ppb	<1	Less than detection level
CHAS97	10/27/2017	6:30	CHAS-FL2-2422-SINK-CHAS97	Lead, ppb	2.72	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
CHAS98	10/27/2017	6:31	CHAS-FL2-2422-DF-CHAS98	Lead, ppb	<1	Less than detection level
CHAS99	10/27/2017	6:32	CHAS-FL2-2424-SINK-CHAS99	Lead, ppb	2.87	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
CHAS100	10/27/2017	6:33	CHAS-FL2-2424-DF-CHAS100	Lead, ppb	<1	Less than detection level
CHAS101	10/27/2017	6:34	CHAS-FL2-2420-SINK-CHAS101	Lead, ppb	1.22	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
CHAS102	10/27/2017	6:34	CHAS-FL2-2423-SINK-CHAS102	Lead, ppb	6.55	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
CHAS103	10/27/2017	6:35	CHAS-FL2-2423-DF-CHAS103	Lead, ppb	<1	Less than detection level
CHAS104	10/27/2017	6:37	CHAS-FL2-2421-SINK-CHAS104	Lead, ppb	9.4	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
CHAS105	10/27/2017	6:36	CHAS-FL2-2421-DF-CHAS105	Lead, ppb	<1	Less than detection level

**Cincinnati Public Schools - Chase School - Lead Testing Results**

Sample #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
CHAS106	10/27/2017	6:38	CHAS-FL2-2412-SINK-CHAS106	Lead, ppb	1.46	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
CHAS107	10/27/2017	6:38	CHAS-FL2-2412-DF-CHAS107	Lead, ppb	<1	Less than detection level
CHAS108	10/27/2017	6:39	CHAS-FL2-2412RR-SINK-CHAS108	Lead, ppb	1.01	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.