



March 31, 2017

Cincinnati Public Schools
Cynthia Eghbalnia
2651 Burnet Avenue
Cincinnati, OH 45219

Cheviot School Resamples

Dear Cynthia:

Two samples were collected in a resample round of lead analyses for Cheviot School. Greater Cincinnati Water Works (GCWW) analyzed the samples and compared the results.

School Sample Results

The USEPA 3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance Document (3Ts Guidelines) is the process and guidelines used for assisting schools with testing for lead. Results are below.

Cincinnati Public Schools - Cheviot School Lead Testing Results-Resamples				
SAMPLE #	SAMPLE NAME	Initial sample DATE 10/21/16 Lead, ppb	CHANGES MADE BY SCHOOL AFTER INITIAL TESTING	Resample DATE 2/3/17 Lead, ppb
CHE47	CHE-FL1-BOYSRRNEARCAFE-RSINK	N/A	FAUCET HAS BEEN FIXED. AT THE TIME OF SAMPLING THE FIRST TIME, IT WAS BROKE.	<1
CHE105	CHE-FL2-BOYSRRNEAR2507-SINK	N/A	FAUCET HAS BEEN FIXED. AT THE TIME OF SAMPLING THE FIRST TIME, IT WAS BROKE.	<1

Changes made and Next Steps

In the first round of sampling, sample # CHE47 [CHE-FL1-BOYSRRNEARCAFE-RSINK] and sample # CHE105 [CHE-FL2-BOYSRRNEAR2507-SINK] were out of service. Faucets were fixed after the October 2016 sampling round and then sampled in February 2017. Results are below the lead detection level; no lead was detected and no further action is needed.

Fixing these two sinks in the school continues to improve the water quality for the students and staff. Your decisions and actions throughout this process speak to your care and commitment to ensure students and staff remain safe and healthy while attending your school.



We look forward to our continued partnership with your school. Our resources are available to assist in many ways. Please contact Jim Nelson at 591-6869 if you have any questions.

Sincerely,

A handwritten signature in black ink that reads "Cathy B. Bailey". The signature is written in a cursive style with a large initial 'C' and 'B'.

Cathy B. Bailey
Director/Greater Cincinnati Water Works

Cc: Dr. Marilyn Crumpton, Cincinnati Health Department
Dr. Camille Jones, Cincinnati Health Department
Chuck DeJonckheere, Hamilton County Public Health
Sheila Hill-Christian, City of Cincinnati
Verna Arnette, Greater Cincinnati Water Works
Jeff Swertfeger, Greater Cincinnati Water Works
Jason DeLaet, Greater Cincinnati Water Works