



May 10, 2018

Cincinnati Public Schools
Cynthia Eghbalnia
2651 Burnet Avenue
Cincinnati, OH 45219

**Ethel Taylor
Academy**

Dear Cynthia:

Thank you for taking the responsibility seriously to protect the health of the children by voluntarily testing the water in your school for lead!

Attached please find the results of the lead analyses performed for Ethel Taylor Academy by the Greater Cincinnati Water Works (GCWW). The following comments speak to the process, samples analyzed and additional steps needed to help ensure the safety of all the students within the school.

School Sampling Process and Results

GCWW and Cincinnati Public Schools (CPS) staff worked together to finalize a sampling plan for the school. The *USEPA 3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance Document (3Ts Guidelines)* is the process and guidelines used for assisting schools with testing for lead.

In November, one hundred, twenty-two (122) samples were collected from drinking fountains, sinks and cooking outlets throughout the school. Multiple sinks within the schools were not initially considered for testing, however, key nearby indicators (coffee makers, drinking cups, plates, utensils, etc.) prompted additional locations to be tested in the schools. Including these sampling locations speaks to the proactive approach CPS continues to have towards understanding the water quality within the schools. Nine (9) additional locations were not sampled. The results show the following:

- 93 samples (76.23%), below the detection level (<1)
- 27 samples (22.13%), between 1ppb and 5ppb
- 0 samples (0%), between 5ppb and 10ppb
- 2 samples (1.64%), between 10ppb and 15ppb
- 0 samples (0%), greater than 15ppb.

One hundred percent (100%) of the results were below the detection level or below the federal action level.

Fifteen parts per billion (ppb) is the federal Lead and Copper Rule action level; desired results are below 15. The federal action level of 15ppb pertains to water utilities and GCWW's review and comments are based on this action level. However, the USEPA 3Ts Guidelines document outlines practices for schools to put in place if samples are greater than 20 ppb.

While we strive to have results less than 15, we recognize that lead is a pervasive environmental contaminant, and no safe blood lead threshold has been identified in children or adults. Therefore, we provide recommendations to further reduce any lead levels discovered in your school.



Next steps


GCWW has reviewed the results from your samples and provides some next-steps comments.

1. Good news! The majority of the drinking fountains and bottle fillers had no lead detections. Two locations, ETA-FL1-160CAFE-LCOMBOBF-ETA12 and ETA-FL1-160CAFE-RDF-ETA13, had low lead detections. These are very low detections; if interested in lowering these levels, flush the line (let the water run) before use. No further action is suggested.
2. Four of the sample locations in the kitchen had lead detections:
 - ETA-FL1-KITSTAFFRR-SINK-ETA2, 2.94ppb
 - ETA-FL1-KIT2TUB-SINK-ETA3, 1.19ppb
 - ETA-FL1-KITNEAR2TUB-HANDSINK-ETA4, 10.8ppb
 - ETA-FL1-KITNEARDISHRM-HANDSINK-ETA7, 2.47ppb.If these locations are used for food and drink preparation, flush the line (let the water run) before use.
3. Several sinks had low lead detections. Based on the names, these are not used for drinking water or cooking purposes.
 - a. Lead is not an issue for body contact such as bathing, showering, and washing hands.
 - a. Consider removing and cleaning the aerator. Particles may be trapped on the aerator and contributing to the lead level.
 - b. If the locations with lead detections are not used on a regular basis, then the infrequent use may be contributing to the lead detections.
4. Review how water is being used within your facility. If water is not used on a regular basis at some of these locations, again, the infrequent use at the outlet may be contributing to the lead detections. Signage at these locations may be helpful (hand washing only, science class purposes only-no drinking, etc.).
5. If it hasn't occurred already, a robust communications plan is suggested. Communications plan steps are outlined in the 3Ts Guidelines. This plan will inform the school community of the sampling work the school has done to date and the steps the school will take to correct any issues discovered. GCWW employees can assist with this plan and are available to attend any school meetings to help explain our lead program, the sample results and our partnership with your school. Suggestions for language and a letter template can be provided if needed. Sampling results will be posted on the GCWW lead.mygcww.org website with other school sampling results.

Greater Cincinnati Water Works takes the presence of lead service lines and the removal of those service lines in our system very seriously. In addition, minimizing the exposure of lead within our preschools, schools, and daycares is one of our highest priorities under our Enhanced Lead Program. Please contact Jim Nelson at 591-6869 if you have any questions.

Thanks again for your partnership with Greater Cincinnati Water Works and your work to further understand the water quality within your building. Your extra steps and care to keep the children in our community safe are appreciated!

Sincerely,



Cathy B. Bailey
Director/Greater Cincinnati Water Works

Cc: Dr. Marilyn Crumpton, Cincinnati Health Department
Dr. Camille Jones, Cincinnati Health Department

Chuck DeJonckheere, Hamilton County Public Health
Patrick Duhaney, City of Cincinnati
Verna Arnette, Greater Cincinnati Water Works
Jeff Swertfeger, Greater Cincinnati Water Works
Jason DeLaet, Greater Cincinnati Water Works
James Nelson, Greater Cincinnati Water Works

Cincinnati Public Schools - Ethel M. Taylor Academy - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
ETA1	11/3/2017	5:12	ETA-FL1-KITNEAR158-HANDSINK-ETA1	Lead, ppb	<1	Less than detection level
ETA2	11/3/2017	5:13	ETA-FL1-KITSTAFFRR-SINK-ETA2	Lead, ppb	2.94	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ETA3	11/3/2017	5:14	ETA-FL1-KIT2TUB-SINK-ETA3	Lead, ppb	1.19	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ETA4	11/3/2017	5:14	ETA-FL1-KITNEAR2TUB-HANDSINK-ETA4	Lead, ppb	10.8	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ETA5	11/3/2017	5:17	ETA-FL1-KITSTOCKPOT-LFILLER-ETA5	Lead, ppb	<1	Less than detection level
ETA6	11/3/2017	5:18	ETA-FL1-KITSTOCKPOT-RFILLER-ETA6	Lead, ppb	<1	Less than detection level
ETA7	11/3/2017	5:20	ETA-FL1-KITNEARDISHRM-HANDSINK-ETA7	Lead, ppb	2.47	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ETA8	11/3/2017	5:21	ETA-FL1-KITDISHRM-HANDSINK-ETA8	Lead, ppb	<1	Less than detection level
ETA9	11/3/2017	5:22	ETA-FL1-KITDISHRM3TUB-LSINK-ETA9	Lead, ppb	<1	Less than detection level
ETA10	11/3/2017	5:22	ETA-FL1-KITDISHRM3TUB-RSINK-ETA10	Lead, ppb	<1	Less than detection level
ETA11	11/3/2017	5:23	ETA-FL1-160CAFE-LCOMBODF-ETA11	Lead, ppb	<1	Less than detection level
ETA12	11/3/2017	5:24	ETA-FL1-160CAFE-LCOMBOBF-ETA12	Lead, ppb	2.48	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ETA13	11/3/2017	5:25	ETA-FL1-160CAFE-RDF-ETA13	Lead, ppb	1.65	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ETA14	11/3/2017	5:27	ETA-FL1-146GYM-DF-ETA14	Lead, ppb	<1	Less than detection level
ETA15	11/3/2017	5:29	ETA-FL1-150GIRLSLOCK-LSINK-ETA15	Lead, ppb	<1	Less than detection level
ETA16	11/3/2017	5:29	ETA-FL1-150GIRLSLOCK-RSINK-ETA16	Lead, ppb	<1	Less than detection level
ETA17	11/3/2017	5:32	ETA-FL1-147BOYSLOCK-LSINK-ETA17	Lead, ppb	<1	Less than detection level

Cincinnati Public Schools - Ethel M. Taylor Academy - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
ETA18	11/3/2017	5:32	ETA-FL1-147BOYSLOCK-RSINK-ETA18	Lead, ppb	<1	Less than detection level
ETA19	11/3/2017	5:34	ETA-FL1-148PEOFFRR-SINK-ETA19	Lead, ppb	<1	Less than detection level
ETA20	11/3/2017	5:37	ETA-FL1-140MUSIC-SINK-ETA20	Lead, ppb	<1	Less than detection level
ETA21	11/3/2017	5:37	ETA-FL1-140MUSIC-DF-ETA21	Lead, ppb	<1	Less than detection level
ETA22	11/3/2017	5:39	ETA-FL1-HALLNEAR140-LDF-ETA22	Lead, ppb	<1	Less than detection level
ETA23	11/3/2017	5:39	ETA-FL1-HALLNEAR140-RDF-ETA23	Lead, ppb	<1	Less than detection level
ETA24	11/3/2017	5:42	ETA-FL1-BOYSRRNEAR140-FLSINK-ETA24	Lead, ppb	<1	Less than detection level
ETA25	11/3/2017	5:42	ETA-FL1-BOYSRRNEAR140-LSINK-ETA25	Lead, ppb	<1	Less than detection level
ETA26	11/3/2017	5:42	ETA-FL1-BOYSRRNEAR140-MSINK-ETA26	Lead, ppb	1.16	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ETA27	11/3/2017	5:42	ETA-FL1-BOYSRRNEAR140-RSINK-ETA27	Lead, ppb	3.12	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ETA28	11/3/2017	5:42	ETA-FL1-BOYSRRNEAR140-FRSINK-ETA28	Lead, ppb	<1	Less than detection level
ETA29	11/3/2017	5:47	ETA-FL1-GIRLSRRNEAR140-FLSINK-ETA29	Lead, ppb	3.02	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ETA30	11/3/2017	5:47	ETA-FL1-GIRLSRRNEAR140-LSINK-ETA30	Lead, ppb	1.07	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ETA31	11/3/2017	5:47	ETA-FL1-GIRLSRRNEAR140-MSINK-ETA31	Lead, ppb	<1	Less than detection level
ETA32	11/3/2017	5:47	ETA-FL1-GIRLSRRNEAR140-RSINK-ETA32	Lead, ppb	<1	Less than detection level
ETA33	11/3/2017	5:47	ETA-FL1-GIRLSRRNEAR140-FRSINK-ETA33	Lead, ppb	<1	Less than detection level
ETA34	11/3/2017	5:49	ETA-FL1-STAFFRRNEAR140-SINK-ETA34	Lead, ppb	<1	Less than detection level
ETA35	11/3/2017	5:51	ETA-FL1-138WORKRM-SINK-ETA35	Lead, ppb	1.17	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

Cincinnati Public Schools - Ethel M. Taylor Academy - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
ETA36	11/3/2017	5:55	ETA-FL1-136-SINK-ETA36	Lead, ppb	3.28	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ETA37	11/3/2017	5:55	ETA-FL1-136-DF-ETA37	Lead, ppb	<1	Less than detection level
ETA38	11/3/2017	5:56	ETA-FL1-136RR-SINK-ETA38	Lead, ppb	<1	Less than detection level
ETA39	11/3/2017	5:58	ETA-FL1-134-SINK-ETA39	Lead, ppb	<1	Less than detection level
ETA40	11/3/2017	5:58	ETA-FL1-134-DF-ETA40	Lead, ppb	<1	Less than detection level
ETA41	11/3/2017	5:12	ETA-FL1-134RR-SINK-ETA41	Lead, ppb	<1	Less than detection level
ETA42	11/3/2017	5:12	ETA-FL1-132-SINK-ETA42	Lead, ppb	1.11	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ETA43	11/3/2017	5:12	ETA-FL1-132-DF-ETA43	Lead, ppb	<1	Less than detection level
ETA44	11/3/2017	5:13	ETA-FL1-132RR-SINK-ETA44	Lead, ppb	1.87	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ETA45	11/3/2017	5:17	ETA-FL1-130-SINK-ETA45	Lead, ppb	<1	Less than detection level
ETA46	11/3/2017	5:17	ETA-FL1-130-DF-ETA46	Lead, ppb	<1	Less than detection level
ETA47	11/3/2017	5:18	ETA-FL1-130RR-SINK-ETA47	Lead, ppb	<1	Less than detection level
ETA48	11/3/2017	5:19	ETA-FL1-128-SINK-ETA48	Lead, ppb	<1	Less than detection level
ETA49	11/3/2017	5:19	ETA-FL1-128-DF-ETA49	Lead, ppb	<1	Less than detection level
ETA50	11/3/2017	5:20	ETA-FL1-128RR-SINK-ETA50	Lead, ppb	<1	Less than detection level
ETA51	11/3/2017	5:21	ETA-FL1-125-SINK-ETA51	Lead, ppb	1.23	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ETA52	11/3/2017	5:21	ETA-FL1-125RR-SINK-ETA52	Lead, ppb	<1	Less than detection level
ETA53	11/3/2017	5:23	ETA-FL1-122ART-LSINK-ETA53	Lead, ppb	<1	Less than detection level
ETA54	11/3/2017	5:23	ETA-FL1-122ART-MSINK-ETA54	Lead, ppb	<1	Less than detection level
ETA55	11/3/2017	5:23	ETA-FL1-122ART-RSINK-ETA55	Lead, ppb	<1	Less than detection level

Cincinnati Public Schools - Ethel M. Taylor Academy - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
ETA56	11/3/2017	5:24	ETA-FL1-118WORKRM-SINK-ETA56	Lead, ppb	1.13	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ETA57	11/3/2017	5:26	ETA-FL1-112HEALTH-SINK-ETA57	Lead, ppb	<1	Less than detection level
ETA58	11/3/2017	5:26	ETA-FL1-112HEALTHRR-SINK-ETA58	Lead, ppb	<1	Less than detection level
ETA59	11/3/2017	5:26	ETA-FL1-112LEXAMRM-SINK-ETA59	Lead, ppb	4.18	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ETA60	11/3/2017	5:26	ETA-FL1-112REXAMRM-SINK-ETA60	Lead, ppb	2.78	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ETA61	11/3/2017	5:28	ETA-FL1-114-SINK-ETA61	Lead, ppb	2.07	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ETA62	11/3/2017	5:30	ETA-FL1-107WORKRM-SINK-ETA62	Lead, ppb	<1	Less than detection level
ETA63	11/3/2017	5:30	ETA-FL1-107MRR-SINK-ETA63	Lead, ppb	<1	Less than detection level
ETA64	11/3/2017	5:30	ETA-FL1-107WRR-SINK-ETA64	Lead, ppb	<1	Less than detection level
ETA65	11/3/2017	5:35	ETA-FL2-223WORKRM-SINK-ETA65	Lead, ppb	<1	Less than detection level
ETA66	11/3/2017	5:38	ETA-FL2-222-SINK-ETA66	Lead, ppb	<1	Less than detection level
ETA67	11/3/2017	5:38	ETA-FL2-222-DF-ETA67	Lead, ppb	<1	Less than detection level
ETA68	11/3/2017	5:39	ETA-FL2-220-SINK-ETA68	Lead, ppb	<1	Less than detection level
ETA69	11/3/2017	5:39	ETA-FL2-220-DF-ETA69	Lead, ppb	<1	Less than detection level
ETA70	11/3/2017	5:40	ETA-FL2-219-SINK-ETA70	Lead, ppb	<1	Less than detection level
ETA71	11/3/2017	5:40	ETA-FL2-219-DF-ETA71	Lead, ppb	<1	Less than detection level
ETA72	11/3/2017	5:41	ETA-FL2-218-SINK-ETA72	Lead, ppb	<1	Less than detection level
ETA73	11/3/2017	5:41	ETA-FL2-218-DF-ETA73	Lead, ppb	<1	Less than detection level
ETA74	11/3/2017	5:42	ETA-FL2-221-SINK-ETA74	Lead, ppb	1.25	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

Cincinnati Public Schools - Ethel M. Taylor Academy - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
ETA75	11/3/2017	5:42	ETA-FL2-221GIRLSRR-SINK-ETA75	Lead, ppb	<1	Less than detection level
ETA76	11/3/2017	5:43	ETA-FL2-221BOYSRR-SINK-ETA76	Lead, ppb	<1	Less than detection level
ETA77	11/3/2017	5:43	ETA-FL2-221UNIRR-SINK-ETA77	Lead, ppb	<1	Less than detection level
ETA78	11/3/2017	5:45	ETA-FL2-HALLNEAR209-LDF-ETA78	Lead, ppb	<1	Less than detection level
ETA79	11/3/2017	5:45	ETA-FL2-HALLNEAR209-RDF-ETA79	Lead, ppb	<1	Less than detection level
ETA80	11/3/2017	5:47	ETA-FL2-209-SINK-ETA80	Lead, ppb	2.56	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ETA81	11/3/2017	5:49	ETA-FL2-209GIRLSRR-SINK-ETA81	Lead, ppb	<1	Less than detection level
ETA82	11/3/2017	5:49	ETA-FL2-209BOYSRR-SINK-ETA82	Lead, ppb	<1	Less than detection level
ETA83	11/3/2017	5:45	ETA-FL2-209UNIRR-SINK-ETA83	Lead, ppb	<1	Less than detection level
ETA84	11/3/2017	5:50	ETA-FL2-210-SINK-ETA84	Lead, ppb	<1	Less than detection level
ETA85	11/3/2017	5:50	ETA-FL2-210-DF-ETA85	Lead, ppb	<1	Less than detection level
ETA86	11/3/2017	5:50	ETA-FL2-211-SINK-ETA86	Lead, ppb	<1	Less than detection level
ETA87	11/3/2017	5:50	ETA-FL2-211-DF-ETA87	Lead, ppb	<1	Less than detection level
ETA88	11/3/2017	5:51	ETA-FL2-212-SINK-ETA88	Lead, ppb	<1	Less than detection level
ETA89	11/3/2017	5:51	ETA-FL2-212-DF-ETA89	Lead, ppb	<1	Less than detection level
ETA90	11/3/2017	5:52	ETA-FL2-213-SINK-ETA90	Lead, ppb	<1	Less than detection level
ETA91	11/3/2017	5:52	ETA-FL2-213-DF-ETA91	Lead, ppb	<1	Less than detection level
ETA92	11/3/2017	5:55	ETA-FL3-322WORKRM-SINK-ETA92	Lead, ppb	1.05	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ETA93	11/3/2017	5:57	ETA-FL3-321-SINK-ETA93	Lead, ppb	<1	Less than detection level
ETA94	11/3/2017	5:57	ETA-FL3-321-DF-ETA94	Lead, ppb	<1	Less than detection level
ETA95	11/3/2017	5:58	ETA-FL3-320-SINK-ETA95	Lead, ppb	<1	Less than detection level
ETA96	11/3/2017	5:58	ETA-FL3-320-DF-ETA96	Lead, ppb	<1	Less than detection level
ETA97	11/3/2017	5:59	ETA-FL3-319-SINK-ETA97	Lead, ppb	<1	Less than detection level
ETA98	11/3/2017	5:59	ETA-FL3-319-DF-ETA98	Lead, ppb	<1	Less than detection level
ETA99	11/3/2017	6:00	ETA-FL3-318-SINK-ETA99	Lead, ppb	<1	Less than detection level
ETA100	11/3/2017	6:00	ETA-FL3-318-DF-ETA100	Lead, ppb	<1	Less than detection level

Cincinnati Public Schools - Ethel M. Taylor Academy - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
ETA101	11/3/2017	6:00	ETA-FL3-313-SINK-ETA101	Lead, ppb	<1	Less than detection level
ETA102	11/3/2017	6:00	ETA-FL3-313GIRLSRR-SINK-ETA102	Lead, ppb	<1	Less than detection level
ETA103	11/3/2017	6:00	ETA-FL3-313BOYSRR-SINK-ETA103	Lead, ppb	<1	Less than detection level
ETA104	11/3/2017	6:02	ETA-FL3-313UNIRR-SINK-ETA104	Lead, ppb	<1	Less than detection level
ETA105	11/3/2017	6:02	ETA-FL3-HALLNEAR303-LDF-ETA105	Lead, ppb	<1	Less than detection level
ETA106	11/3/2017	6:02	ETA-FL3-HALLNEAR303-RDF-ETA106	Lead, ppb	<1	Less than detection level
ETA107	11/3/2017	6:05	ETA-FL3-308WORKRM-SINK-ETA107	Lead, ppb	1.42	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ETA108	11/3/2017	6:05	ETA-FL3-303-SINK-ETA108	Lead, ppb	3.06	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ETA109	N/A	N/A	ETA-FL3-303-DF-ETA109	Lead, ppb	N/A	There is not a drinking fountain in this room; just a sink. Not a location.
ETA110	11/3/2017	6:09	ETA-FL3-303GIRLSRR-SINK-ETA110	Lead, ppb	<1	Less than detection level
ETA111	11/3/2017	6:09	ETA-FL3-303BOYSRR-SINK-ETA111	Lead, ppb	10.6	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ETA112	11/3/2017	6:09	ETA-FL3-303UNIRR-SINK-ETA112	Lead, ppb	<1	Less than detection level
ETA113	11/3/2017	6:10	ETA-FL3-307-SINK-ETA113	Lead, ppb	<1	Less than detection level
ETA114	11/3/2017	6:10	ETA-FL3-307-DF-ETA114	Lead, ppb	<1	Less than detection level
ETA115	11/3/2017	6:10	ETA-FL3-307RR-SINK-ETA115	Lead, ppb	<1	Less than detection level
ETA116	11/3/2017	6:12	ETA-FL3-312-SINK-ETA116	Lead, ppb	<1	Less than detection level
ETA117	11/3/2017	6:12	ETA-FL3-312-DF-ETA117	Lead, ppb	<1	Less than detection level
ETA118	11/3/2017	6:13	ETA-FL3-311-SINK-ETA118	Lead, ppb	<1	Less than detection level
ETA119	11/3/2017	6:13	ETA-FL3-311-DF-ETA119	Lead, ppb	<1	Less than detection level
ETA120	11/3/2017	6:11	ETA-FL3-310WALLMSINK-LSINK-ETA120	Lead, ppb	1.09	Science Room. Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

Cincinnati Public Schools - Ethel M. Taylor Academy - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
ETA121	11/3/2017	6:11	ETA-FL3-310RWALLMSINK-RSINK-ETA121	Lead, ppb	1.35	Science Room. Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ETA122	11/3/2017	6:12	ETA-FL3-310RWALLRSINK-LSINK-ETA122	Lead, ppb	1.4	Science Room. Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ETA123	11/3/2017	6:12	ETA-FL3-310RWALLRSINK-RSINK-ETA123	Lead, ppb	1.79	Science Room. Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
N/A	N/A	N/A	ETA-FL3-310RWALLLSINK-LSINK	Lead, ppb	N/A	Science Room - Turned Off
N/A	N/A	N/A	ETA-FL3-310RWALLLSINK-RSINK	Lead, ppb	N/A	Science Room - Turned Off
N/A	N/A	N/A	ETA-FL3-310FRONTDESK-SINK	Lead, ppb	N/A	Science Room - Turned Off
N/A	N/A	N/A	ETA-FL3-310LWALLLSINK-LSINK	Lead, ppb	N/A	Science Room - Turned Off
N/A	N/A	N/A	ETA-FL3-310LWALLLSINK-RSINK	Lead, ppb	N/A	Science Room - Turned Off
N/A	N/A	N/A	ETA-FL3-310LWALLMSINK-LSINK	Lead, ppb	N/A	Science Room - Turned Off
N/A	N/A	N/A	ETA-FL3-310LWALLMSINK-RSINK	Lead, ppb	N/A	Science Room - Turned Off
N/A	N/A	N/A	ETA-FL3-310LWALLRSINK-LSINK	Lead, ppb	N/A	Science Room - Turned Off
N/A	N/A	N/A	ETA-FL3-310LWALLRSINK-RSINK	Lead, ppb	N/A	Science Room - Turned Off