



April 23, 2018

Cincinnati Public Schools
Cynthia Eghbalnia
2651 Burnet Avenue
Cincinnati, OH 45219

Evanston

Academy

Dear Cynthia:

Thank you for taking the responsibility seriously to protect the health of the children by voluntarily testing the water in your school for lead!

Attached please find the results of the lead analyses performed for Evanston Academy by the Greater Cincinnati Water Works (GCWW). The following comments speak to the process, samples analyzed and additional steps needed to help ensure the safety of all the students within the school.

School Sampling Process and Results

GCWW and Cincinnati Public Schools (CPS) staff worked together to finalize a sampling plan for the school. The *USEPA 3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance Document (3Ts Guidelines)* is the process and guidelines used for assisting schools with testing for lead.

In December, one hundred, twenty-one (121) samples were collected from drinking fountains, sinks and cooking outlets throughout the school. Multiple sinks within the school were not initially considered for testing, however, key nearby indicators (coffee makers, drinking cups, plates, utensils, etc.) prompted additional locations to be tested in the schools. Including these sampling locations speaks to the proactive approach CPS continues to have towards understanding the water quality within the schools. The results show the following:

- 85 samples (70.24%), below the detection level (<1)
- 33 samples (27.27%), between 1ppb and 5ppb
- 1 sample (0.83%), between 5ppb and 10ppb
- 1 sample (0.83%) between 10ppb and 15ppb
- 1 sample (0.83%) greater than 15ppb.

Ninety-nine percent (99.17%) of the sample results were below the detection level or below the federal action level.

Fifteen parts per billion (ppb) is the federal Lead and Copper Rule action level; desired results are below 15. The federal action level of 15ppb pertains to water utilities and GCWW's review and comments are based on this action level. However, the USEPA 3Ts Guidelines document outlines practices for schools to put in place if samples are greater than 20 ppb.

While we strive to have results less than 15, we recognize that lead is a pervasive environmental contaminant, and no safe blood lead threshold has been identified in children or adults. Therefore, we provide recommendations to further reduce any lead levels discovered in your school.



Next steps


GCWW has reviewed the results from your samples and provides some next-steps comments:

1. Great news! All the drinking fountain locations had results below the detection level. No further action is suggested for these locations.
2. There was one high lead level, boy's locker room sink (EVA-FL1-1080BOYSLOCK-RSINK-EVA41). Based on the sample name, it is assumed this is not a drinking water or cooking outlet. Although the location is not used for these purposes, consider immediate remedies such as taking the sample location out of service until a more defined plan can be created OR post a sign above the location limiting the purpose of this sink ('hand washing only', 'work sink only'). Posting a sign will deter students and staff from potentially using the sink to fill a water bottle, etc. For more information, refer to the 3Ts Guidelines that suggest shutting off or disconnecting problem outlets until the problem is resolved. After removing the location from operation, start with
 - a. Removing and cleaning the aerator. Particles may be trapped on the aerator and contributing to the lead level. Consider resampling.
 - b. Flush the line and resample. If the resample shows a reduced lead level, then the infrequent use at this location may be contributing to the lead level. At that time, posting the sign may be helpful in deterring drinking water use.
3. A few samples in the café and kitchen area had lead detections. All three (EVA-KIT-DISHRM3TUB-RSINK-EVA87, EVA-KIT-NEAR1091-HANDSINK-EVA91, EVA-KIT-NEAROVEN/SERVE-HANDSINK-EVA93) locations were sinks. If these locations are used for food and drink preparation, flush the line (let the water run) before use. No further action is suggested.
4. Almost all sample locations in the locker rooms had lead detections, but below the federal action level. Infrequent use may be the cause of these lead detections. Lead is not an issue for body contact such as bathing, showering, and washing hands. Posting signs to limit use may deter students and staff from using these locations to fill a water bottle, etc.
5. Several other sinks had lead detections. Based on the names, these are not used for drinking water or cooking purposes.
 - a. Lead is not an issue for body contact such as bathing, showering, and washing hands.
 - b. Cleaning the aerators at these locations may lower the lead levels.
 - c. If the locations with lead detections are not used on a regular basis, then the infrequent use may be contributing to the lead detections.
6. Review how water is being used within your facility. Again, if water is not used on a regular basis at some of these locations, the infrequent use at the outlet may be contributing to the lead detections. Signage at some locations may be helpful (hand washing only, science class purposes only-no drinking, etc.). However, some lead detections were minimal; signage may not be needed at these locations.
7. If it hasn't occurred already, a robust communications plan is suggested. Communications plan steps are outlined in the 3Ts Guidelines. This plan will inform the school community of the sampling work the school has done to date and the steps the school will take to correct any issues discovered. GCWW employees can assist with this plan and are available to attend any school meetings to help explain our lead program, the sample results and our partnership with your school. Suggestions for language and a letter template can be provided if needed. Sampling results will be posted on the GCWW lead.mygcww.org website with other school sampling results.

Greater Cincinnati Water Works takes the presence of lead service lines and the removal of those service lines in our system very seriously. In addition, minimizing the exposure of lead within our preschools, schools, and daycares is one of our highest priorities under our Enhanced Lead Program. Please contact Jim Nelson at 591-6869 if you have any questions.

Thanks again for your partnership with Greater Cincinnati Water Works and your work to further understand the water quality within your building. Your extra steps and care to keep the children in our community safe are appreciated!

Sincerely,

A handwritten signature in black ink that reads "Cathy B. Bailey". The signature is written in a cursive style with a large initial 'C' and a long, sweeping tail on the 'y'.

Cathy B. Bailey
Director/Greater Cincinnati Water Works

Cc: Dr. Marilyn Crumpton, Cincinnati Health Department
Dr. Camille Jones, Cincinnati Health Department
Chuck DeJonckheere, Hamilton County Public Health
Patrick Duhaney, City of Cincinnati
Verna Arnette, Greater Cincinnati Water Works
Jeff Swertfeger, Greater Cincinnati Water Works
Jason DeLaet, Greater Cincinnati Water Works
James Nelson, Greater Cincinnati Water Works

Cincinnati Public Schools - Evanston Academy - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
EVA1	12/1/2017	5:04:00	EVA-FL1-1010STAFFWORKRRM-SINK-EVA1	Lead, PPB	1.67	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
EVA2	12/1/2017	5:05:00	EVA-FL1-1011HEALTH-SINK-EVA2	Lead, PPB	1.75	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
EVA3	12/1/2017	5:06:00	EVA-FL1-1011HEALTH-DF-EVA3	Lead, PPB	<1	Less than detection level
EVA4	12/1/2017	5:07:00	EVA-FL1-1011HEALTHRR-SINK-EVA4	Lead, PPB	<1	Less than detection level
EVA5	12/1/2017	5:08:00	EVA-FL1-1014UNIRR-SINK-EVA5	Lead, PPB	1.35	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
EVA6	12/1/2017	5:09:00	EVA-FL1-1015UNIRR-SINK-EVA6	Lead, PPB	<1	Less than detection level
EVA7	12/1/2017	5:11:00	EVA-FL1-1018-SINK-EVA7	Lead, PPB	1.2	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
EVA8	12/1/2017	5:12:00	EVA-FL1-1018-DF-EVA8	Lead, PPB	<1	Less than detection level
EVA9	12/1/2017	5:13:00	EVA-FL1-1018RR-SINK-EVA9	Lead, PPB	<1	Less than detection level
EVA10	12/1/2017	5:16:00	EVA-FL1-1020-SINK-EVA10	Lead, PPB	1.09	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
EVA11	12/1/2017	5:17:00	EVA-FL1-1020-DF-EVA11	Lead, PPB	<1	Less than detection level
EVA12	12/1/2017	5:18:00	EVA-FL1-1020RR-SINK-EVA12	Lead, PPB	<1	Less than detection level
EVA13	12/1/2017	5:19:00	EVA-FL1-1022-SINK-EVA13	Lead, PPB	1.15	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
EVA14	12/1/2017	5:20:00	EVA-FL1-1022-DF-EVA14	Lead, PPB	<1	Less than detection level
EVA15	12/1/2017	5:21:00	EVA-FL1-1022RR-SINK-EVA15	Lead, PPB	<1	Less than detection level
EVA16	12/1/2017	5:22:00	EVA-FL1-1024-SINK-EVA16	Lead, PPB	<1	Less than detection level
EVA17	12/1/2017	5:24:00	EVA-FL1-1024-DF-EVA17	Lead, PPB	<1	Less than detection level
EVA18	12/1/2017	5:23:00	EVA-FL1-1024RR-SINK-EVA18	Lead, PPB	<1	Less than detection level
EVA19	12/1/2017	5:25:00	EVA-FL1-ELA1017-SINK-EVA19	Lead, PPB	<1	Less than detection level
EVA20	12/1/2017	5:26:00	EVA-FL1-ELA1017-DF-EVA20	Lead, PPB	<1	Less than detection level

Cincinnati Public Schools - Evanston Academy - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
EVA21	12/1/2017	5:27:00	EVA-FL1-1026-SINK-EVA21	Lead, PPB	1.15	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
EVA22	12/1/2017	5:28:00	EVA-FL1-1026-DF-EVA22	Lead, PPB	<1	Less than detection level
EVA23	12/1/2017	5:30:00	EVA-FL1-1027RR-SINK-EVA23	Lead, PPB	<1	Less than detection level
EVA24	12/1/2017	5:31:00	EVA-FL1-1028-SINK-EVA24	Lead, PPB	1.73	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
EVA25	12/1/2017	5:32:00	EVA-FL1-1028-DF-EVA25	Lead, PPB	<1	Less than detection level
EVA26	12/1/2017	5:34:00	EVA-FL1-1032-LSINK-EVA26	Lead, PPB	2.31	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
EVA27	12/1/2017	5:35:00	EVA-FL1-1032-RSINK-EVA27	Lead, PPB	<1	Less than detection level
EVA28	12/1/2017	5:36:00	EVA-FL1-1034ART-LSINK-EVA28	Lead, PPB	3.97	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
EVA29	12/1/2017	5:37:00	EVA-FL1-1034ART-MSINK-EVA29	Lead, PPB	2.33	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
EVA30	12/1/2017	5:38:00	EVA-FL1-1034ART-RSINK-EVA30	Lead, PPB	1.68	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
EVA31	12/1/2017	5:40:00	EVA-FL1-1037MUSIC-SINK-EVA31	Lead, PPB	<1	Less than detection level
EVA32	12/1/2017	5:41:00	EVA-FL1-1037MUSIC-DF-EVA32	Lead, PPB	<1	Less than detection level
EVA33	12/1/2017	5:44:00	EVA-FL1-1039GIRLSRR-LSINK-EVA33	Lead, PPB	<1	Less than detection level
EVA34	12/1/2017	5:45:00	EVA-FL1-1039GIRLSRR-MSINK-EVA34	Lead, PPB	<1	Less than detection level
EVA35	12/1/2017	5:46:00	EVA-FL1-1039GIRLSRR-RSINK-EVA35	Lead, PPB	<1	Less than detection level
EVA36	12/1/2017	5:48:00	EVA-FL1-1040BOYSRR-LSINK-EVA36	Lead, PPB	<1	Less than detection level
EVA37	12/1/2017	5:49:00	EVA-FL1-1040BOYSRR-MSINK-EVA37	Lead, PPB	<1	Less than detection level
EVA38	12/1/2017	5:50:00	EVA-FL1-1040BOYSRR-RSINK-EVA38	Lead, PPB	<1	Less than detection level

Cincinnati Public Schools - Evanston Academy - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
EVA39	12/1/2017	5:52:00	EVA-FL1-1080BOYSLOCK-LSINK-EVA39	Lead, PPB	4.81	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
EVA40	12/1/2017	5:53:00	EVA-FL1-1080BOYSLOCK-MSINK-EVA40	Lead, PPB	5.72	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
EVA41	12/1/2017	5:54:00	EVA-FL1-1080BOYSLOCK-RSINK-EVA41	Lead, PPB	31.1	Above 15ppb federal action level and the 20ppb trigger level to take action as explained in the USEPA 3Ts Guidelines for schools. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
EVA42	12/1/2017	5:56:00	EVA-FL1-1080BOYSLOCK-DF-EVA42	Lead, PPB	<1	Less than detection level
EVA43	12/1/2017	5:58:00	EVA-FL1-1076PEOFFRR-SINK-EVA43	Lead, PPB	2.43	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
EVA44	12/1/2017	6:00:00	EVA-FL1-1074GIRLSLOCK-LSINK-EVA44	Lead, PPB	4.98	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
EVA45	12/1/2017	6:01:00	EVA-FL1-1074GIRLSLOCK-MSINK-EVA45	Lead, PPB	1.1	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
EVA46	12/1/2017	6:02:00	EVA-FL1-1074GIRLSLOCK-RSINK-EVA46	Lead, PPB	4.51	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
EVA47	12/1/2017	6:03:00	EVA-FL1-1074GIRLSLOCK-DF-EVA47	Lead, PPB	<1	Less than detection level
EVA48	12/1/2017	5:17:00	EVA-FL1-1070STAFFLOUNGE-LSINK-EVA48	Lead, PPB	<1	Less than detection level
EVA49	12/1/2017	5:17:00	EVA-FL1-1070STAFFLOUNGE-RSINK-EVA49	Lead, PPB	<1	Less than detection level
EVA50	12/1/2017	5:17:00	EVA-FL1-1070STAFFLOUNGERR-SINK-EVA50	Lead, PPB	<1	Less than detection level
EVA51	12/1/2017	5:21:00	EVA-FL1-1046-SINK-EVA51	Lead, PPB	<1	Less than detection level
EVA52	12/1/2017	5:21:00	EVA-FL1-1046-DF-EVA52	Lead, PPB	<1	Less than detection level
EVA53	12/1/2017	5:25:00	EVA-FL1-1047-SINK-EVA53	Lead, PPB	<1	Less than detection level

Cincinnati Public Schools - Evanston Academy - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
EVA54	12/1/2017	5:25:00	EVA-FL1-1047-DF-EVA54	Lead, PPB	<1	Less than detection level
EVA55	12/1/2017	5:26:00	EVA-FL1-1048-SINK-EVA55	Lead, PPB	1.05	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
EVA56	12/1/2017	5:26:00	EVA-FL1-1048-DF-EVA56	Lead, PPB	<1	Less than detection level
EVA57	12/1/2017	5:27:00	EVA-FL1-HALLNEAR1048-LDF-EVA57	Lead, PPB	<1	Less than detection level
EVA58	12/1/2017	5:27:00	EVA-FL1-HALLNEAR1048-RDF-EVA58	Lead, PPB	<1	Less than detection level
EVA59	12/1/2017	5:29:00	EVA-FL1-1068GIRLSRR-SINK-EVA59	Lead, PPB	<1	Less than detection level
EVA60	12/1/2017	5:29:00	EVA-FL1-1067BOYSRR-SINK-EVA60	Lead, PPB	1.03	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
EVA61	12/1/2017	5:30:00	EVA-FL1-1049-SINK-EVA61	Lead, PPB	<1	Less than detection level
EVA62	12/1/2017	5:30:00	EVA-FL1-1049-DF-EVA62	Lead, PPB	<1	Less than detection level
EVA63	12/1/2017	5:31:00	EVA-FL1-1050-SINK-EVA63	Lead, PPB	1.32	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
EVA64	12/1/2017	5:31:00	EVA-FL1-1050-DF-EVA64	Lead, PPB	<1	Less than detection level
EVA65	12/1/2017	5:33:00	EVA-FL1-1061BOYSRR-SINK-EVA65	Lead, PPB	<1	Less than detection level
EVA66	12/1/2017	5:33:00	EVA-FL1-1060GIRLSRR-SINK-EVA66	Lead, PPB	<1	Less than detection level
EVA67	12/1/2017	5:35:00	EVA-FL1-1051-SINK-EVA67	Lead, PPB	4.45	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
EVA68	12/1/2017	5:35:00	EVA-FL1-1051-DF-EVA68	Lead, PPB	<1	Less than detection level
EVA69	12/1/2017	5:38:00	EVA-FL1-1052-SINK-EVA69	Lead, PPB	11.1	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
EVA70	12/1/2017	5:38:00	EVA-FL1-1052-DF-EVA70	Lead, PPB	<1	Less than detection level
EVA71	12/1/2017	5:39:00	EVA-FL1-1053-SINK-EVA71	Lead, PPB	2.73	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
EVA72	12/1/2017	5:39:00	EVA-FL1-1053-DF-EVA72	Lead, PPB	<1	Less than detection level
EVA73	12/1/2017	5:40:00	EVA-FL1-1054-SINK-EVA73	Lead, PPB	<1	Less than detection level

Cincinnati Public Schools - Evanston Academy - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
EVA74	12/1/2017	5:40:00	EVA-FL1-1054-DF-EVA74	Lead, PPB	<1	Less than detection level
EVA75	12/1/2017	5:46:00	EVA-FL1-1104GIRLSRR-SINK-EVA75	Lead, PPB	<1	Less than detection level
EVA76	12/1/2017	5:46:00	EVA-FL1-1105BOYSRR-SINK-EVA76	Lead, PPB	<1	Less than detection level
EVA77	12/1/2017	5:46:00	EVA-FL1-1106STAFFRR-SINK-EVA77	Lead, PPB	<1	Less than detection level
EVA78	12/1/2017	5:47:00	EVA-FL1-1102-SINK-EVA78	Lead, PPB	<1	Less than detection level
EVA79	12/1/2017	5:47:00	EVA-FL1-1102-DF-EVA79	Lead, PPB	<1	Less than detection level
EVA80	12/1/2017	5:50:00	EVA-FL1-1103-SINK-EVA80	Lead, PPB	1.42	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
EVA81	12/1/2017	5:50:00	EVA-FL1-1103-DF-EVA81	Lead, PPB	<1	Less than detection level
EVA82	12/1/2017	5:04:00	EVA-FL1-CAFE-LCOMBODF-EVA82	Lead, PPB	<1	Less than detection level
EVA83	12/1/2017	5:04:00	EVA-FL1-CAFE-LCOMBODBF-EVA83	Lead, PPB	<1	Less than detection level
EVA84	12/1/2017	5:04:00	EVA-FL1-CAFE-RDF-EVA84	Lead, PPB	<1	Less than detection level
EVA85	12/1/2017	5:06:00	EVA-KIT-DISHRM-HANDSINK-EVA85	Lead, PPB	<1	Less than detection level
EVA86	12/1/2017	5:06:00	EVA-KIT-DISHRM3TUB-LSINK-EVA86	Lead, PPB	<1	Less than detection level
EVA87	12/1/2017	5:06:00	EVA-KIT-DISHRM3TUB-RSINK-EVA87	Lead, PPB	1.3	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
EVA88	12/1/2017	5:09:00	EVA-KIT-2TUBISLAND-SINK-EVA88	Lead, PPB	<1	Less than detection level
EVA89	12/1/2017	5:09:00	EVA-KIT-STOCKPOT-LFILLER-EVA89	Lead, PPB	<1	Less than detection level
EVA90	12/1/2017	5:09:00	EVA-KIT-STOCKPOT-RFILLER-EVA90	Lead, PPB	<1	Less than detection level
EVA91	12/1/2017	5:10:00	EVA-KIT-NEAR1091-HANDSINK-EVA91	Lead, PPB	1.09	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
EVA92	12/1/2017	5:11:00	EVA-KIT-1093STAFFRR-SINK-EVA92	Lead, PPB	<1	Less than detection level
EVA93	12/1/2017	5:12:00	EVA-KIT-NEAROVEN/SERVE-HANDSINK-EVA93	Lead, PPB	3.89	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
EVA94	12/1/2017	5:53:00	EVA-FL2-2003-SINK-EVA94	Lead, PPB	<1	Less than detection level
EVA95	12/1/2017	5:55:00	EVA-FL2-2010-SINK-EVA95	Lead, PPB	2.17	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
EVA96	12/1/2017	5:55:00	EVA-FL2-2010-DF-EVA96	Lead, PPB	<1	Less than detection level

Cincinnati Public Schools - Evanston Academy - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
EVA97	12/1/2017	5:58:00	EVA-FL2-2011-SINK-EVA97	Lead, PPB	<1	Less than detection level
EVA98	12/1/2017	5:58:00	EVA-FL2-2011-DF-EVA98	Lead, PPB	<1	Less than detection level
EVA99	12/1/2017	5:59:00	EVA-FL2-HALLNEAR2011-LDF-EVA99	Lead, PPB	<1	Less than detection level
EVA100	12/1/2017	5:59:00	EVA-FL2-HALLNEAR2011-RDF-EVA100	Lead, PPB	<1	Less than detection level
EVA101	12/1/2017	5:59:00	EVA-FL2-2012FRONTDESK-SINK-EVA101	Lead, PPB	3.98	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
EVA102	12/1/2017	6:04:00	EVA-FL2-2012LWALL-FLSINK-EVA102	Lead, PPB	<1	Less than detection level
EVA103	12/1/2017	6:04:00	EVA-FL2-2012LWALL-LSINK-EVA103	Lead, PPB	<1	Less than detection level
EVA104	12/1/2017	6:04:00	EVA-FL2-2012LWALL-RSINK-EVA104	Lead, PPB	1.98	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
EVA105	12/1/2017	6:04:00	EVA-FL2-2012LWALL-FRSINK-EVA105	Lead, PPB	<1	Less than detection level
EVA106	12/1/2017	6:05:00	EVA-FL2-2013-SINK-EVA106	Lead, PPB	1.79	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
EVA107	12/1/2017	6:05:00	EVA-FL2-2013-DF-EVA107	Lead, PPB	<1	Less than detection level
EVA108	12/1/2017	6:05:00	EVA-FL2-2014-SINK-EVA108	Lead, PPB	<1	Less than detection level
EVA109	12/1/2017	6:05:00	EVA-FL2-2014-DF-EVA109	Lead, PPB	<1	Less than detection level
EVA110	12/1/2017	6:06:00	EVA-FL2-2015-SINK-EVA110	Lead, PPB	<1	Less than detection level
EVA111	12/1/2017	6:06:00	EVA-FL2-2015-DF-EVA111	Lead, PPB	<1	Less than detection level
EVA112	12/1/2017	6:07:00	EVA-FL2-2016-SINK-EVA112	Lead, PPB	1.98	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
EVA113	12/1/2017	6:07:00	EVA-FL2-2016-DF-EVA113	Lead, PPB	<1	Less than detection level
EVA114	12/1/2017	6:08:00	EVA-FL2-2017-SINK-EVA114	Lead, PPB	<1	Less than detection level
EVA115	12/1/2017	6:08:00	EVA-FL2-2017-DF-EVA115	Lead, PPB	<1	Less than detection level
EVA116	12/1/2017	6:09:00	EVA-FL2-2021STAFFRR-SINK-EVA116	Lead, PPB	1.58	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

Cincinnati Public Schools - Evanston Academy - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
EVA117	12/1/2017	6:09:00	EVA-FL2-2022BOYSRR-SINK-EVA117	Lead, PPB	1.53	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
EVA118	12/1/2017	6:09:00	EVA-FL2-2023GIRLSRR-SINK-EVA118	Lead, PPB	<1	Less than detection level
EVA119	12/1/2017	6:12:00	EVA-FL2-2026-SINK-EVA119	Lead, PPB	<1	Less than detection level
EVA120	12/1/2017	6:13:00	EVA-FL2-2028BOYSRR-SINK-EVA120	Lead, PPB	<1	Less than detection level
EVA121	12/1/2017	6:13:00	EVA-FL2-2029GIRLSRR-SINK-EVA121	Lead, PPB	<1	Less than detection level