



May 10, 2018

Cincinnati Public Schools  
Cynthia Eghbalnia  
2651 Burnet Avenue  
Cincinnati, OH 45219

**Fairview-Clifton  
German Language  
School**

Dear Cynthia:

Thank you for taking the responsibility seriously to protect the health of the children by voluntarily testing the water in your school for lead!

Attached please find the results of the lead analyses performed for Fairview-Clifton German Language School by the Greater Cincinnati Water Works (GCWW). The following comments speak to the process, samples analyzed and additional steps needed to help ensure the safety of all the students within the school.

**School Sampling Process and Results**

GCWW and Cincinnati Public Schools (CPS) staff worked together to finalize a sampling plan for the school. The *USEPA 3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance Document (3Ts Guidelines)* is the process and guidelines used for assisting schools with testing for lead.

In January, one hundred, fifty-three (153) samples were collected from drinking fountains, sinks and cooking outlets throughout the school. Multiple sinks within the schools were not initially considered for testing, however, key nearby indicators (coffee makers, drinking cups, plates, utensils, etc.) prompted additional locations to be tested in the schools. Including these sampling locations speaks to the proactive approach CPS continues to have towards understanding the water quality within the schools. The results show the following:

- 131 samples (84.52%), below the detection level (<1)
- 13 samples (8.39%), between 1ppb and 5ppb
- 2 samples (1.29%), between 5ppb and 10ppb
- 3 samples (1.93%), between 10ppb and 15ppb
- 6 samples (3.87%), greater than 15ppb.

Ninety-six percent (96%) of the results were below the detection level or below the federal action level.

Fifteen parts per billion (ppb) is the federal Lead and Copper Rule action level; desired results are below 15. The federal action level of 15ppb pertains to water utilities and GCWW's review and comments are based on this action level. However, the USEPA 3Ts Guidelines document outlines practices for schools to put in place if samples are greater than 20 ppb.

While we strive to have results less than 15, we recognize that lead is a pervasive environmental contaminant, and no safe blood lead threshold has been identified in children or adults. Therefore, we provide recommendations to further reduce any lead levels discovered in your school.



## Next steps

GCWW has reviewed the results from your samples and provides some next-steps comments.

1. Four drinking fountains had lead detections:
  - FCG-FL1-1104-DF-FCG53, 1.62ppb
  - FCG-FL1-1107-DF-FCG62, 17ppb
  - FCG-FL2-2209-DF-FCG104, 2.01ppb
  - FCG-FL2-2210-DF-FCG106, 1.37ppb
  - FCG-FL2-2213-DF-FCG110, 8.23ppb.

For the drinking fountain with a lead detection greater than 15ppb, consider an immediate remedy such as taking the sample location out of service until a more defined plan can be created or post a sign limiting the use at this location. Refer to the USEPA 3Ts Guidelines for more information and suggestions on signage. For the other locations, to lower the lead levels, flush the line (let the water run) before use.

2. Five sinks had results greater than 15ppb:
  - FCG-FL1-1112-SINK-FCG78, 40.4ppb
  - FCG-FL2-2202-SINK-FCG86, 39.3ppb
  - FCG-FL2-2210-SINK-FCG105, 58.2ppb
  - FCG-FL2-2213-SINK-FCG109, 54.8ppb
  - FCG-FL3-3305-SINK-FCG127, 17.1ppb.

All of these locations are sinks and it is assumed by the names, they are not used as drinking water or cooking outlets. However, consider an immediate remedy such as taking the sample locations out of service until a more defined plan can be created or post a sign limiting the use at these locations. Refer to the USEPA 3Ts Guidelines for more information and suggestions on signage. After the locations are out of service, work to reduce the lead levels by first removing and cleaning the aerators as particles may be trapped on the aerator and contributing to the lead detections. Consider resampling after the cleaning.


3. Two samples in the kitchen had low lead detections. If these locations are used for food and drink preparation, flush the line (let the water run) before use.
4. Several other sinks had lead detections. Based on the names, these are not used for drinking water or cooking purposes.
  - a. Lead is not an issue for body contact such as bathing, showering, and washing hands.
  - a. To lower the lead levels, again, consider removing and cleaning the aerator. Particles may be trapped on the aerator and contributing to the lead level.
  - b. If the locations with lead detections are not used on a regular basis, then the infrequent use may be contributing to the lead detections.
5. Review how water is being used within your facility. Again, if water is not used on a regular basis at some of these locations, again, the infrequent use at the outlet may be contributing to the lead detections. Signage at these locations may be helpful (hand washing only, science class purposes only-no drinking, etc.).
6. If it hasn't occurred already, a robust communications plan is suggested. Communications plan steps are outlined in the 3Ts Guidelines. This plan will inform the school community of the sampling work the school has done to date and the steps the school will take to correct any issues discovered. GCWW employees can assist with this plan and are available to attend any school meetings to help explain our lead program, the sample results and our partnership with your school. Suggestions for language and a letter template can be provided if needed. Sampling results will be posted on the GCWW lead.mygcww.org website with other school sampling results.

Greater Cincinnati Water Works takes the presence of lead service lines and the removal of those service lines in our system very seriously. In addition, minimizing the exposure of lead within our preschools, schools, and

daycares is one of our highest priorities under our Enhanced Lead Program. Please contact Jim Nelson at 591-6869 if you have any questions.

Thanks again for your partnership with Greater Cincinnati Water Works and your work to further understand the water quality within your building. Your extra steps and care to keep the children in our community safe are appreciated!

Sincerely,

A handwritten signature in black ink that reads "Cathy B. Bailey". The signature is written in a cursive style with a large initial 'C'.

Cathy B. Bailey  
Director/Greater Cincinnati Water Works

Cc: Dr. Marilyn Crumpton, Cincinnati Health Department  
Dr. Camille Jones, Cincinnati Health Department  
Chuck DeJonckheere, Hamilton County Public Health  
Patrick Duhaney, City of Cincinnati  
Verna Arnette, Greater Cincinnati Water Works  
Jeff Swertfeger, Greater Cincinnati Water Works  
Jason DeLaet, Greater Cincinnati Water Works  
James Nelson, Greater Cincinnati Water Works

### Cincinnati Public Schools - Fairview-Clifton German Language School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
FCG1	12/14/2017	5:33	FCG-FL1-1011OFF-SINK-FCG1	Lead, ppb	<1	Less than detection level
FCG2	12/14/2017	5:37	FCG-FL1-1006STAFFRR-SINK-FCG2	Lead, ppb	<1	Less than detection level
FCG3	12/14/2017	5:37	FCG-FL1-1004WKRM-SINK-FCG3	Lead, ppb	<1	Less than detection level
FCG4	12/14/2017	5:38	FCG-FL1-1005HEALTH-SINK-FCG4	Lead, ppb	<1	Less than detection level
FCG5	12/14/2017	5:38	FCG-FL1-1008LAUNDRY-IM-FCG5	Lead, ppb	<1	Less than detection level
FCG6	12/14/2017	5:39	FCG-FL1-1007RR-SINK-FCG6	Lead, ppb	<1	Less than detection level
FCG7	12/14/2017	5:40	FCG-FL1-CAFE-COMBOBF-FCG7	Lead, ppb	<1	Less than detection level
FCG8	12/14/2017	5:40	FCG-FL1-CAFE-COMBODF-FCG8	Lead, ppb	<1	Less than detection level
FCG9	12/14/2017	5:42	FCG-FL1-1301DISHRM-HANDSINK-FCG9	Lead, ppb	<1	Less than detection level
FCG10	12/14/2017	5:42	FCG-FL1-1301DISHRM3TUB-LSINK-FCG10	Lead, ppb	<1	Less than detection level
FCG11	12/14/2017	5:42	FCG-FL1-1301DISHRM3TUB-RSINK-FCG11	Lead, ppb	13.1	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
FCG12	12/14/2017	5:45	FCG-FL1-1304STAFFRR-SINK-FCG12	Lead, ppb	<1	Less than detection level
FCG13	12/14/2017	5:45	FCG-FL1-KITNEAROVEN-HANDSINK-FCG13	Lead, ppb	<1	Less than detection level
FCG14	12/14/2017	5:46	FCG-FL1-KITSTOCKPOT-LFILLER-FCG14	Lead, ppb	1.94	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
FCG15	12/14/2017	5:46	FCG-FL1-KITSTOCKPOT-RFILLER-FCG15	Lead, ppb	<1	Less than detection level
FCG16	12/14/2017	5:46	FCG-FL1-KITNEARCOOL-HANDSINK-FCG16	Lead, ppb	<1	Less than detection level
FCG17	12/14/2017	5:47	FCG-FL1-KIT1TUB-SINK-FCG17	Lead, ppb	1.9	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
FCG18	12/14/2017	5:47	FCG-FL1-KIT2TUB-SINK-FCG18	Lead, ppb	<1	Less than detection level
FCG19	12/14/2017	5:47	FCG-FL1-1311-SINK-FCG19	Lead, ppb	<1	Less than detection level
FCG20	12/14/2017	5:48	FCG-FL1-HALLNEARGYM-LDF-FCG20	Lead, ppb	<1	Less than detection level
FCG21	12/14/2017	5:40	FCG-FL1-HALLNEARGYM-RDF-FCG21	Lead, ppb	<1	Less than detection level
FCG22	12/14/2017	5:53	FCG-FL1-1327PEOFFRR-SINK-FCG22	Lead, ppb	<1	Less than detection level
FCG23	12/14/2017	5:53	FCG-FL1-1326GIRLSLOCK-LSINK-FCG23	Lead, ppb	<1	Less than detection level
FCG24	12/14/2017	5:53	FCG-FL1-1326GIRLSLOCK-MSINK-FCG24	Lead, ppb	<1	Less than detection level

### Cincinnati Public Schools - Fairview-Clifton German Language School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
FCG25	12/14/2017	5:53	FCG-FL1-1326GIRLSLOCK-RSINK-FCG25	Lead, ppb	<1	Less than detection level
FCG26	12/14/2017	5:54	FCG-FL1-1323BOYSLOCK-LSINK-FCG26	Lead, ppb	<1	Less than detection level
FCG27	12/14/2017	5:54	FCG-FL1-1323BOYSLOCK-MSINK-FCG27	Lead, ppb	<1	Less than detection level
FCG28	12/14/2017	5:54	FCG-FL1-1323BOYSLOCK-RSINK-FCG28	Lead, ppb	<1	Less than detection level
FCG29	12/14/2017	5:56	FCG-FL1-1212ART-LSINK-FCG29	Lead, ppb	<1	Less than detection level
FCG30	12/14/2017	5:56	FCG-FL1-1212ART-MSINK-FCG30	Lead, ppb	<1	Less than detection level
FCG31	12/14/2017	5:56	FCG-FL1-1212ART-RSINK-FCG31	Lead, ppb	<1	Less than detection level
FCG32	12/14/2017	5:58	FCG-FL1-1210MUSIC-SINK-FCG32	Lead, ppb	<1	Less than detection level
FCG33	12/14/2017	5:58	FCG-FL1-1210MUSIC-DF-FCG33	Lead, ppb	<1	Less than detection level
FCG34	12/14/2017	6:03	FCG-FL1-1208GIRLSRR-FLSINK-FCG34	Lead, ppb	<1	Less than detection level
FCG35	12/14/2017	6:03	FCG-FL1-1208GIRLSRR-LSINK-FCG35	Lead, ppb	<1	Less than detection level
FCG36	12/14/2017	6:03	FCG-FL1-1208GIRLSRR-RSINK-FCG36	Lead, ppb	<1	Less than detection level
FCG37	12/14/2017	6:03	FCG-FL1-1208GIRLSRR-FRSINK-FCG37	Lead, ppb	<1	Less than detection level
FCG38	12/14/2017	6:05	FCG-FL1-1207BOYSRR-FLSINK-FCG38	Lead, ppb	<1	Less than detection level
FCG39	12/14/2017	6:05	FCG-FL1-1207BOYSRR-LSINK-FCG39	Lead, ppb	<1	Less than detection level
FCG40	12/14/2017	6:05	FCG-FL1-1207BOYSRR-RSINK-FCG40	Lead, ppb	<1	Less than detection level
FCG41	12/14/2017	6:05	FCG-FL1-1207BOYSRR-FRSINK-FCG41	Lead, ppb	<1	Less than detection level
FCG42	12/14/2017	6:07	FCG-FL1-1203LIBRARYWKRM-SINK-FCG42	Lead, ppb	<1	Less than detection level
FCG43	12/14/2017	6:08	FCG-FL1-1101-SINK-FCG43	Lead, ppb	1.6	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
FCG44	12/14/2017	6:08	FCG-FL1-1101-DF-FCG44	Lead, ppb	<1	Less than detection level
FCG45	12/14/2017	6:08	FCG-FL1-1101RR-SINK-FCG45	Lead, ppb	<1	Less than detection level
FCG46	12/14/2017	6:09	FCG-FL1-1102-SINK-FCG46	Lead, ppb	<1	Less than detection level
FCG47	12/14/2017	6:09	FCG-FL1-1102-DF-FCG47	Lead, ppb	<1	Less than detection level
FCG48	12/14/2017	6:09	FCG-FL1-1102RR-SINK-FCG48	Lead, ppb	<1	Less than detection level
FCG49	12/14/2017	6:14	FCG-FL1-1103-SINK-FCG49	Lead, ppb	<1	Less than detection level
FCG50	12/14/2017	6:14	FCG-FL1-1103-DF-FCG50	Lead, ppb	<1	Less than detection level
FCG51	12/14/2017	6:14	FCG-FL1-1103RR-SINK-FCG51	Lead, ppb	<1	Less than detection level
FCG52	12/14/2017	6:15	FCG-FL1-1104-SINK-FCG52	Lead, ppb	<1	Less than detection level

**Cincinnati Public Schools - Fairview-Clifton German Language School - Lead Testing Results**

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
FCG53	12/14/2017	6:15	FCG-FL1-1104-DF-FCG53	Lead, ppb	1.62	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
FCG54	12/14/2017	6:15	FCG-FL1-1104RR-SINK-FCG54	Lead, ppb	<1	Less than detection level
FCG55	12/14/2017	6:17	FCG-FL1-1105-SINK-FCG55	Lead, ppb	<1	Less than detection level
FCG56	12/14/2017	6:17	FCG-FL1-1105-DF-FCG56	Lead, ppb	<1	Less than detection level
FCG57	12/14/2017	6:17	FCG-FL1-1105RR-SINK-FCG57	Lead, ppb	<1	Less than detection level
FCG58	12/14/2017	6:21	FCG-FL1-1106-SINK-FCG58	Lead, ppb	11.6	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
FCG59	12/14/2017	6:21	FCG-FL1-1106-DF-FCG59	Lead, ppb	<1	Less than detection level
FCG60	12/14/2017	6:21	FCG-FL1-1106RR-SINK-FCG60	Lead, ppb	<1	Less than detection level
FCG61	12/14/2017	6:23	FCG-FL1-1107-SINK-FCG61	Lead, ppb	1.74	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
FCG62	12/14/2017	6:23	FCG-FL1-1107-DF-FCG62	Lead, ppb	17	Above 15ppb federal action level. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
FCG63	12/14/2017	6:23	FCG-FL1-1107RR-SINK-FCG63	Lead, ppb	<1	Less than detection level
FCG64	12/14/2017	6:24	FCG-FL1-HALL1118RR-SINK-FCG64	Lead, ppb	<1	Less than detection level
FCG65	12/14/2017	6:24	FCG-FL1-HALL1119RR-SINK-FCG65	Lead, ppb	<1	Less than detection level
FCG66	12/14/2017	6:25	FCG-FL1-1108-SINK-FCG66	Lead, ppb	<1	Less than detection level
FCG67	12/14/2017	6:25	FCG-FL1-1108-DF-FCG67	Lead, ppb	<1	Less than detection level
FCG68	12/14/2017	6:26	FCG-FL1-1109-SINK-FCG68	Lead, ppb	<1	Less than detection level
FCG69	12/14/2017	6:26	FCG-FL1-1109-DF-FCG69	Lead, ppb	<1	Less than detection level
FCG70	12/14/2017	6:27	FCG-FL1-1110-SINK-FCG70	Lead, ppb	<1	Less than detection level
FCG71	12/14/2017	6:27	FCG-FL1-1110-DF-FCG71	Lead, ppb	<1	Less than detection level
FCG72	12/14/2017	6:28	FCG-FL1-1114-SINK-FCG72	Lead, ppb	<1	Less than detection level

**Cincinnati Public Schools - Fairview-Clifton German Language School - Lead Testing Results**

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
FCG73	12/14/2017	6:28	FCG-FL1-1114-DF-FCG73	Lead, ppb	<1	Less than detection level
FCG74	12/14/2017	6:29	FCG-FL1-ELA1113-SINK-FCG74	Lead, ppb	2.16	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
FCG75	12/14/2017	6:29	FCG-FL1-ELA1113-DF-FCG75	Lead, ppb	<1	Less than detection level
FCG76	12/14/2017	6:34	FCG-FL1-1111-SINK-FCG76	Lead, ppb	<1	Less than detection level
FCG77	12/14/2017	6:34	FCG-FL1-1111-DF-FCG77	Lead, ppb	<1	Less than detection level
FCG78	12/14/2017	6:35	FCG-FL1-1112-SINK-FCG78	Lead, ppb	40.4	Above 15ppb federal action level and the 20ppb trigger level to take action as explained in the USEPA 3Ts Guidelines for schools. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
FCG79	12/14/2017	6:35	FCG-FL1-1112-DF-FCG79	Lead, ppb	<1	Less than detection level
FCG80	12/14/2017	6:37	FCG-FL1-HALL1128RR-SINK-FCG80	Lead, ppb	<1	Less than detection level
FCG81	12/14/2017	6:37	FCG-FL1-HALL1127RR-SINK-FCG81	Lead, ppb	<1	Less than detection level
FCG82	12/14/2017	6:38	FCG-FL1-1126WKRM-SINK-FCG82	Lead, ppb	<1	Less than detection level
FCG83	12/14/2017	6:38	FCG-FL1-1126WKRMRR-SINK-FCG83	Lead, ppb	<1	Less than detection level
FCG84	12/14/2017	6:40	FCG-FL2-2201-SINK-FCG84	Lead, ppb	<1	Less than detection level
FCG85	12/14/2017	6:33	FCG-FL2-2201-DF-FCG85	Lead, ppb	<1	Less than detection level
FCG86	12/14/2017	6:38	FCG-FL2-2202-SINK-FCG86	Lead, ppb	39.3	Above 15ppb federal action level and the 20ppb trigger level to take action as explained in the USEPA 3Ts Guidelines for schools. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
FCG87	12/14/2017	6:35	FCG-FL2-2202-DF-FCG87	Lead, ppb	<1	Less than detection level

**Cincinnati Public Schools - Fairview-Clifton German Language School - Lead Testing Results**

<b>SAMPLE #</b>	<b>SAMPLE DATE</b>	<b>SAMPLE TIME</b>	<b>SAMPLE</b>	<b>PARAMETER, CODE</b>	<b>AMOUNT</b>	<b>GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS</b>
FCG88	12/14/2017	6:38	FCG-FL2-2203-SINK-FCG88	Lead, ppb	<1	Less than detection level
FCG89	12/14/2017	6:38	FCG-FL2-2203-DF-FCG89	Lead, ppb	<1	Less than detection level
FCG90	12/14/2017	6:42	FCG-FL2-2204-SINK-FCG90	Lead, ppb	<1	Less than detection level
FCG91	12/14/2017	6:42	FCG-FL2-2204-DF-FCG91	Lead, ppb	<1	Less than detection level
FCG92	12/14/2017	6:44	FCG-FL2-2205-SINK-FCG92	Lead, ppb	2.25	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
FCG93	12/14/2017	6:44	FCG-FL2-2205-DF-FCG93	Lead, ppb	<1	Less than detection level
FCG94	12/14/2017	6:46	FCG-FL2-2206-SINK-FCG94	Lead, ppb	1.31	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
FCG95	12/14/2017	6:46	FCG-FL2-2206-DF-FCG95	Lead, ppb	<1	Less than detection level
FCG96	12/14/2017	6:48	FCG-FL2-2207-SINK-FCG96	Lead, ppb	<1	Less than detection level
FCG97	12/14/2017	6:48	FCG-FL2-2207-DF-FCG97	Lead, ppb	<1	Less than detection level
FCG98	12/14/2017	6:49	FCG-FL2-2218RR-SINK-FCG98	Lead, ppb	<1	Less than detection level
FCG99	12/14/2017	6:50	FCG-FL2-2219RR-SINK-FCG99	Lead, ppb	<1	Less than detection level
FCG100	12/14/2017	6:50	FCG-FL2-2220RR-SINK-FCG100	Lead, ppb	<1	Less than detection level
FCG101	12/14/2017	6:44	FCG-FL2-2208-SINK-FCG101	Lead, ppb	<1	Less than detection level
FCG102	12/14/2017	6:44	FCG-FL2-2208-DF-FCG102	Lead, ppb	<1	Less than detection level
FCG103	12/14/2017	6:45	FCG-FL2-2209-SINK-FCG103	Lead, ppb	3.69	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
FCG104	12/14/2017	6:45	FCG-FL2-2209-DF-FCG104	Lead, ppb	2.01	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.



**Cincinnati Public Schools - Fairview-Clifton German Language School - Lead Testing Results**

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
FCG105	12/14/2017	6:46	FCG-FL2-2210-SINK-FCG105	Lead, ppb	58.2	Above 15ppb federal action level and the 20ppb trigger level to take action as explained in the USEPA 3Ts Guidelines for schools. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
FCG106	12/14/2017	6:46	FCG-FL2-2210-DF-FCG106	Lead, ppb	1.37	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
FCG107	12/14/2017	5:36	FCG-FL2-2214-SINK-FCG107	Lead, ppb	<1	Less than detection level
FCG108	12/14/2017	5:36	FCG-FL2-2214-DF-FCG108	Lead, ppb	<1	Less than detection level
FCG109	12/14/2017	5:34	FCG-FL2-2213-SINK-FCG109	Lead, ppb	54.8	Above 15ppb federal action level and the 20ppb trigger level to take action as explained in the USEPA 3Ts Guidelines for schools. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
FCG110	12/14/2017	5:34	FCG-FL2-2213-DF-FCG110	Lead, ppb	8.23	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
FCG111	12/14/2017	5:40	FCG-FL2-2211-SINK-FCG111	Lead, ppb	<1	Less than detection level
FCG112	12/14/2017	5:40	FCG-FL2-2211-DF-FCG112	Lead, ppb	<1	Less than detection level
FCG113	12/14/2017	5:41	FCG-FL2-2212-SINK-FCG113	Lead, ppb	<1	Less than detection level
FCG114	12/14/2017	5:41	FCG-FL2-2212-DF-FCG114	Lead, ppb	<1	Less than detection level
FCG115	12/14/2017	5:43	FCG-FL2-2228RR-SINK-FCG115	Lead, ppb	<1	Less than detection level
FCG116	12/14/2017	5:44	FCG-FL2-2227RR-SINK-FCG116	Lead, ppb	<1	Less than detection level
FCG117	12/14/2017	5:45	FCG-FL2-2226WKRM-SINK-FCG117	Lead, ppb	<1	Less than detection level

**Cincinnati Public Schools - Fairview-Clifton German Language School - Lead Testing Results**

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
FCG118	12/14/2017	5:46	FCG-FL2-2226WKRMR-R-SINK-FCG118	Lead, ppb	<1	Less than detection level
FCG119	12/14/2017	5:48	FCG-FL3-3301-SINK-FCG119	Lead, ppb	1.09	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
FCG120	12/14/2017	5:48	FCG-FL3-3301-DF-FCG120	Lead, ppb	<1	Less than detection level
FCG121	12/14/2017	5:51	FCG-FL3-3302-SINK-FCG121	Lead, ppb	<1	Less than detection level
FCG122	12/14/2017	5:51	FCG-FL3-3302-DF-FCG122	Lead, ppb	<1	Less than detection level
FCG123	12/14/2017	5:53	FCG-FL3-3303-SINK-FCG123	Lead, ppb	1.63	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
FCG124	12/14/2017	5:53	FCG-FL3-3303-DF-FCG124	Lead, ppb	<1	Less than detection level
FCG125	12/14/2017	5:55	FCG-FL3-3304-SINK-FCG125	Lead, ppb	<1	Less than detection level
FCG126	12/14/2017	5:55	FCG-FL3-3304-DF-FCG126	Lead, ppb	<1	Less than detection level
FCG127	12/14/2017	5:57	FCG-FL3-3305-SINK-FCG127	Lead, ppb	17.1	Above 15ppb federal action level. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
FCG128	12/14/2017	5:57	FCG-FL3-3305-DF-FCG128	Lead, ppb	<1	Less than detection level
FCG129	12/14/2017	5:59	FCG-FL3-3306-SINK-FCG129	Lead, ppb	<1	Less than detection level
FCG130	12/14/2017	5:59	FCG-FL3-3306-DF-FCG130	Lead, ppb	<1	Less than detection level
FCG131	12/14/2017	6:00	FCG-FL3-HALL3316RR-SINK-FCG131	Lead, ppb	<1	Less than detection level
FCG132	12/14/2017	6:01	FCG-FL3-HALL3317RR-SINK-FCG132	Lead, ppb	<1	Less than detection level
FCG133	12/14/2017	6:02	FCG-FL3-HALL3318RR-SINK-FCG133	Lead, ppb	<1	Less than detection level
FCG134	12/14/2017	6:04	FCG-FL3-3314-SINK-FCG134	Lead, ppb	<1	Less than detection level
FCG135	12/14/2017	6:04	FCG-FL3-3314-DF-FCG135	Lead, ppb	<1	Less than detection level
FCG136	12/14/2017	6:06	FCG-FL3-3308-SINK-FCG136	Lead, ppb	<1	Less than detection level
FCG137	12/14/2017	6:06	FCG-FL3-3308-DF-FCG137	Lead, ppb	<1	Less than detection level
FCG138	12/14/2017	6:08	FCG-FL3-3309-SINK-FCG138	Lead, ppb	<1	Less than detection level
FCG139	12/14/2017	6:08	FCG-FL3-3309-DF-FCG139	Lead, ppb	<1	Less than detection level

### Cincinnati Public Schools - Fairview-Clifton German Language School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
FCG140	12/14/2017	6:10	FCG-FL3-3310-SINK-FCG140	Lead, ppb	<1	Less than detection level
FCG141	12/14/2017	6:10	FCG-FL3-3310-DF-FCG141	Lead, ppb	<1	Less than detection level
FCG142	12/14/2017	6:12	FCG-FL3-3311-SINK-FCG142	Lead, ppb	<1	Less than detection level
FCG143	12/14/2017	6:12	FCG-FL3-3311-DF-FCG143	Lead, ppb	<1	Less than detection level
FCG144	12/14/2017	6:13	FCG-FL3-3312FRONTDESK-SINK-FCG144	Lead, ppb	5.13	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
FCG145	12/14/2017	6:14	FCG-FL3-3312RWALL-SINK-FCG145	Lead, ppb	<1	Less than detection level
FCG146	12/14/2017	6:15	FCG-FL3-3312BWALL-LSINK-FCG146	Lead, ppb	<1	Less than detection level
FCG147	12/14/2017	6:16	FCG-FL3-3312BWALL-RSINK-FCG147	Lead, ppb	<1	Less than detection level
FCG148	12/14/2017	6:17	FCG-FL3-3312LWALL-SINK-FCG148	Lead, ppb	<1	Less than detection level
FCG149	12/14/2017	6:19	FCG-FL3-HALL3328RR-SINK-FCG149	Lead, ppb	<1	Less than detection level
FCG150	12/14/2017	6:21	FCG-FL3-HALL3327RR-SINK-FCG150	Lead, ppb	<1	Less than detection level
FCG151	12/14/2017	6:22	FCG-FL3-HALLNEAR3326-SINK-FCG151	Lead, ppb	11.6	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
FCG152	12/14/2017	6:22	FCG-FL3-HALLNEAR3326-DF-FCG152	Lead, ppb	<1	Less than detection level
FCG153	12/14/2017	6:24	FCG-FL3-3326WKRM-SINK-FCG153	Lead, ppb	<1	Less than detection level
FCG154	12/14/2017	6:26	FCG-FL3-3326WKRMRR-SINK-FCG154	Lead, ppb	<1	Less than detection level
FCG155	12/14/2017	5:56	FCG-FL1-1212ART-RDF-FCG155	Lead, ppb	<1	Less than detection level