

April 3, 2017

Cincinnati Public Schools
 Cynthia Eghbalnia
 2651 Burnet Avenue
 Cincinnati, OH 45219

Hartwell School Resample

Dear Cynthia:

One sample was collected in a resample round of lead analyses for Hartwell School. Greater Cincinnati Water Works (GCWW) analyzed the sample and compared the results.

School Sample Results

The *USEPA 3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance Document (3Ts Guidelines)* is the process and guidelines used for assisting schools with testing for lead. Results are below.

Cincinnati Public Schools - Hartwell School Lead Testing Results-Resample				
SAMPLE #	SAMPLE NAME	Initial sample DATE 11/8/16 Lead, ppb	CHANGES MADE BY SCHOOL AFTER INITIAL TESTING	Resample DATE 2/3/17 Lead, ppb
HAR32	HAR-FL1-HALLWAYNEAR1300-LDF	N/A	DRINKING FOUNTAIN WAS NOT WORKING AT THE TIME OF SAMPLING. IT HAS BEEN FIXED.	<1

Changes made and Next Steps

In the first round of sampling, sample location # HAR32 [HAR-FL1-HALLWAYNEAR1300-LDF] was out of service. The drinking faucet was fixed after the November 2016 sampling round and then sampled in February 2017. Results are below the lead detection level; no lead was detected and no further action is needed.

Fixing this drinking fountain in the school continues to improve the water quality for the students and staff. Your decisions and actions throughout this process speak to your care and commitment to ensure students and staff remain safe and healthy while attending your school.



We look forward to our continued partnership with your school. Our resources are available to assist in many ways. Please contact Jim Nelson at 591-6869 if you have any questions.

Sincerely,

A handwritten signature in black ink that reads "Cathy B. Bailey". The signature is written in a cursive style with a large initial 'C' and a distinct 'B'.

Cathy B. Bailey
Director/Greater Cincinnati Water Works

Cc: Dr. Marilyn Crumpton, Cincinnati Health Department
Dr. Camille Jones, Cincinnati Health Department
Chuck DeJonckheere, Hamilton County Public Health
Sheila Hill-Christian, City of Cincinnati
Verna Arnette, Greater Cincinnati Water Works
Jeff Swertfeger, Greater Cincinnati Water Works
Jason DeLaet, Greater Cincinnati Water Works