



May 10, 2018

## Hays-Porter School

Cincinnati Public Schools  
Cynthia Eghbalnia  
2651 Burnet Avenue  
Cincinnati, OH 45219

Dear Cynthia:

Thank you for taking the responsibility seriously to protect the health of the children by voluntarily testing the water in your school for lead!

Attached please find the results of the lead analyses performed for Hays-Porter School by the Greater Cincinnati Water Works (GCWW). The following comments speak to the process, samples analyzed and additional steps needed to help ensure the safety of all the students within the school.

### **School Sampling Process and Results**

GCWW and Cincinnati Public Schools (CPS) staff worked together to finalize a sampling plan for the school. The *USEPA 3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance Document (3Ts Guidelines)* is the process and guidelines used for assisting schools with testing for lead.

In January, one hundred, seventeen (117) samples were collected from drinking fountains, sinks and cooking outlets throughout the school. Multiple sinks within the schools were not initially considered for testing, however, key nearby indicators (coffee makers, drinking cups, plates, utensils, etc.) prompted additional locations to be tested in the schools. Including these sampling locations speaks to the proactive approach CPS continues to have towards understanding the water quality within the schools. One additional location was not sampled. The results show the following:

- 88 samples (75.21%), below the detection level (<1)
- 18 samples (15.39%), between 1ppb and 5ppb
- 4 samples (3.42%), between 5ppb and 10ppb
- 5 samples (4.27%), between 10ppb and 15ppb
- 2 samples (1.71%), greater than 15ppb.

Ninety-eight percent (98%) of the results were below the detection level or below the federal action level.

Fifteen parts per billion (ppb) is the federal Lead and Copper Rule action level; desired results are below 15. The federal action level of 15ppb pertains to water utilities and GCWW's review and comments are based on this action level. However, the USEPA 3Ts Guidelines document outlines practices for schools to put in place if samples are greater than 20 ppb.

While we strive to have results less than 15, we recognize that lead is a pervasive environmental contaminant, and no safe blood lead threshold has been identified in children or adults. Therefore, we provide recommendations to further reduce any lead levels discovered in your school.



### Next steps

GCWW has reviewed the results from your samples and provides some next-steps comments.

1. Great news! The majority of the drinking fountain locations had no lead detections. One sample location, HAY-FL1-1036-DF-HAY61, had a low lead detection. Consider flushing the line (letting the water run) before use. No further action is suggested.
2. Two locations had results greater than 15ppb:
  - HAY-FL1-1077BOYSLOCK-LSINK-HAY9, 132ppb
  - HAY-FL1-1023COMMUNITYRM-SINK-HAY24, 20.4ppbBoth of these locations are sinks and it is assumed by the names, they are not used as drinking water or cooking outlets. However, consider an immediate remedy such as taking the sample locations out of service until a more defined plan can be created or post a sign limiting the use at these locations. Refer to the USEPA 3Ts Guidelines for more information and suggestions on signage. After the locations are out of service, work to reduce the lead levels by first removing and cleaning the aerators as particles may be trapped on the aerator and contributing to the lead detections. Consider resampling after the cleaning.
3. Three samples in the kitchen had lead detections. If these locations are used for food and drink preparation, flush the line (let the water run) before use.
4. Three of the four locker room sample locations had lead detections, including the high lead level mentioned above. If these locations are not used on a regular basis, the infrequent use may be contributing to the lead detections. Signage at these locations limiting the use may be helpful.
5. Several other sinks had lead detections. Based on the names, these are not used for drinking water or cooking purposes.
  - a. Lead is not an issue for body contact such as bathing, showering, and washing hands.
  - a. To lower the lead levels, again, consider removing and cleaning the aerator. Particles may be trapped on the aerator and contributing to the lead level.
  - b. If the locations with lead detections are not used on a regular basis, then the infrequent use may be contributing to the lead detections.
6. Review how water is being used within your facility. Again, if water is not used on a regular basis at some of these locations, again, the infrequent use at the outlet may be contributing to the lead detections. Signage at these locations may be helpful (hand washing only, science class purposes only-no drinking, etc.).
7. If it hasn't occurred already, a robust communications plan is suggested. Communications plan steps are outlined in the 3Ts Guidelines. This plan will inform the school community of the sampling work the school has done to date and the steps the school will take to correct any issues discovered. GCWW employees can assist with this plan and are available to attend any school meetings to help explain our lead program, the sample results and our partnership with your school. Suggestions for language and a letter template can be provided if needed. Sampling results will be posted on the GCWW [lead.mycww.org](http://lead.mycww.org) website with other school sampling results.

Greater Cincinnati Water Works takes the presence of lead service lines and the removal of those service lines in our system very seriously. In addition, minimizing the exposure of lead within our preschools, schools, and daycares is one of our highest priorities under our Enhanced Lead Program. Please contact Jim Nelson at 591-6869 if you have any questions.

Thanks again for your partnership with Greater Cincinnati Water Works and your work to further understand the water quality within your building. Your extra steps and care to keep the children in our community safe are appreciated!

Sincerely,

A handwritten signature in black ink that reads "Cathy B. Bailey". The signature is written in a cursive, flowing style.

Cathy B. Bailey  
Director/Greater Cincinnati Water Works

Cc: Dr. Marilyn Crumpton, Cincinnati Health Department  
Dr. Camille Jones, Cincinnati Health Department  
Chuck DeJonckheere, Hamilton County Public Health  
Patrick Duhaney, City of Cincinnati  
Verna Arnette, Greater Cincinnati Water Works  
Jeff Swertfeger, Greater Cincinnati Water Works  
Jason DeLaet, Greater Cincinnati Water Works  
James Nelson, Greater Cincinnati Water Works

### Cincinnati Public Schools - Hays-Porter School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
HAY1	1/18/2018	5:41	HAY-FL1-ENTNEAR1004-LDF-HAY1	Lead, ppb	<1	Less than detection level
HAY2	1/18/2018	5:41	HAY-FL1-ENTNEAR1004-RDF-HAY2	Lead, ppb	<1	Less than detection level
HAY3	1/18/2018	5:43	HAY-FL1-1006HEALTH-SINK-HAY3	Lead, ppb	<1	Less than detection level
HAY4	1/18/2018	5:43	HAY-FL1-1006HEALTHRR-SINK-HAY4	Lead, ppb	13	Less than detection level
HAY5	1/18/2018	5:45	HAY-FL1-1012WKRM-SINK-HAY5	Lead, ppb	<1	Less than detection level
HAY6	1/18/2018	5:47	HAY-FL1-MAINFOFFLUNIRR-SINK-HAY6	Lead, ppb	<1	Less than detection level
HAY7	1/18/2018	5:47	HAY-FL1-MAINFOFFRUNIRR-SINK-HAY7	Lead, ppb	<1	Less than detection level
HAY8	1/18/2018	5:50	HAY-FL1-1070GYM-DF-HAY8	Lead, ppb	<1	Less than detection level
HAY9	1/18/2018	5:51	HAY-FL1-1077BOYSLOCK-LSINK-HAY9	Lead, ppb	132	Above 15ppb federal action level and the 20ppb trigger level to take action as explained in the USEPA 3Ts Guidelines for schools. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
HAY10	1/18/2018	5:51	HAY-FL1-1077BOYSLOCK-RSINK-HAY10	Lead, ppb	3.55	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
HAY11	1/18/2018	5:53	HAY-FL1-1074GIRLSLOCK-LSINK-HAY11	Lead, ppb	10.1	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
HAY12	1/18/2018	5:53	HAY-FL1-1074GIRLSLOCK-RSINK-HAY12	Lead, ppb	<1	Less than detection level
HAY13	1/18/2018	5:55	HAY-FL1-PEOFFRR-SINK-HAY13	Lead, ppb	<1	Less than detection level
HAY14	1/18/2018	5:56	HAY-FL1-1067WKRM-IM-HAY14	Lead, ppb	<1	Less than detection level
HAY15	1/18/2018	5:05	HAY-FL1-KITDISHRM-HANDSINK-HAY15	Lead, ppb	<1	Less than detection level
HAY16	1/18/2018	5:06	HAY-FL1-KITDISHRM3TUB-LSINK-HAY16	Lead, ppb	<1	Less than detection level
HAY17	1/18/2018	5:06	HAY-FL1-KITDISHRM3TUB-RSINK-HAY17	Lead, ppb	<1	Less than detection level
HAY18	1/18/2018	5:07	HAY-FL1-KITSTOCKPOT-LFILLER-HAY18	Lead, ppb	6	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

### Cincinnati Public Schools - Hays-Porter School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
HAY19	1/18/2018	5:08	HAY-FL1-KITSTOCKPOT-RFILLER-HAY19	Lead, ppb	1.63	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
HAY20	1/18/2018	5:09	HAY-FL1-KITNEARSERVE-HANDSINK-HAY20	Lead, ppb	<1	Less than detection level
HAY21	1/18/2018	5:10	HAY-FL1-KIT2TUB-SINK-HAY21	Lead, ppb	<1	Less than detection level
HAY22	1/18/2018	5:10	HAY-FL1-KITNEARCOOL-HANDSINK-HAY22	Lead, ppb	1.94	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
HAY23	1/18/2018	5:12	HAY-FL1-KITSTAFFLOCKRR-SINK-HAY23	Lead, ppb	<1	Less than detection level
HAY24	1/18/2018	5:14	HAY-FL1-1023COMMUNITYRM-SINK-HAY24	Lead, ppb	20.4	Above 15ppb federal action level and the 20ppb trigger level to take action as explained in the USEPA 3Ts Guidelines for schools. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
HAY25	1/18/2018	5:16	HAY-FL1-GIRLSRRNEARCAFE-FLSINK-HAY25	Lead, ppb	1.02	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
HAY26	1/18/2018	5:16	HAY-FL1-GIRLSRRNEARCAFE-LSINK-HAY26	Lead, ppb	<1	Less than detection level
HAY27	1/18/2018	5:16	HAY-FL1-GIRLSRRNEARCAFE-RSINK-HAY27	Lead, ppb	<1	Less than detection level
HAY28	1/18/2018	5:16	HAY-FL1-GIRLSRRNEARCAFE-FRSINK-HAY28	Lead, ppb	<1	Less than detection level
HAY29	1/18/2018	5:19	HAY-FL1-NEARCAFE-LCOMBOBF-HAY29	Lead, ppb	<1	Less than detection level
HAY30	1/18/2018	5:19	HAY-FL1-NEARCAFE-LCOMBODF-HAY30	Lead, ppb	<1	Less than detection level
HAY31	1/18/2018	5:19	HAY-FL1-NEARCAFE-RDF-HAY31	Lead, ppb	<1	Less than detection level
HAY32	1/18/2018	5:21	HAY-FL1-BOYSRRNEARCAFE-FLSINK-HAY32	Lead, ppb	<1	Less than detection level
HAY33	1/18/2018	5:21	HAY-FL1-BOYSRRNEARCAFE-LSINK-HAY33	Lead, ppb	<1	Less than detection level
HAY34	1/18/2018	5:21	HAY-FL1-BOYSRRNEARCAFE-RSINK-HAY34	Lead, ppb	<1	Less than detection level

### Cincinnati Public Schools - Hays-Porter School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
HAY35	1/18/2018	5:21	HAY-FL1-BOYSRRNEARCAFE-FRSINK-HAY35	Lead, ppb	<1	Less than detection level
HAY36	1/18/2018	5:27	HAY-FL1-1028-SINK-HAY36	Lead, ppb	<1	Less than detection level
HAY37	1/18/2018	5:27	HAY-FL1-1028-DF-HAY37	Lead, ppb	<1	Less than detection level
HAY38	1/18/2018	5:27	HAY-FL1-1028RR-SINK-HAY38	Lead, ppb	<1	Less than detection level
HAY39	1/18/2018	5:29	HAY-FL1-WKRMNEAR1028-SINK-HAY39	Lead, ppb	1.39	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
HAY40	1/18/2018	5:30	HAY-FL1-HALLNEAR1035-DF-HAY40	Lead, ppb	<1	Less than detection level
HAY41	1/18/2018	5:36	HAY-FL1-ELA1039-SINK-HAY41	Lead, ppb	<1	Less than detection level
HAY42	1/18/2018	5:36	HAY-FL1-ELA1039LRR-SINK-HAY42	Lead, ppb	<1	Less than detection level
HAY43	1/18/2018	5:37	HAY-FL1-ELA1039MRR-SINK-HAY43	Lead, ppb	<1	Less than detection level
HAY44	1/18/2018	5:37	HAY-FL1-ELA1039RRR-SINK-HAY44	Lead, ppb	<1	Less than detection level
HAY45	1/18/2018	5:04	HAY-FL1-1047-SINK-HAY45	Lead, ppb	<1	Less than detection level
HAY46	1/18/2018	5:04	HAY-FL1-1047-DF-HAY46	Lead, ppb	<1	Less than detection level
HAY47	1/18/2018	5:05	HAY-FL1-1046-SINK-HAY47	Lead, ppb	<1	Less than detection level
HAY48	1/18/2018	5:05	HAY-FL1-1046-DF-HAY48	Lead, ppb	<1	Less than detection level
HAY49	1/18/2018	5:06	HAY-FL1-1034-SINK-HAY49	Lead, ppb	<1	Less than detection level
HAY50	1/18/2018	5:08	HAY-FL1-1034-DF-HAY50	Lead, ppb	<1	Less than detection level
HAY51	1/18/2018	5:08	HAY-FL1-1031-SINK-HAY51	Lead, ppb	<1	Less than detection level
HAY52	1/18/2018	5:08	HAY-FL1-1031-DF-HAY52	Lead, ppb	<1	Less than detection level
HAY53	1/18/2018	5:09	HAY-FL1-ELA1038-SINK-HAY53	Lead, ppb	<1	Less than detection level
HAY54	1/18/2018	5:09	HAY-FL1-ELA1038LRR-SINK-HAY54	Lead, ppb	<1	Less than detection level
HAY55	1/18/2018	5:09	HAY-FL1-ELA1038MRR-SINK-HAY55	Lead, ppb	1.9	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
HAY56	1/18/2018	5:09	HAY-FL1-ELA1038RRR-SINK-HAY56	Lead, ppb	<1	Less than detection level
HAY57	1/18/2018	5:10	HAY-FL1-1032-SINK-HAY57	Lead, ppb	<1	Less than detection level
HAY58	1/18/2018	5:10	HAY-FL1-1032-DF-HAY58	Lead, ppb	<1	Less than detection level
HAY59	1/18/2018	5:10	HAY-FL1-1032RR-SINK-HAY59	Lead, ppb	<1	Less than detection level
HAY60	1/18/2018	5:17	HAY-FL1-1036-SINK-HAY60	Lead, ppb	<1	Less than detection level

### Cincinnati Public Schools - Hays-Porter School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
HAY61	1/18/2018	5:17	HAY-FL1-1036-DF-HAY61	Lead, ppb	2.1	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
HAY62	1/18/2018	5:17	HAY-FL1-1036RR-SINK-HAY62	Lead, ppb	7.22	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
HAY63	1/18/2018	5:18	HAY-FL1-1049-SINK-HAY63	Lead, ppb	1.26	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
HAY64	1/18/2018	5:18	HAY-FL1-1049-DF-HAY64	Lead, ppb	<1	Less than detection level
HAY65	1/18/2018	5:18	HAY-FL1-1049RR-SINK-HAY65	Lead, ppb	<1	Less than detection level
HAY66	1/18/2018	5:22	HAY-FL1-1051-SINK-HAY66	Lead, ppb	<1	Less than detection level
HAY67	1/18/2018	5:22	HAY-FL1-1051-DF-HAY67	Lead, ppb	<1	Less than detection level
HAY68	1/18/2018	5:22	HAY-FL1-1051RR-SINK-HAY68	Lead, ppb	<1	Less than detection level
HAY69	1/18/2018	5:31	HAY-FL2-2003MUSIC/ART-SINK-HAY69	Lead, ppb	<1	Less than detection level
HAY70	1/18/2018	5:33	HAY-FL2-2005-LSINK-HAY70	Lead, ppb	<1	Less than detection level
HAY71	1/18/2018	5:33	HAY-FL2-2005-MSINK-HAY71	Lead, ppb	13.1	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
HAY72	1/18/2018	5:33	HAY-FL2-2005-RSINK-HAY72	Lead, ppb	9.09	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
HAY73	1/18/2018	5:42	HAY-FL2-2008BWALL-LSINK-HAY73	Lead, ppb	6.12	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
HAY74	1/18/2018	5:42	HAY-FL2-2008BWALL-RSINK-HAY74	Lead, ppb	2.22	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.



### Cincinnati Public Schools - Hays-Porter School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
HAY75	1/18/2018	5:42	HAY-FL2-2008RWALL-SINK-HAY75	Lead, ppb	1.21	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
HAY76	1/18/2018	5:42	HAY-FL2-2008FWALL-SINK-HAY76	Lead, ppb	10.4	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
HAY77	1/18/2018	5:50	HAY-FL2-2013WKRM-SINK-HAY77	Lead, ppb	<1	Less than detection level
HAY78	1/18/2018	5:50	HAY-FL2-2018WKRM-SINK-HAY78	Lead, ppb	3.33	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
HAY79	1/18/2018	5:50	HAY-FL2-STAFFRRNEAR2018-SINK-HAY79	Lead, ppb	<1	Less than detection level
HAY80	1/18/2018	5:51	HAY-FL2-HALLNEAR2025/2024-DF-HAY80	Lead, ppb	<1	Less than detection level
HAY81	1/18/2018	5:51	HAY-FL2-ELA2025-SINK-HAY81	Lead, ppb	2.64	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
HAY82	1/18/2018	5:52	HAY-FL2-ELA2025LRR-SINK-HAY82	Lead, ppb	<1	Less than detection level
HAY83	1/18/2018	5:52	HAY-FL2-ELA2025MRR-SINK-HAY83	Lead, ppb	<1	Less than detection level
HAY84	1/18/2018	5:52	HAY-FL2-ELA2025RRR-SINK-HAY84	Lead, ppb	<1	Less than detection level
HAY85	1/18/2018	5:53	HAY-FL2-2036-SINK-HAY85	Lead, ppb	<1	Less than detection level
HAY86	1/18/2018	5:53	HAY-FL2-2036-DF-HAY86	Lead, ppb	<1	Less than detection level
HAY87	1/18/2018	5:54	HAY-FL2-2027-SINK-HAY87	Lead, ppb	<1	Less than detection level
HAY88	1/18/2018	5:54	HAY-FL2-2027-DF-HAY88	Lead, ppb	<1	Less than detection level
HAY89	1/18/2018	5:55	HAY-FL2-2026-SINK-HAY89	Lead, ppb	<1	Less than detection level
HAY90	1/18/2018	5:55	HAY-FL2-2026-DF-HAY90	Lead, ppb	<1	Less than detection level
HAY91	1/18/2018	5:55	HAY-FL2-2019-SINK-HAY91	Lead, ppb	<1	Less than detection level
HAY92	1/18/2018	5:56	HAY-FL2-ELA2024-SINK-HAY92	Lead, ppb	<1	Less than detection level
HAY93	1/18/2018	5:56	HAY-FL2-ELA2024LRR-SINK-HAY93	Lead, ppb	<1	Less than detection level
HAY94	1/18/2018	5:56	HAY-FL2-ELA2024MRR-SINK-HAY94	Lead, ppb	<1	Less than detection level
HAY95	1/18/2018	5:56	HAY-FL2-ELA2024RRR-SINK-HAY95	Lead, ppb	<1	Less than detection level
HAY96	1/18/2018	5:57	HAY-FL2-2021-SINK-HAY96	Lead, ppb	<1	Less than detection level
HAY97	1/18/2018	5:57	HAY-FL2-2021-DF-HAY97	Lead, ppb	<1	Less than detection level



### Cincinnati Public Schools - Hays-Porter School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
HAY98	1/18/2018	5:58	HAY-FL2-2023-SINK-HAY98	Lead, ppb	1.61	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
HAY99	1/18/2018	5:58	HAY-FL2-2023-DF-HAY99	Lead, ppb	<1	Less than detection level
HAY100	1/18/2018	5:58	HAY-FL2-2028-SINK-HAY100	Lead, ppb	<1	Less than detection level
HAY101	1/18/2018	5:58	HAY-FL2-2028-DF-HAY101	Lead, ppb	<1	Less than detection level
HAY102	1/18/2018	5:02	HAY-FL2-2037-SINK-HAY102	Lead, ppb	<1	Less than detection level
HAY103	1/18/2018	5:02	HAY-FL2-2037-DF-HAY103	Lead, ppb	<1	Less than detection level
HAY104	1/18/2018	6:00	HAY-FL3-3003-SINK-HAY104	Lead, ppb	<1	Less than detection level
HAY105	1/18/2018	6:09	HAY-FL3-HALLNEARELA3005-DF-HAY105	Lead, ppb	<1	Less than detection level
HAY106	1/18/2018	6:10	HAY-FL3-ELA3005-SINK-HAY106	Lead, ppb	10.3	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
HAY107	1/18/2018	6:10	HAY-FL3-ELA3005LRR-SINK-HAY107	Lead, ppb	<1	Less than detection level
HAY108	1/18/2018	6:10	HAY-FL3-ELA3005MRR-SINK-HAY108	Lead, ppb	<1	Less than detection level
HAY109	1/18/2018	6:10	HAY-FL3-ELA3005RRR-SINK-HAY109	Lead, ppb	1.97	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
HAY110	1/18/2018	6:13	HAY-FL3-3008-SINK-HAY110	Lead, ppb	3.59	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
HAY111	1/18/2018	6:13	HAY-FL3-3008-DF-HAY111	Lead, ppb	<1	Less than detection level
HAY112	1/18/2018	6:14	HAY-FL3-3007-SINK-HAY112	Lead, ppb	1.5	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
HAY113	1/18/2018	6:14	HAY-FL3-3007-DF-HAY113	Lead, ppb	<1	Less than detection level
HAY114	1/18/2018	6:17	HAY-FL3-3006-SINK-HAY114	Lead, ppb	2.42	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
HAY115	1/18/2018	6:17	HAY-FL3-3006-DF-HAY115	Lead, ppb	<1	Less than detection level

### Cincinnati Public Schools - Hays-Porter School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
HAY116	1/18/2018	6:08	HAY-FL3-3004-SINK-HAY116	Lead, ppb	2.09	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
HAY117	1/18/2018	6:08	HAY-FL3-3004-DF-HAY117	Lead, ppb	<1	Less than detection level
N/A	N/A	N/A	HAY-FL2-2008FRONTDESK-SINK	Lead, ppb	N/A	Out of service at the time of walkthrough.