



October 12, 2018

**Heritage Hill
Elementary School
Resample**

Princeton City School District
Heritage Hill Elementary School
Jon W. Fricke
11961 Chesterdale Road
Cincinnati, OH 45246

Dear Mr. Fricke,

Samples for various locations were collected in a resample round of lead analyses for Heritage Hill Elementary School. Greater Cincinnati Water Works (GCWW) analyzed the samples and compared the results.

School Sample Results

The *USEPA 3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance Document (3Ts Guidelines)* is the process and guidelines used for assisting schools with testing for lead. Results are shown below.

Princeton City School District - Heritage Hill Elementary School Lead Testing Results-Resamples					
SAMPLE	Initial 1st Draw sample Date 4/3/18 Lead, ppb	Changes made after first round of sampling	1st Draw sample Date 9/28/18 Lead, ppb	30 second flush sample Date 9/28/18 Lead, ppb	60 second flush sample Date 9/28/18 Lead, ppb
HHE-FL1-104RR-SINK-HHE18	25.4	Cleaned aerator; flushed the line	<1	<1	<1
HHE-FL1-GIRLSRRNEAR150-RSINK-HHE51	23.2	Cleaned aerator; flushed the line	<1	<1	<1

Changes made and Next Steps

After conducting a first round sampling in April 2018, remediations were done, and resamples were collected in September 2018 at these locations.

For all the locations in the resample round, aerators were cleaned, and the lines were flushed with ample water before resampling. This greatly reduced the lead levels at these locations; no further action is suggested.



Your work and changes in the school continue to improve the water quality for the students and staff. Your decisions and actions throughout this process speak to your care and commitment to ensure students and staff remain safe and healthy while attending your school.

Our resources are available to assist in many ways. Please contact Jim Nelson at 591-6869 if you have any questions.

Sincerely,

A handwritten signature in black ink that reads "Cathy B. Bailey". The signature is written in a cursive style with a large initial "C" and a long, sweeping underline.

Cathy B. Bailey

Director/Greater Cincinnati Water Works

Cc: Melba Moore, Cincinnati Health Department
Dr. Camille Jones, Cincinnati Health Department
Chuck DeJonckheere, Hamilton County Public Health
Verna Arnette, Greater Cincinnati Water Works
Jeff Swertfeger, Greater Cincinnati Water Works
Jason DeLaet, Greater Cincinnati Water Works
James Nelson, Greater Cincinnati Water Works