



May 29, 2018

Cincinnati Public Schools
Cynthia Eghbalnia
2651 Burnet Avenue
Cincinnati, OH 45219

**John P. Parker
School**

Dear Cynthia:

Thank you for taking the responsibility seriously to protect the health of the children by voluntarily testing the water in your school for lead!

Attached please find the results of the lead analyses performed for John P. Parker School by the Greater Cincinnati Water Works (GCWW). The following comments speak to the process, samples analyzed and additional steps needed to help ensure the safety of all the students within the school.

School Sampling Process and Results

GCWW and Cincinnati Public Schools (CPS) staff worked together to finalize a sampling plan for the school. The *USEPA 3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance Document (3Ts Guidelines)* is the process and guidelines used for assisting schools with testing for lead.

In February, one hundred, forty-two (142) samples were collected from drinking fountains, sinks and cooking outlets throughout the school. Multiple sinks within the schools were not initially considered for testing, however, key nearby indicators (coffee makers, drinking cups, plates, utensils, etc.) prompted additional locations to be tested in the schools. Including these sampling locations speaks to the proactive approach CPS continues to have towards understanding the water quality within the schools. The results show the following:

- 64 samples (45.07%), below the detection level (<1)
- 63 samples (44.37%), between 1ppb and 5ppb
- 9 samples (6.33%), between 5ppb and 10ppb
- 4 samples (2.82%), between 10ppb and 15ppb
- 2 samples (1.41%), greater than 15ppb.

Ninety-eight percent (98.59%) of the results were below the detection level or below the federal action level.

Fifteen parts per billion (ppb) is the federal Lead and Copper Rule action level; desired results are below 15. The federal action level of 15ppb pertains to water utilities and GCWW's review and comments are based on this action level. However, the USEPA 3Ts Guidelines document outlines practices for schools to put in place if samples are greater than 20 ppb.

While we strive to have results less than 15, we recognize that lead is a pervasive environmental contaminant, and no safe blood lead threshold has been identified in children or adults. Therefore, we provide recommendations to further reduce any lead levels discovered in your school.



Next steps

GCWW has reviewed the results from your samples and provides some next-steps comments.

1. Some drinking fountain locations had lead detections (however, all were below the federal action level of 15ppb):

JPP-FL1-1063-DF-JPP55	JPP-FL1-1082-DF-JPP72	JPP-FL1-1080-DF-JPP75
JPP-FL1-1064-DF-JPP81	JPP-FL2-2087-DF-JPP92	JPP-FL2-2085-DF-JPP94
JPP-FL2-ELA2109-DF-JPP96	JPP-FL2-ELA2059-DF-JPP105	JPP-FL2-2061-DF-JPP109
JPP-FL2-2057-DF-JPP112	JPP-FL2-2064-DF-JPP131	JPP-FL2-2066-DF-JPP133
JPP-FL2-2086-DF-JPP139		

To lower these levels, flush the line (let the water run) before use. No further action is suggested.


2. Two locations had lead detections greater than 15ppb, JPP-FL2-2056RWALL-RSINK-JPP121 and JPP-FL2-2064-SINK-JPP130. Both locations are sinks and it is assumed by the names that they are not used as drinking water or cooking outlets. However, consider an immediate remedy such as taking the sample locations out of service until a more defined plan can be created or post a sign limiting the use at these locations. Refer to the USEPA 3Ts Guidelines for more information and suggestions on signage. After the location is out of service, work to reduce the lead level by first removing and cleaning the aerator as particles may be trapped on the aerator and contributing to the lead detection. Consider resampling after the cleaning. In the case of the science lab location, consider posting a sign to limit the purpose of the sink as infrequent use may continue to contribute to lead detections.
3. Four (4) of the ten (10) sample locations in the kitchen had lead detections. Most of these locations had low lead levels. Flush the line before use if using these locations for food and drink preparation. No further action is suggested.
4. Several other sinks had lead detections. Based on the names, these are not used for drinking water or cooking purposes.
 - a. Lead is not an issue for body contact such as bathing, showering, and washing hands.
 - a. To lower the lead levels, consider removing and cleaning the aerator. Particles may be trapped on the aerator and contributing to the lead level.
 - b. If the locations with lead detections are not used on a regular basis, then the infrequent use may be contributing to the lead detections.
5. Six (6) of the seven (7) locations in the science lab had lead detections. Posting signs in this room limiting the purpose of the sinks (science use only, not for drinking purposes, etc.) may be helpful in deterring students and staff from using these locations for drinking water and food preparation.
6. Review how water is being used within your facility. Again, if water is not used on a regular basis at some of these locations, the infrequent use at the outlet may be contributing to the lead detections. Signage at these locations may be helpful (hand washing only, science class purposes only-no drinking, etc.).
7. If it hasn't occurred already, a robust communications plan is suggested. Communications plan steps are outlined in the 3Ts Guidelines. This plan will inform the school community of the sampling work the school has done to date and the steps the school will take to correct any issues discovered. GCWW employees can assist with this plan and are available to attend any school meetings to help explain our lead program, the sample results and our partnership with your school. Suggestions for language and a letter template can be provided if needed. Sampling results will be posted on the GCWW lead.mygcww.org website with other school sampling results.

Greater Cincinnati Water Works takes the presence of lead service lines and the removal of those service lines in our system very seriously. In addition, minimizing the exposure of lead within our preschools, schools, and

daycares is one of our highest priorities under our Enhanced Lead Program. Please contact Jim Nelson at 591-6869 if you have any questions.

Thanks again for your partnership with Greater Cincinnati Water Works and your work to further understand the water quality within your building. Your extra steps and care to keep the children in our community safe are appreciated!

Sincerely,

A handwritten signature in black ink that reads "Cathy B. Bailey". The signature is written in a cursive, flowing style.

Cathy B. Bailey
Director/Greater Cincinnati Water Works

Cc: Dr. Marilyn Crumpton, Cincinnati Health Department
Dr. Camille Jones, Cincinnati Health Department
Chuck DeJonckheere, Hamilton County Public Health
Sheila Hill-Christian, City of Cincinnati
Verna Arnette, Greater Cincinnati Water Works
Jeff Swertfeger, Greater Cincinnati Water Works
Jason DeLaet, Greater Cincinnati Water Works
James Nelson, Greater Cincinnati Water Works

Cincinnati Public Schools - Parker (John P.) School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
JPP1	2/16/2018	5:07	JPP-FL1-KITSTOCKPOT-LFILLER-JPP1	Lead, ppb	<1	Less than detection level
JPP2	2/16/2018	5:07	JPP-FL1-KITSTOCKPOT-RFILLER-JPP2	Lead, ppb	<1	Less than detection level
JPP3	2/16/2018	5:08	JPP-FL1-KITNEARSTOCKPOT-HANDSINK-JPP3	Lead, ppb	<1	Less than detection level
JPP4	2/16/2018	5:08	JPP-FL1-KIT1TUB-SINK-JPP4	Lead, ppb	<1	Less than detection level
JPP5	2/16/2018	5:09	JPP-FL1-KIT2TUB-SINK-JPP5	Lead, ppb	<1	Less than detection level
JPP6	2/16/2018	5:09	JPP-FL1-KIT1046STAFFRR-SINK-JPP6	Lead, ppb	1.66	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP7	2/16/2018	5:10	JPP-FL1-KITNEARSERVE-HANDSINK-JPP7	Lead, ppb	1.16	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP8	2/16/2018	5:10	JPP-FL1-KITDISHRM3TUB-LSINK-JPP8	Lead, ppb	2.04	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP9	2/16/2018	5:10	JPP-FL1-KITDISHRM3TUB-RSINK-JPP9	Lead, ppb	4.2	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP10	2/16/2018	5:10	JPP-FL1-KITDISHRM-HANDSINK-JPP10	Lead, ppb	<1	Less than detection level
JPP11	2/16/2018	5:11	JPP-FL1-CAFE-LDF-JPP11	Lead, ppb	<1	Less than detection level
JPP12	2/16/2018	5:11	JPP-FL1-CAFE-RCOMBODF-JPP12	Lead, ppb	<1	Less than detection level
JPP13	2/16/2018	5:11	JPP-FL1-CAFE-RCOMBOBF-JPP13	Lead, ppb	<1	Less than detection level
JPP14	2/16/2018	5:21	JPP-FL1-GIRLSLOCK-DF-JPP14	Lead, ppb	<1	Less than detection level
JPP15	2/16/2018	5:21	JPP-FL1-GIRLSLOCK-LSINK-JPP15	Lead, ppb	<1	Less than detection level
JPP16	2/16/2018	5:21	JPP-FL1-GIRLSLOCK-MSINK-JPP16	Lead, ppb	<1	Less than detection level
JPP17	2/16/2018	5:21	JPP-FL1-GIRLSLOCK-RSINK-JPP17	Lead, ppb	1.11	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

Cincinnati Public Schools - Parker (John P.) School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
JPP18	2/16/2018	5:23	JPP-FL1-1037PROFFRR-SINK-JPP18	Lead, ppb	3.77	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP19	2/16/2018	5:24	JPP-FL1-BOYSLOCK-DF-JPP19	Lead, ppb	<1	Less than detection level
JPP20	2/16/2018	5:24	JPP-FL1-BOYSLOCK-LSINK-JPP20	Lead, ppb	<1	Less than detection level
JPP21	2/16/2018	5:24	JPP-FL1-BOYSLOCK-MSINK-JPP21	Lead, ppb	<1	Less than detection level
JPP22	2/16/2018	5:24	JPP-FL1-BOYSLOCK-RSINK-JPP22	Lead, ppb	<1	Less than detection level
JPP23	2/16/2018	5:27	JPP-FL1-1104BOYSRR-LSINK-JPP23	Lead, ppb	<1	Less than detection level
JPP24	2/16/2018	5:27	JPP-FL1-1104BOYSRR-MSINK-JPP24	Lead, ppb	<1	Less than detection level
JPP25	2/16/2018	5:27	JPP-FL1-1104BOYSRR-RSINK-JPP25	Lead, ppb	1.03	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP26	2/16/2018	5:29	JPP-FL1-1103GIRLSRR-LSINK-JPP26	Lead, ppb	<1	Less than detection level
JPP27	2/16/2018	5:29	JPP-FL1-1103GIRLSRR-MSINK-JPP27	Lead, ppb	<1	Less than detection level
JPP28	2/16/2018	5:29	JPP-FL1-1103GIRLSRR-RSINK-JPP28	Lead, ppb	<1	Less than detection level
JPP29	2/16/2018	5:31	JPP-FL1-1023ART-LSINK-JPP29	Lead, ppb	1.28	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP30	2/16/2018	5:31	JPP-FL1-1023ART-MSINK-JPP30	Lead, ppb	1.42	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP31	2/16/2018	5:31	JPP-FL1-1023ART-RSINK-JPP31	Lead, ppb	1.58	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP32	2/16/2018	5:32	JPP-FL1-1016MUSIC-SINK-JPP32	Lead, ppb	1.49	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

Cincinnati Public Schools - Parker (John P.) School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
JPP33	2/16/2018	5:33	JPP-FL1-1018-SINK-JPP33	Lead, ppb	12.9	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP34	2/16/2018	5:33	JPP-FL1-1019-SINK-JPP34	Lead, ppb	14.1	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP35	2/16/2018	5:33	JPP-FL1-1014STAFFLOUNGE-SINK-JPP35	Lead, ppb	1.19	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP36	2/16/2018	5:35	JPP-FL1-1011MAILRM-SINK-JPP36	Lead, ppb	8.2	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP37	2/16/2018	5:36	JPP-FL1-1013WKRM-SINK-JPP37	Lead, ppb	5.87	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP38	2/16/2018	5:36	JPP-FL1-1013WKRMFRIDGE-IM-JPP38	Lead, ppb	<1	Less than detection level
JPP39	2/16/2018	5:37	JPP-FL1-1009RR-SINK-JPP39	Lead, ppb	<1	Less than detection level
JPP40	2/16/2018	5:37	JPP-FL1-1008RR-SINK-JPP40	Lead, ppb	1.01	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP41	2/16/2018	5:38	JPP-FL1-1007RR-SINK-JPP41	Lead, ppb	1.51	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP42	2/16/2018	5:42	JPP-FL1-HALLNEAR1052-LDF-JPP42	Lead, ppb	<1	Less than detection level
JPP43	2/16/2018	5:42	JPP-FL1-HALLNEAR1052-RDF-JPP43	Lead, ppb	<1	Less than detection level

Cincinnati Public Schools - Parker (John P.) School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
JPP44	2/16/2018	5:43	JPP-FL1-1055HEALTH-SINK-JPP44	Lead, ppb	1.11	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP45	2/16/2018	5:43	JPP-FL1-1054-SINK-JPP45	Lead, ppb	<1	Less than detection level
JPP46	2/16/2018	5:43	JPP-FL1-1053RR-SINK-JPP46	Lead, ppb	1.3	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP47	2/16/2018	5:45	JPP-FL1-1057-SINK-JPP47	Lead, ppb	2	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP48	2/16/2018	5:45	JPP-FL1-1057-DF-JPP48	Lead, ppb	<1	Less than detection level
JPP49	2/16/2018	5:46	JPP-FL1-1069RR-SINK-JPP49	Lead, ppb	<1	Less than detection level
JPP50	2/16/2018	5:48	JPP-FL1-ELA1059-SINK-JPP50	Lead, ppb	1.49	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP51	2/16/2018	5:48	JPP-FL1-ELA1059-DF-JPP51	Lead, ppb	<1	Less than detection level
JPP52	2/16/2018	5:48	JPP-FL1-1061-SINK-JPP52	Lead, ppb	2.06	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP53	2/16/2018	5:48	JPP-FL1-1061-DF-JPP53	Lead, ppb	<1	Less than detection level
JPP54	2/16/2018	5:49	JPP-FL1-1063-SINK-JPP54	Lead, ppb	<1	Less than detection level
JPP55	2/16/2018	5:49	JPP-FL1-1063-DF-JPP55	Lead, ppb	3.67	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP56	2/16/2018	5:50	JPP-FL1-1065-SINK-JPP56	Lead, ppb	<1	Less than detection level
JPP57	2/16/2018	5:50	JPP-FL1-1065-DF-JPP57	Lead, ppb	<1	Less than detection level
JPP58	2/16/2018	5:50	JPP-FL1-1067RR-SINK-JPP58	Lead, ppb	<1	Less than detection level

Cincinnati Public Schools - Parker (John P.) School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
JPP59	2/16/2018	5:06	JPP-FL1-1070RR-SINK-JPP59	Lead, ppb	5.38	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP60	2/16/2018	5:07	JPP-FL1-1071WKRM-SINK-JPP60	Lead, ppb	12.2	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP61	2/16/2018	5:08	JPP-FL1-1077RR-SINK-JPP61	Lead, ppb	1.3	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP62	2/16/2018	5:10	JPP-FL1-1079-SINK-JPP62	Lead, ppb	<1	Less than detection level
JPP63	2/16/2018	5:10	JPP-FL1-1079-DF-JPP63	Lead, ppb	<1	Less than detection level
JPP64	2/16/2018	5:11	JPP-FL1-1079RR-SINK-JPP64	Lead, ppb	2.27	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP65	2/16/2018	5:14	JPP-FL1-1081-SINK-JPP65	Lead, ppb	3.13	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP66	2/16/2018	5:14	JPP-FL1-1081-DF-JPP66	Lead, ppb	<1	Less than detection level
JPP67	2/16/2018	5:14	JPP-FL1-1081RR-SINK-JPP67	Lead, ppb	<1	Less than detection level
JPP68	2/16/2018	5:22	JPP-FL1-ELA1109-SINK-JPP68	Lead, ppb	4.06	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP69	2/16/2018	5:22	JPP-FL1-ELA1109-DF-JPP69	Lead, ppb	<1	Less than detection level
JPP70	2/16/2018	5:22	JPP-FL1-ELA1109FRIDGE-IM-JPP70	Lead, ppb	1.08	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP71	2/16/2018	5:16	JPP-FL1-1082-SINK-JPP71	Lead, ppb	<1	Less than detection level

Cincinnati Public Schools - Parker (John P.) School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
JPP72	2/16/2018	5:16	JPP-FL1-1082-DF-JPP72	Lead, ppb	1.12	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP73	2/16/2018	5:16	JPP-FL1-1082RR-SINK-JPP73	Lead, ppb	<1	Less than detection level
JPP74	2/16/2018	5:20	JPP-FL1-1080-SINK-JPP74	Lead, ppb	5.02	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP75	2/16/2018	5:20	JPP-FL1-1080-DF-JPP75	Lead, ppb	1.44	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP76	2/16/2018	5:20	JPP-FL1-1080RR-SINK-JPP76	Lead, ppb	1.9	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP77	2/16/2018	5:24	JPP-FL1-1078RR-SINK-JPP77	Lead, ppb	1.36	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP78	2/16/2018	5:26	JPP-FL1-1072RR-SINK-JPP78	Lead, ppb	1.02	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP79	2/16/2018	5:28	JPP-FL1-1068RR-SINK-JPP79	Lead, ppb	<1	Less than detection level
JPP80	2/16/2018	5:30	JPP-FL1-1064-SINK-JPP80	Lead, ppb	6.73	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP81	2/16/2018	5:30	JPP-FL1-1064-DF-JPP81	Lead, ppb	1.19	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

Cincinnati Public Schools - Parker (John P.) School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
JPP82	2/16/2018	5:32	JPP-FL1-1062-SINK-JPP82	Lead, ppb	3.36	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP83	2/16/2018	5:32	JPP-FL1-1062-DF-JPP83	Lead, ppb	<1	Less than detection level
JPP84	2/16/2018	5:34	JPP-FL1-1060-SINK-JPP84	Lead, ppb	1.26	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP85	2/16/2018	5:34	JPP-FL1-1060-DF-JPP85	Lead, ppb	<1	Less than detection level
JPP86	2/16/2018	5:38	JPP-FL1-ELA1058-SINK-JPP86	Lead, ppb	1.14	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP87	2/16/2018	5:38	JPP-FL1-ELA1058-DF-JPP87	Lead, ppb	<1	Less than detection level
JPP88	2/16/2018	5:36	JPP-FL1-1056-SINK-JPP88	Lead, ppb	3.28	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP89	2/16/2018	5:36	JPP-FL1-1056-DF-JPP89	Lead, ppb	<1	Less than detection level
JPP90	2/16/2018	5:40	JPP-FL1-1066RR-SINK-JPP90	Lead, ppb	<1	Less than detection level
JPP91	2/16/2018	5:42	JPP-FL2-2087-SINK-JPP91	Lead, ppb	1.37	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP92	2/16/2018	5:42	JPP-FL2-2087-DF-JPP92	Lead, ppb	8.45	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP93	2/16/2018	5:44	JPP-FL2-2085-SINK-JPP93	Lead, ppb	4.4	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

Cincinnati Public Schools - Parker (John P.) School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
JPP94	2/16/2018	5:44	JPP-FL2-2085-DF-JPP94	Lead, ppb	1.56	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP95	2/16/2018	5:46	JPP-FL2-ELA2109-SINK-JPP95	Lead, ppb	2.64	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP96	2/16/2018	5:46	JPP-FL2-ELA2109-DF-JPP96	Lead, ppb	1.16	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP97	2/16/2018	5:49	JPP-FL2-2083RR-SINK-JPP97	Lead, ppb	<1	Less than detection level
JPP98	2/16/2018	5:05	JPP-FL2-2077STAFFLOUNGE-SINK-JPP98	Lead, ppb	5.5	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP99	2/16/2018	5:06	JPP-FL2-2077STAFFLOUNGEFRIDGE-IM-JPP99	Lead, ppb	2.59	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP100	2/16/2018	5:07	JPP-FL2-2071RR-SINK-JPP100	Lead, ppb	1.04	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP101	2/16/2018	5:06	JPP-FL2-2069RR-SINK-JPP101	Lead, ppb	<1	Less than detection level
JPP102	2/16/2018	5:07	JPP-FL2-2065-SINK-JPP102	Lead, ppb	1.25	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP103	2/16/2018	5:08	JPP-FL2-2065-DF-JPP103	Lead, ppb	<1	Less than detection level
JPP104	2/16/2018	5:09	JPP-FL2-ELA2059-SINK-JPP104	Lead, ppb	1.07	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

Cincinnati Public Schools - Parker (John P.) School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
JPP105	2/16/2018	5:10	JPP-FL2-ELA2059-DF-JPP105	Lead, ppb	1.11	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP106	2/16/2018	5:11	JPP-FL2-2063-SINK-JPP106	Lead, ppb	3.22	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP107	2/16/2018	5:12	JPP-FL2-2063-DF-JPP107	Lead, ppb	<1	Less than detection level
JPP108	2/16/2018	5:13	JPP-FL2-2061-SINK-JPP108	Lead, ppb	3.17	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP109	2/16/2018	5:14	JPP-FL2-2061-DF-JPP109	Lead, ppb	3.72	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP110	2/16/2018	5:15	JPP-FL2-2067RR-SINK-JPP110	Lead, ppb	<1	Less than detection level
JPP111	2/16/2018	5:16	JPP-FL2-2057-SINK-JPP111	Lead, ppb	2.63	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP112	2/16/2018	5:17	JPP-FL2-2057-DF-JPP112	Lead, ppb	1.83	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP113	2/16/2018	5:19	JPP-FL2-2055-SINK-JPP113	Lead, ppb	<1	Less than detection level
JPP114	2/16/2018	5:20	JPP-FL2-2055-DF-JPP114	Lead, ppb	<1	Less than detection level
JPP115	2/16/2018	5:21	JPP-FL2-2056FRONTDESK-SINK-JPP115	Lead, ppb	8.78	Science Lab. Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

Cincinnati Public Schools - Parker (John P.) School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
JPP116	2/16/2018	5:22	JPP-FL2-2056LWALL-LSINK-JPP116	Lead, ppb	12.3	Science Lab. Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP117	2/16/2018	5:23	JPP-FL2-2056LWALL-RSINK-JPP117	Lead, ppb	<1	Science Lab. Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP118	2/16/2018	5:24	JPP-FL2-2056BWALL-LSINK-JPP118	Lead, ppb	3.46	Science Lab. Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP119	2/16/2018	5:25	JPP-FL2-2056BWALL-RSINK-JPP119	Lead, ppb	2.05	Science Lab. Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP120	2/16/2018	5:26	JPP-FL2-2056RWALL-LSINK-JPP120	Lead, ppb	2.53	Science Lab. Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP121	2/16/2018	5:27	JPP-FL2-2056RWALL-RSINK-JPP121	Lead, ppb	20.8	Science Lab. Above 15ppb federal action level and the 20ppb trigger level to take action as explained in the USEPA 3Ts Guidelines for schools. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
JPP122	2/16/2018	5:28	JPP-FL2-2086-SINK-JPP122	Lead, ppb	<1	Less than detection level
JPP123	2/16/2018	5:29	JPP-FL2-2058-SINK-JPP123	Lead, ppb	1.71	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP124	2/16/2018	5:30	JPP-FL2-2058-DF-JPP124	Lead, ppb	<1	Less than detection level

Cincinnati Public Schools - Parker (John P.) School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
JPP125	2/16/2018	5:31	JPP-FL2-2068RR-SINK-JPP125	Lead, ppb	<1	Less than detection level
JPP126	2/16/2018	5:33	JPP-FL2-ELA2060-SINK-JPP126	Lead, ppb	1.84	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP127	2/16/2018	5:34	JPP-FL2-ELA2060-DF-JPP127	Lead, ppb	<1	Less than detection level
JPP128	2/16/2018	5:35	JPP-FL2-2062-SINK-JPP128	Lead, ppb	4.58	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP129	2/16/2018	5:36	JPP-FL2-2062-DF-JPP129	Lead, ppb	<1	Less than detection level
JPP130	2/16/2018	5:37	JPP-FL2-2064-SINK-JPP130	Lead, ppb	19.6	Above 15ppb federal action level. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
JPP131	2/16/2018	5:38	JPP-FL2-2064-DF-JPP131	Lead, ppb	9.64	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP132	2/16/2018	5:39	JPP-FL2-2066-SINK-JPP132	Lead, ppb	2.4	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP133	2/16/2018	5:40	JPP-FL2-2066-DF-JPP133	Lead, ppb	1.4	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP134	2/16/2018	5:41	JPP-FL2-2070RR-SINK-JPP134	Lead, ppb	<1	Less than detection level
JPP135	2/16/2018	5:43	JPP-FL2-2072RR-SINK-JPP135	Lead, ppb	3.21	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP136	2/16/2018	5:44	JPP-FL2-HALLNEAR2074-LDF-JPP136	Lead, ppb	<1	Less than detection level

Cincinnati Public Schools - Parker (John P.) School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
JPP137	2/16/2018	5:45	JPP-FL2-HALLNEAR2074-RDF-JPP137	Lead, ppb	<1	Less than detection level
JPP138	2/16/2018	5:46	JPP-FL2-2078RR-SINK-JPP138	Lead, ppb	1.22	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP139	2/16/2018	5:48	JPP-FL2-2086-DF-JPP139	Lead, ppb	2.18	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP140	2/16/2018	5:49	JPP-FL2-2082RR-SINK-JPP140	Lead, ppb	1.73	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP141	2/16/2018	5:51	JPP-FL2-2084-SINK-JPP141	Lead, ppb	1.01	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
JPP142	2/16/2018	5:52	JPP-FL2-2084-DF-JPP142	Lead, ppb	<1	Less than detection level