

July 17, 2017

Cincinnati Public Schools  
 Cynthia Eghbalnia  
 2651 Burnet Avenue  
 Cincinnati, OH 45219

**Kilgour School  
 Resample**

Dear Cynthia:

**Samples for one location were collected in a resample round** of lead analyses for Kilgour School. Greater Cincinnati Water Works (GCWW) analyzed the samples and compared the results.

**School Sample Results**

The *USEPA 3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance Document (3Ts Guidelines)* is the process and guidelines used for assisting schools with testing for lead. Results are below.

Cincinnati Public Schools - Kilgour Elementary School Lead Testing Results- Resamples					
SAMPLE	Initial 1st Draw sample Date 11/22/16 Lead, ppb	Changes made by school after initial sampling	1st Draw sample Date 1/11/17 Lead, ppb	30 second flush sample Date 1/11/17 Lead, ppb	60 second flush sample Date 1/11/17 Lead, ppb
KILG-KITCHEN-STOCKPOT-RFILLER-KILG16	24.8	Plumbers checked out the line, operated the unit and line	<1	<1	<1
Regarding KILG16 (per CPS staff), This unit is not routinely used (had not been used for ~ 6 months prior to testing and may be used once or twice a year), and when it is, the water does not come into contact with any food items (sealed bags are placed in the water to heat).					

**Changes made and Next Steps**


1. Plumbers checked and operated the line (flushed). This action helped as no lead was detected during the resampling round. No further action is suggested.

Your work and changes in the school continue to improve the water quality for the students and staff. Your decisions and actions throughout this process speak to your care and commitment to ensure students and staff remain safe and healthy while attending your school.



We look forward to our continued partnership with Cincinnati Public Schools. Our resources are available to assist in many ways. Please contact Jim Nelson at 591-6869 if you have any questions.

Sincerely,

A handwritten signature in cursive script that reads "Cathy B. Bailey". The signature is written in black ink on a white background.

Cathy B. Bailey  
Director/Greater Cincinnati Water Works

Cc: Dr. Marilyn Crumpton, Cincinnati Health Department  
Dr. Camille Jones, Cincinnati Health Department  
Chuck DeJonckheere, Hamilton County Public Health  
Sheila Hill-Christian, City of Cincinnati  
Verna Arnette, Greater Cincinnati Water Works  
Jeff Swertfeger, Greater Cincinnati Water Works  
Jason DeLaet, Greater Cincinnati Water Works