



**GREATER CINCINNATI
WATER WORKS**

A Service of The City of Cincinnati

Cincinnati Archdiocese - McNicholas High School - Lead Testing Results (resample)

SAMPLE	Initial 1st Draw sample Date 1/11/17 Lead, ppb	1st Draw sample Date 3/15/17 Lead, ppb	30 second flush sample Date 3/15/17 Lead, ppb	60 second flush sample Date 3/15/17 Lead, ppb	3 minute flush sample Date 3/15/17 Lead, ppb	5 minute flush sample Date 3/15/17 Lead, ppb
MCN-SCH1FLKIT-3TUB-LSINK-MCN172	74.1	40	1.86	<1	<1	<1
MCN-SCH1FLKIT-3TUB-RSINK-MCN173-1STDRAW	35.4	1.51	<1	<1	<1	<1