



May 14, 2018

Midway School

Cincinnati Public Schools
Cynthia Eghbalnia
2651 Burnet Avenue
Cincinnati, OH 45219

Dear Cynthia:

Thank you for taking the responsibility seriously to protect the health of the children by voluntarily testing the water in your school for lead!

Attached please find the results of the lead analyses performed for Midway School by the Greater Cincinnati Water Works (GCWW). The following comments speak to the process, samples analyzed and additional steps needed to help ensure the safety of all the students within the school.

School Sampling Process and Results

GCWW and Cincinnati Public Schools (CPS) staff worked together to finalize a sampling plan for the school. The *USEPA 3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance Document (3Ts Guidelines)* is the process and guidelines used for assisting schools with testing for lead.

In February, one hundred, forty (140) samples were collected from drinking fountains, sinks and cooking outlets throughout the school. Multiple sinks within the schools were not initially considered for testing, however, key nearby indicators (coffee makers, drinking cups, plates, utensils, etc.) prompted additional locations to be tested in the schools. Including these sampling locations speaks to the proactive approach CPS continues to have towards understanding the water quality within the schools. The results show the following:

- 92 samples (65.71%), below the detection level (<1)
- 36 samples (25.71%), between 1ppb and 5ppb
- 6 samples (4.29%), between 5ppb and 10ppb
- 2 samples (1.43%), between 10ppb and 15ppb
- 4 samples (2.86%), greater than 15ppb.

Nearly Ninety-seven percent (97.14%) of the results were below the detection level or below the federal action level.

Fifteen parts per billion (ppb) is the federal Lead and Copper Rule action level; desired results are below 15. The federal action level of 15ppb pertains to water utilities and GCWW's review and comments are based on this action level. However, the USEPA 3Ts Guidelines document outlines practices for schools to put in place if samples are greater than 20 ppb.

While we strive to have results less than 15, we recognize that lead is a pervasive environmental contaminant, and no safe blood lead threshold has been identified in children or adults. Therefore, we provide recommendations to further reduce any lead levels discovered in your school.



Next steps

GCWW has reviewed the results from your samples and provides some next-steps comments.

1. One drinking fountain had a result greater than 15ppb, MID-FL1-1144-DF-MID44. Consider an immediate remedy such as taking the sample location out of service until a more defined plan can be created or post a sign limiting the use at this location. Refer to the USEPA 3Ts Guidelines for more information and suggestions on signage. After the location is out of service, work to reduce the lead level by first cleaning the fountain and removing and cleaning the aerator as particles may be trapped on the aerator and contributing to the lead detection. Consider resampling after the cleaning. Also, if this drinking fountain is not used on a regular basis, the infrequent use may be contributing to the lead detection.
2. Other locations also had results greater than 15ppb;
 - MID-FL1-1134-SINK-MID51, 26.1ppb
 - MID-FL1-1111GIRLSRR-LSINK-MID78,16.1ppb
 - MID-FL2-2252-SINK-MID100, 17.9ppb.

All of these locations are sinks and it is assumed by the names, they are not used as drinking water or cooking outlets. However, again, consider an immediate remedy such as taking the sample locations out of service until a more defined plan can be created or post a sign limiting the use at these locations. Refer to the USEPA 3Ts Guidelines for more information and suggestions on signage. After the locations are out of service, work to reduce the lead levels by first removing and cleaning the aerators as particles may be trapped on the aerator and contributing to the lead detections. Consider resampling after the cleaning.

3. Most of the drinking fountains had no lead detections. Three drinking fountains had lead detections:
 - MID-FL1-1151-DF-MID13, 1.02ppb
 - MID-FL1-1141-DF-MID50, 10.8ppb
 - MID-FL2-2252-DF-MID101, 1.16ppb

To lower the lead levels at these locations, flush the line (let the water run) before use.


4. Some of the sample locations in the kitchen had lead detections. If these kitchen locations are used for food and drink preparation, flush the line (let the water run) before use.
5. Several other sinks had lead detections. Based on the names, these are not used for drinking water or cooking purposes.
 - a. Lead is not an issue for body contact such as bathing, showering, and washing hands.
 - a. To lower the lead levels, again, consider removing and cleaning the aerators. Particles may be trapped on the aerators and contributing to the lead levels.
 - b. If the locations with lead detections are not used on a regular basis, then the infrequent use may be contributing to the lead detections.

6. Review how water is being used within your facility. Again, if water is not used on a regular basis at some of these locations, again, the infrequent use at the outlet may be contributing to the lead detections. Signage at these locations may be helpful (hand washing only, science class purposes only-no drinking, etc.).
7. If it hasn't occurred already, a robust communications plan is suggested. Communications plan steps are outlined in the 3Ts Guidelines. This plan will inform the school community of the sampling work the school has done to date and the steps the school will take to correct any issues discovered. GCWW employees can assist with this plan and are available to attend any school meetings to help explain our lead program, the sample results and our partnership with your school. Suggestions for language and a letter template can be provided if needed. Sampling results will be posted on the GCWW lead.mygcww.org website with other school sampling results.

Greater Cincinnati Water Works takes the presence of lead service lines and the removal of those service lines in our system very seriously. In addition, minimizing the exposure of lead within our preschools, schools, and daycares is one of our highest priorities under our Enhanced Lead Program. Please contact Jim Nelson at 591-6869 if you have any questions.

Thanks again for your partnership with Greater Cincinnati Water Works and your work to further understand the water quality within your building. Your extra steps and care to keep the children in our community safe are appreciated!

Sincerely,

A handwritten signature in black ink that reads "Cathy B. Bailey". The signature is written in a cursive style with a large initial 'C'.

Cathy B. Bailey
Director/Greater Cincinnati Water Works

Cc: Dr. Marilyn Crumpton, Cincinnati Health Department
Dr. Camille Jones, Cincinnati Health Department
Chuck DeJonckheere, Hamilton County Public Health
Sheila Hill-Christian, City of Cincinnati
Verna Arnette, Greater Cincinnati Water Works
Jeff Swertfeger, Greater Cincinnati Water Works
Jason DeLaet, Greater Cincinnati Water Works
James Nelson, Greater Cincinnati Water Works

Cincinnati Public Schools - Midway School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
MID1	2/23/2018	5:11:00	MID-FL1-1131ART-LSINK-MID1	Lead, ppb	<1	Less than detection level
MID2	2/23/2018	5:12:00	MID-FL1-1131ART-MSINK-MID2	Lead, ppb	<1	Less than detection level
MID3	2/23/2018	5:13:00	MID-FL1-1131ART-RSINK-MID3	Lead, ppb	<1	Less than detection level
MID4	2/23/2018	5:14:00	MID-FL1-1133-SINK-MID4	Lead, ppb	<1	Less than detection level
MID5	2/23/2018	5:15:00	MID-FL1-1133-DF-MID5	Lead, ppb	<1	Less than detection level
MID6	2/23/2018	5:16:00	MID-FL1-1133RR-SINK-MID6	Lead, ppb	<1	Less than detection level
MID7	2/23/2018	5:17:00	MID-FL1-ELA1150-SINK-MID7	Lead, ppb	1.44	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MID8	2/23/2018	5:18:00	MID-FL1-ELA1150-DF-MID8	Lead, ppb	<1	Less than detection level
MID9	2/23/2018	5:19:00	MID-FL1-A1150RR-SINK-MID9	Lead, ppb	<1	Less than detection level
MID10	2/23/2018	5:20:00	MID-FL1-B1150RR-SINK-MID10	Lead, ppb	<1	Less than detection level
MID11	2/23/2018	5:21:00	MID-FL1-C1150RR-SINK-MID11	Lead, ppb	<1	Less than detection level
MID12	2/23/2018	5:22:00	MID-FL1-1151-SINK-MID12	Lead, ppb	3.61	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MID13	2/23/2018	5:23:00	MID-FL1-1151-DF-MID13	Lead, ppb	1.02	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MID14	2/23/2018	5:24:00	MID-FL1-1152-SINK-MID14	Lead, ppb	1.12	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MID15	2/23/2018	5:25:00	MID-FL1-1152-DF-MID15	Lead, ppb	<1	Less than detection level
MID16	2/23/2018	5:26:00	MID-FL1-1153-SINK-MID16	Lead, ppb	<1	Less than detection level
MID17	2/23/2018	5:27:00	MID-FL1-1153-DF-MID17	Lead, ppb	<1	Less than detection level
MID18	2/23/2018	5:28:00	MID-FL1-1154-SINK-MID18	Lead, ppb	4.85	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MID19	2/23/2018	5:29:00	MID-FL1-1154-DF-MID19	Lead, ppb	<1	Less than detection level

Cincinnati Public Schools - Midway School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
MID20	2/23/2018	5:30:00	MID-FL1-ELA1145-SINK-MID20	Lead, ppb	1.34	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MID21	2/23/2018	5:31:00	MID-FL1-ELA1145-DF-MID21	Lead, ppb	<1	Less than detection level
MID22	2/23/2018	5:32:00	MID-FL1-A1145RR-SINK-MID22	Lead, ppb	<1	Less than detection level
MID23	2/23/2018	5:33:00	MID-FL1-B1145RR-SINK-MID23	Lead, ppb	<1	Less than detection level
MID24	2/23/2018	5:34:00	MID-FL1-1149-SINK-MID24	Lead, ppb	<1	Less than detection level
MID25	2/23/2018	5:35:00	MID-FL1-1149-DF-MID25	Lead, ppb	<1	Less than detection level
MID26	2/23/2018	5:36:00	MID-FL1-1149RR-SINK-MID26	Lead, ppb	<1	Less than detection level
MID27	2/23/2018	5:37:00	MID-FL1-1148-SINK-MID27	Lead, ppb	1.1	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MID28	2/23/2018	5:38:00	MID-FL1-1148-DF-MID28	Lead, ppb	<1	Less than detection level
MID29	2/23/2018	5:39:00	MID-FL1-1148RR-SINK-MID29	Lead, ppb	<1	Less than detection level
MID30	2/23/2018	5:40:00	MID-FL1-1147-SINK-MID30	Lead, ppb	<1	Less than detection level
MID31	2/23/2018	5:41:00	MID-FL1-1147-DF-MID31	Lead, ppb	<1	Less than detection level
MID32	2/23/2018	5:42:00	MID-FL1-1147RR-SINK-MID32	Lead, ppb	<1	Less than detection level
MID33	2/23/2018	5:43:00	MID-FL1-1146-SINK-MID33	Lead, ppb	<1	Less than detection level
MID34	2/23/2018	5:44:00	MID-FL1-1146-DF-MID34	Lead, ppb	<1	Less than detection level
MID35	2/23/2018	5:45:00	MID-FL1-1146RR-SINK-MID35	Lead, ppb	<1	Less than detection level
MID36	2/23/2018	5:46:00	MID-FL1-HALLWAYNEAR1140-LDF-MID36	Lead, ppb	<1	Less than detection level
MID37	2/23/2018	5:47:00	MID-FL1-HALLWAYNEAR1140-RDF-MID37	Lead, ppb	<1	Less than detection level
MID38	2/23/2018	5:48:00	MID-FL1-ELA1140-SINK-MID38	Lead, ppb	<1	Less than detection level
MID39	2/23/2018	5:49:00	MID-FL1-ELA1140-DF-MID39	Lead, ppb	<1	Less than detection level
MID40	2/23/2018	5:50:00	MID-FL1-A1140RR-SINK-MID40	Lead, ppb	<1	Less than detection level
MID41	2/23/2018	5:51:00	MID-FL1-B1140RR-SINK-MID41	Lead, ppb	<1	Less than detection level
MID42	2/23/2018	5:52:00	MID-FL1-C1140RR-SINK-MID42	Lead, ppb	<1	Less than detection level
MID43	2/23/2018	5:53:00	MID-FL1-1144-SINK-MID43	Lead, ppb	13.2	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

Cincinnati Public Schools - Midway School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
MID44	2/23/2018	5:54:00	MID-FL1-1144-DF-MID44	Lead, ppb	42.4	Above 15ppb federal action level and the 20ppb trigger level to take action as explained in the USEPA 3Ts Guidelines for schools. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
MID45	2/23/2018	5:55:00	MID-FL1-1143-SINK-MID45	Lead, ppb	1.75	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MID46	2/23/2018	5:56:00	MID-FL1-1143-DF-MID46	Lead, ppb	<1	Less than detection level
MID47	2/23/2018	5:14:00	MID-FL1-1142-SINK-MID47	Lead, ppb	5.95	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MID48	2/23/2018	5:14:00	MID-FL1-1142-DF-MID48	Lead, ppb	<1	Less than detection level
MID49	2/23/2018	5:16:00	MID-FL1-1141-SINK-MID49	Lead, ppb	2.4	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MID50	2/23/2018	5:16:00	MID-FL1-1141-DF-MID50	Lead, ppb	10.8	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MID51	2/23/2018	5:18:00	MID-FL1-1134-SINK-MID51	Lead, ppb	26.1	Above 15ppb federal action level and the 20ppb trigger level to take action as explained in the USEPA 3Ts Guidelines for schools. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).

Cincinnati Public Schools - Midway School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
MID52	2/23/2018	5:20:00	MID-FL1-1132MUSIC-SINK-MID52	Lead, ppb	3.55	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MID53	2/23/2018	5:20:00	MID-FL1-1132MUSIC-DF-MID53	Lead, ppb	<1	Less than detection level
MID54	2/23/2018	5:21:00	MID-FL1-KITSTOCKPOT-LFILLER-MID54	Lead, ppb	<1	Less than detection level
MID55	2/23/2018	5:22:00	MID-FL1-KITSTOCKPOT-MFILLER-MID55	Lead, ppb	2.44	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MID56	2/23/2018	5:23:00	MID-FL1-KITSTOCKPOT-RFILLER-MID56	Lead, ppb	7.35	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MID57	2/23/2018	5:24:00	MID-FL1-KITNEAR2TUBSPRAY-HANDSINK-MID57	Lead, ppb	1.32	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MID58	2/23/2018	5:24:00	MID-FL1-KIT2TUBSPRAY-SINK-MID58	Lead, ppb	2.72	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MID59	2/23/2018	5:25:00	MID-FL1-KITNEARCOOL-HANDSINK-MID59	Lead, ppb	<1	Less than detection level
MID60	2/23/2018	5:26:00	MID-FL1-KIT2TUBNEAR1124E-SINK-MID60	Lead, ppb	<1	Less than detection level
MID61	2/23/2018	5:26:00	MID-FL1-KIT1124CSTAFFLOCKRR-SINK-MID61	Lead, ppb	<1	Less than detection level
MID62	2/23/2018	5:27:00	MID-FL1-KITNEARDISHRM-HANDSINK-MID62	Lead, ppb	<1	Less than detection level
MID63	2/23/2018	5:28:00	MID-FL1-KITDISHRM3TUB-LSINK-MID63	Lead, ppb	<1	Less than detection level
MID64	2/23/2018	5:28:00	MID-FL1-KITDISHRM3TUB-RSINK-MID64	Lead, ppb	<1	Less than detection level
MID65	2/23/2018	5:30:00	MID-FL1-CAFE-LCOMBODF-MID65	Lead, ppb	<1	Less than detection level
MID66	2/23/2018	5:30:00	MID-FL1-CAFE-LCOMBOBF-MID66	Lead, ppb	<1	Less than detection level
MID67	2/23/2018	5:30:00	MID-FL1-CAFE-RDF-MID67	Lead, ppb	<1	Less than detection level
MID68	2/23/2018	5:33:00	MID-FL1-1120GYM-LDF-MID68	Lead, ppb	<1	Less than detection level
MID69	2/23/2018	5:33:00	MID-FL1-1120GYM-RDF-MID69	Lead, ppb	<1	Less than detection level
MID70	2/23/2018	5:35:00	MID-FL1-1119BOYSLOCK-LSINK-MID70	Lead, ppb	<1	Less than detection level
MID71	2/23/2018	5:35:00	MID-FL1-1119BOYSLOCK-RSINK-MID71	Lead, ppb	<1	Less than detection level

Cincinnati Public Schools - Midway School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
MID72	2/23/2018	5:37:00	MID-FL1-1118GIRLSLOCK-LSINK-MID72	Lead, ppb	<1	Less than detection level
MID73	2/23/2018	5:37:00	MID-FL1-1118GIRLSLOCK-RSINK-MID73	Lead, ppb	<1	Less than detection level
MID74	2/23/2018	5:38:00	MID-FL1-1117PEOFFRR-SINK-MID74	Lead, ppb	<1	Less than detection level
MID75	2/23/2018	5:40:00	MID-FL1-1112BOYSRR-LSINK-MID75	Lead, ppb	<1	Less than detection level
MID76	2/23/2018	5:40:00	MID-FL1-1112BOYSRR-MSINK-MID76	Lead, ppb	<1	Less than detection level
MID77	2/23/2018	5:40:00	MID-FL1-1112BOYSRR-RSINK-MID77	Lead, ppb	<1	Less than detection level
MID78	2/23/2018	5:42:00	MID-FL1-1111GIRLSRR-LSINK-MID78	Lead, ppb	16.1	Above 15ppb federal action level. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
MID79	2/23/2018	5:42:00	MID-FL1-1111GIRLSRR-MSINK-MID79	Lead, ppb	<1	Less than detection level
MID80	2/23/2018	5:42:00	MID-FL1-1111GIRLSRR-RSINK-MID80	Lead, ppb	<1	Less than detection level
MID81	2/23/2018	5:43:00	MID-FL1-B1110RR-SINK-MID81	Lead, ppb	<1	Less than detection level
MID82	2/23/2018	5:43:00	MID-FL1-A1110RR-SINK-MID82	Lead, ppb	5.34	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MID83	2/23/2018	5:43:00	MID-FL1-1110MO-SINK-MID83	Lead, ppb	<1	Less than detection level
MID84	2/23/2018	5:46:00	MID-FL1-1106CONFRM-SINK-MID84	Lead, ppb	4.29	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MID85	2/23/2018	5:49:00	MID-FL1-1103HEALTH-SINK-MID85	Lead, ppb	2.79	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MID86	2/23/2018	5:49:00	MID-FL1-1103HEALTH-IM-MID86	Lead, ppb	<1	Less than detection level
MID87	2/23/2018	5:49:00	MID-FL1-1103HEALTHRR-SINK-MID87	Lead, ppb	<1	Less than detection level
MID88	2/23/2018	5:52:00	MID-FL1-1101COMMRM-SINK-MID88	Lead, ppb	<1	Less than detection level
MID89	2/23/2018	5:52:00	MID-FL1-1101COMMRM-IM-MID89	Lead, ppb	<1	Less than detection level

Cincinnati Public Schools - Midway School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
MID90	2/23/2018	5:55:00	MID-FL1-C1125LIBRARY-SINK-MID90	Lead, ppb	1.32	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MID91	2/23/2018	5:18:00	MID-FL2-2233-SINK-MID91	Lead, ppb	2.49	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MID92	2/23/2018	5:18:00	MID-FL2-2233-DF-MID92	Lead, ppb	<1	Less than detection level
MID93	2/23/2018	5:19:00	MID-FL2-ELA2250-SINK-MID93	Lead, ppb	3.26	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MID94	2/23/2018	5:19:00	MID-FL2-ELA2250-DF-MID94	Lead, ppb	<1	Less than detection level
MID95	2/23/2018	5:20:00	MID-FL2-A2250RR-SINK-MID95	Lead, ppb	<1	Less than detection level
MID96	2/23/2018	5:20:00	MID-FL2-B2250RR-SINK-MID96	Lead, ppb	<1	Less than detection level
MID97	2/23/2018	5:20:00	MID-FL2-C2250RR-SINK-MID97	Lead, ppb	<1	Less than detection level
MID98	2/23/2018	5:21:00	MID-FL2-2251-SINK-MID98	Lead, ppb	2.45	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MID99	2/23/2018	5:21:00	MID-FL2-2251-DF-MID99	Lead, ppb	<1	Less than detection level
MID100	2/23/2018	5:23:00	MID-FL2-2252-SINK-MID100	Lead, ppb	17.9	Above 15ppb federal action level. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
MID101	2/23/2018	5:23:00	MID-FL2-2252-DF-MID101	Lead, ppb	1.16	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MID102	2/23/2018	5:24:00	MID-FL2-2253-SINK-MID102	Lead, ppb	4.08	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

Cincinnati Public Schools - Midway School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
MID103	2/23/2018	5:24:00	MID-FL2-2253-DF-MID103	Lead, ppb	<1	Less than detection level
MID104	2/23/2018	5:27:00	MID-FL2-2254-SINK-MID104	Lead, ppb	2.53	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MID105	2/23/2018	5:27:00	MID-FL2-2254-DF-MID105	Lead, ppb	<1	Less than detection level
MID106	2/23/2018	5:28:00	MID-FL2-ELA2245-SINK-MID106	Lead, ppb	5.38	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MID107	2/23/2018	5:28:00	MID-FL2-ELA2245-DF-MID107	Lead, ppb	<1	Less than detection level
MID108	2/23/2018	5:29:00	MID-FL2-A2245RR-SINK-MID108	Lead, ppb	8.12	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MID109	2/23/2018	5:29:00	MID-FL2-B2245RR-SINK-MID109	Lead, ppb	8.19	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MID110	2/23/2018	5:29:00	MID-FL2-C2245RR-SINK-MID110	Lead, ppb	<1	Less than detection level
MID111	2/23/2018	5:32:00	MID-FL2-2249-SINK-MID111	Lead, ppb	1.75	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MID112	2/23/2018	5:32:00	MID-FL2-2249-DF-MID112	Lead, ppb	<1	Less than detection level
MID113	2/23/2018	5:33:00	MID-FL2-2248-SINK-MID113	Lead, ppb	3.59	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MID114	2/23/2018	5:33:00	MID-FL2-2248-DF-MID114	Lead, ppb	<1	Less than detection level
MID115	2/23/2018	5:34:00	MID-FL2-2247-SINK-MID115	Lead, ppb	2.87	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MID116	2/23/2018	5:34:00	MID-FL2-2247-DF-MID116	Lead, ppb	<1	Less than detection level

Cincinnati Public Schools - Midway School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
MID117	2/23/2018	5:35:00	MID-FL2-2246-SINK-MID117	Lead, ppb	2.69	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MID118	2/23/2018	5:35:00	MID-FL2-2246-DF-MID118	Lead, ppb	<1	Less than detection level
MID119	2/23/2018	5:36:00	MID-FL2-HALLWAYNEAR2240-LDF-MID119	Lead, ppb	<1	Less than detection level
MID120	2/23/2018	5:36:00	MID-FL2-HALLWAYNEAR2240-RDF-MID120	Lead, ppb	<1	Less than detection level
MID121	2/23/2018	5:41:00	MID-FL2-ELA2240-SINK-MID121	Lead, ppb	4.72	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MID122	2/23/2018	5:41:00	MID-FL2-ELA2240-DF-MID122	Lead, ppb	<1	Less than detection level
MID123	2/23/2018	5:42:00	MID-FL2-A2240RR-SINK-MID123	Lead, ppb	<1	Less than detection level
MID124	2/23/2018	5:42:00	MID-FL2-B2240RR-SINK-MID124	Lead, ppb	<1	Less than detection level
MID125	2/23/2018	5:42:00	MID-FL2-C2240RR-SINK-MID125	Lead, ppb	<1	Less than detection level
MID126	2/23/2018	5:43:00	MID-FL2-2244-SINK-MID126	Lead, ppb	2.36	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MID127	2/23/2018	5:43:00	MID-FL2-2244-DF-MID127	Lead, ppb	<1	Less than detection level
MID128	2/23/2018	5:45:00	MID-FL2-2243-SINK-MID128	Lead, ppb	1.5	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MID129	2/23/2018	5:45:00	MID-FL2-2243-DF-MID129	Lead, ppb	<1	Less than detection level
MID130	2/23/2018	5:47:00	MID-FL2-2242-SINK-MID130	Lead, ppb	3.26	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MID131	2/23/2018	5:47:00	MID-FL2-2242-DF-MID131	Lead, ppb	<1	Less than detection level
MID132	2/23/2018	5:49:00	MID-FL2-2241-SINK-MID132	Lead, ppb	<1	Less than detection level
MID133	2/23/2018	5:49:00	MID-FL2-2241-DF-MID133	Lead, ppb	<1	Less than detection level

Cincinnati Public Schools - Midway School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
MID134	2/23/2018	5:51:00	MID-FL2-2234FRONTDESK-SINK-MID134	Lead, ppb	2.18	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MID135	2/23/2018	5:51:00	MID-FL2-2234LWALL-LSINK-MID135	Lead, ppb	2.1	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MID136	2/23/2018	5:51:00	MID-FL2-2234LWALL-LDF-MID136	Lead, ppb	<1	Less than detection level
MID137	2/23/2018	5:53:00	MID-FL2-2234LWALL-RSINK-MID137	Lead, ppb	2.64	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MID138	2/23/2018	5:53:00	MID-FL2-2234RWALL-LSINK-MID138	Lead, ppb	3.24	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MID139	2/23/2018	5:53:00	MID-FL2-2234RWALL-RSINK-MID139	Lead, ppb	1.3	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MID140	2/23/2018	5:54:00	MID-FL2-2232-SINK-MID140	Lead, ppb	2.24	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.