



June 1, 2018

## Mt. Airy School

Cincinnati Public Schools  
Cynthia Eghbalnia  
2651 Burnet Avenue  
Cincinnati, OH 45219

Dear Cynthia:

Thank you for taking the responsibility seriously to protect the health of the children by voluntarily testing the water in your school for lead!

Attached please find the results of the lead analyses performed for Mt. Airy School by the Greater Cincinnati Water Works (GCWW). The following comments speak to the process, samples analyzed and additional steps needed to help ensure the safety of all the students within the school.

### **School Sampling Process and Results**

GCWW and Cincinnati Public Schools (CPS) staff worked together to finalize a sampling plan for the school. The *USEPA 3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance Document (3Ts Guidelines)* is the process and guidelines used for assisting schools with testing for lead.

In April, one hundred, thirty (130) samples were collected from drinking fountains, sinks and cooking outlets throughout the school. Multiple sinks within the schools were not initially considered for testing, however, key nearby indicators (coffee makers, drinking cups, plates, utensils, etc.) prompted additional locations to be tested in the schools. Including these sampling locations speaks to the proactive approach CPS continues to have towards understanding the water quality within the schools. Four additional locations were not sampled. The results show the following:

- 106 samples (81.54%), below the detection level (<1)
- 17 samples (13.08%), between 1ppb and 5ppb
- 3 samples (2.3%), between 5ppb and 10ppb
- 2 samples (1.54%), between 10ppb and 15ppb
- 2 samples (1.54%), greater than 15ppb.

Ninety-eight percent (98.46%) of the results were below the detection level or below the federal action level.

Fifteen parts per billion (ppb) is the federal Lead and Copper Rule action level; desired results are below 15. The federal action level of 15ppb pertains to water utilities and GCWW's review and comments are based on this action level. However, the USEPA 3Ts Guidelines document outlines practices for schools to put in place if samples are greater than 20 ppb.

While we strive to have results less than 15, we recognize that lead is a pervasive environmental contaminant, and no safe blood lead threshold has been identified in children or adults. Therefore, we provide recommendations to further reduce any lead levels discovered in your school.



### Next steps


GCWW has reviewed the results from your samples and provides some next-steps comments.

1. Great news! All the drinking fountains and bottle fillers had results below the detection level for lead except for one location, MTA-FL1-HALLWAYNEAR1040/1042-LCOMBOBF-MTA20. This location had a trace amount of lead. The amount is very low, however, flushing the line before use (letting the water run) will reduce the risk of lead. No further action is suggested.
2. Three locations had lead detections at or greater than 15ppb,
  - MTA-FL1-1097RR-SINK-MTA46,
  - MTA-FL1-ELA1081RR-SINK-MTA58 and
  - MTA-FL1-ELA1082RR-SINK-MTA59.Two of the three sinks in room ELA108 (extended learning area) had high lead detections. These locations are sinks and it is assumed by the names that they are not used as drinking water or cooking outlets. However, consider an immediate remedy such as taking the sample locations out of service until a more defined plan can be created or post a sign limiting the use at these locations. Refer to the USEPA 3Ts Guidelines for more information and suggestions on signage. After the location is out of service, work to reduce the lead level by first removing and cleaning the aerator as particles may be trapped on the aerator and contributing to the lead detection. Consider resampling after the cleaning.
3. Three (3) of the ten (10) sample locations in the kitchen had low lead detections. Flush the line before use if using these locations for food and drink preparation. No further action is suggested.
4. Several other sinks had lead detections. Based on the names, these are not used for drinking water or cooking purposes.
  - a. Lead is not an issue for body contact such as bathing, showering, and washing hands.
  - a. To lower the lead levels, consider removing and cleaning the aerator. Particles may be trapped on the aerator and contributing to the lead level.
  - b. If the locations with lead detections are not used on a regular basis, then the infrequent use may be contributing to the lead detections.
5. Review how water is being used within your facility. Again, if water is not used on a regular basis at some of these locations, the infrequent use at the outlet may be contributing to the lead detections. Signage at these locations may be helpful (hand washing only, science class purposes only-no drinking, etc.).
6. If it hasn't occurred already, a robust communications plan is suggested. Communications plan steps are outlined in the 3Ts Guidelines. This plan will inform the school community of the sampling work the school has done to date and the steps the school will take to correct any issues discovered. GCWW employees can assist with this plan and are available to attend any school meetings to help explain our lead program, the sample results and our partnership with your school. Suggestions for language and a letter template can be provided if needed. Sampling results will be posted on the GCWW [lead.mygcww.org](http://lead.mygcww.org) website with other school sampling results.

Greater Cincinnati Water Works takes the presence of lead service lines and the removal of those service lines in our system very seriously. In addition, minimizing the exposure of lead within our preschools, schools, and daycares is one of our highest priorities under our Enhanced Lead Program. Please contact Jim Nelson at 591-6869 if you have any questions.

Thanks again for your partnership with Greater Cincinnati Water Works and your work to further understand the water quality within your building. Your extra steps and care to keep the children in our community safe are appreciated!

Sincerely,

A handwritten signature in black ink that reads "Cathy B. Bailey". The signature is written in a cursive style with a large initial 'C'.

Cathy B. Bailey  
Director/Greater Cincinnati Water Works

Cc: Dr. Marilyn Crumpton, Cincinnati Health Department  
Dr. Camille Jones, Cincinnati Health Department  
Chuck DeJonckheere, Hamilton County Public Health  
Sheila Hill-Christian, City of Cincinnati  
Verna Arnette, Greater Cincinnati Water Works  
Jeff Swertfeger, Greater Cincinnati Water Works  
Jason DeLaet, Greater Cincinnati Water Works  
James Nelson, Greater Cincinnati Water Works

### Cincinnati Public Schools - Mt. Airy School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
MTA1	4/26/2018	5:11	MTA-KIT-NEARSERVE-HANDSINK-MTA1	Lead, ppb	1.57	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MTA2	4/26/2018	5:12	MTA-KIT-STOCKPOT-LFILLER-MTA2	Lead, ppb	4.35	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MTA3	4/26/2018	5:13	MTA-KIT-STOCKPOT-RFILLER-MTA3	Lead, ppb	2.02	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MTA4	4/26/2018	5:14	MTA-KIT-2TUB-SINK-MTA4	Lead, ppb	<1	Less than detection level
MTA5	4/26/2018	5:15	MTA-KIT-1TUB-SINK-MTA5	Lead, ppb	<1	Less than detection level
MTA6	4/26/2018	5:16	MTA-KIT-128STAFFRR-SINK-MTA6	Lead, ppb	<1	Less than detection level
MTA7	4/26/2018	5:17	MTA-KIT-DISHRM3TUB-LSINK-MTA7	Lead, ppb	<1	Less than detection level
MTA8	4/26/2018	5:18	MTA-KIT-DISHRM3TUB-RSINK-MTA8	Lead, ppb	<1	Less than detection level
MTA9	4/26/2018	5:19	MTA-KIT-NEAR1035-HANDSINK-MTA9	Lead, ppb	<1	Less than detection level
MTA10	4/26/2018	5:20	MTA-FL1-1014GIRLSLOCK-DF-MTA10	Lead, ppb	<1	Less than detection level
MTA11	4/26/2018	5:21	MTA-FL1-1014GIRLSLOCK-LSINK-MTA11	Lead, ppb	1.73	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MTA12	4/26/2018	5:22	MTA-FL1-1014GIRLSLOCK-MSINK-MTA12	Lead, ppb	<1	Less than detection level
MTA13	4/26/2018	5:23	MTA-FL1-1014GIRLSLOCK-RSINK-MTA13	Lead, ppb	<1	Less than detection level
MTA14	4/26/2018	5:24	MTA-FL1-1019BOYSLOCK-DF-MTA14	Lead, ppb	<1	Less than detection level
MTA15	4/26/2018	5:25	MTA-FL1-1019BOYSLOCK-LSINK-MTA15	Lead, ppb	<1	Less than detection level
MTA16	4/26/2018	5:26	MTA-FL1-1019BOYSLOCK-MSINK-MTA16	Lead, ppb	<1	Less than detection level
MTA17	4/26/2018	5:27	MTA-FL1-1019BOYSLOCK-RSINK-MTA17	Lead, ppb	<1	Less than detection level
MTA18	4/26/2018	5:28	MTA-FL1-1016PEOFFRR-SINK-MTA18	Lead, ppb	<1	Less than detection level
MTA19	4/26/2018	5:31	MTA-FL1-HALLWAYNEAR1040/1042-LCOMBODF-MTA19	Lead, ppb	<1	Less than detection level
MTA20	4/26/2018	5:32	MTA-FL1-HALLWAYNEAR1040/1042-LCOMBOBF-MTA20	Lead, ppb	1.1	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MTA21	4/26/2018	5:33	MTA-FL1-HALLWAYNEAR1040/1042-RDF-MTA21	Lead, ppb	<1	Less than detection level

**Cincinnati Public Schools - Mt. Airy School - Lead Testing Results**

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
MTA22	4/26/2018	5:34	MTA-FL1-1040GIRLSRR-LSINK-MTA22	Lead, ppb	3.05	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MTA23	4/26/2018	5:35	MTA-FL1-1040GIRLSRR-MSINK-MTA23	Lead, ppb	<1	Less than detection level
MTA24	4/26/2018	5:36	MTA-FL1-1040GIRLSRR-RSINK-MTA24	Lead, ppb	<1	Less than detection level
MTA25	4/26/2018	5:37	MTA-FL1-1042BOYSRR-LSINK-MTA25	Lead, ppb	<1	Less than detection level
MTA26	4/26/2018	5:38	MTA-FL1-1042BOYSRR-MSINK-MTA26	Lead, ppb	<1	Less than detection level
MTA27	4/26/2018	5:39	MTA-FL1-1042BOYSRR-RSINK-MTA27	Lead, ppb	<1	Less than detection level
MTA28	4/26/2018	5:40	MTA-FL1-1004WKRM-SINK-MTA28	Lead, ppb	<1	Less than detection level
MTA29	4/26/2018	5:41	MTA-FL1-1110OFFRR-SINK-MTA29	Lead, ppb	<1	Less than detection level
MTA30	4/26/2018	5:42	MTA-FL1-1109RR-SINK-MTA30	Lead, ppb	<1	Less than detection level
MTA31	4/26/2018	5:44	MTA-FL1-1112MAILRM-SINK-MTA31	Lead, ppb	<1	Less than detection level
MTA32	4/26/2018	5:46	MTA-FL1-1102HEALTHRR-SINK-MTA32	Lead, ppb	<1	Less than detection level
MTA33	4/26/2018	5:47	MTA-FL1-1102HEALTHEXAM1-SINK-MTA33	Lead, ppb	<1	Less than detection level
MTA34	4/26/2018	5:48	MTA-FL1-1102HEALTHEXAM2-SINK-MTA34	Lead, ppb	<1	Less than detection level
MTA35	4/26/2018	5:49	MTA-FL1-1102HEALTH-IM-MTA35	Lead, ppb	<1	Less than detection level
MTA36	4/26/2018	5:50	MTA-FL1-1102HEALTH-SINK-MTA36	Lead, ppb	<1	Less than detection level
MTA37	4/26/2018	5:53	MTA-FL1-1043COMMRMLWALL-SINK-MTA37	Lead, ppb	3.38	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MTA38	4/26/2018	5:54	MTA-FL1-1043COMMRMRWALL-SINK-MTA38	Lead, ppb	<1	Less than detection level
MTA39	4/26/2018	5:55	MTA-FL1-ELA1090-SINK-MTA39	Lead, ppb	<1	Less than detection level
MTA40	4/26/2018	5:56	MTA-FL1-ELA1090-DF-MTA40	Lead, ppb	<1	Less than detection level
MTA41	4/26/2018	5:57	MTA-FL1-1099-SINK-MTA41	Lead, ppb	<1	Less than detection level
MTA42	4/26/2018	5:58	MTA-FL1-1099-DF-MTA42	Lead, ppb	<1	Less than detection level
MTA43	4/26/2018	5:59	MTA-FL1-1099RR-SINK-MTA43	Lead, ppb	<1	Less than detection level
MTA44	4/26/2018	6:00	MTA-FL1-1097-SINK-MTA44	Lead, ppb	5.57	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MTA45	4/26/2018	6:01	MTA-FL1-1097-DF-MTA45	Lead, ppb	<1	Less than detection level

### Cincinnati Public Schools - Mt. Airy School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
MTA46	4/26/2018	6:02	MTA-FL1-1097RR-SINK-MTA46	Lead, ppb	23.2	Above 15ppb federal action level and the 20ppb trigger level to take action as explained in the USEPA 3Ts Guidelines for schools. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
MTA47	4/26/2018	6:03	MTA-FL1-1095-SINK-MTA47	Lead, ppb	<1	Less than detection level
MTA48	4/26/2018	6:04	MTA-FL1-1095-DF-MTA48	Lead, ppb	<1	Less than detection level
MTA49	4/26/2018	6:05	MTA-FL1-1095RR-SINK-MTA49	Lead, ppb	<1	Less than detection level
MTA50	4/26/2018	6:06	MTA-FL1-1093-SINK-MTA50	Lead, ppb	<1	Less than detection level
MTA51	4/26/2018	6:07	MTA-FL1-1093-DF-MTA51	Lead, ppb	<1	Less than detection level
MTA52	4/26/2018	6:08	MTA-FL1-1093RR-SINK-MTA52	Lead, ppb	<1	Less than detection level
MTA53	4/26/2018	6:09	MTA-FL1-1091-SINK-MTA53	Lead, ppb	<1	Less than detection level
MTA54	4/26/2018	6:10	MTA-FL1-1091-DF-MTA54	Lead, ppb	<1	Less than detection level
MTA55	4/26/2018	6:11	MTA-FL1-1091RR-SINK-MTA55	Lead, ppb	<1	Less than detection level
MTA56	4/26/2018	5:12	MTA-FL1-ELA1080-SINK-MTA56	Lead, ppb	<1	Less than detection level
MTA57	4/26/2018	5:12	MTA-FL1-ELA1080-DF-MTA57	Lead, ppb	<1	Less than detection level
MTA58	4/26/2018	5:14	MTA-FL1-ELA1081RR-SINK-MTA58	Lead, ppb	165	Above 15ppb federal action level and the 20ppb trigger level to take action as explained in the USEPA 3Ts Guidelines for schools. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
MTA59	4/26/2018	5:14	MTA-FL1-ELA1082RR-SINK-MTA59	Lead, ppb	15	At the 15ppb federal action level. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
MTA60	4/26/2018	5:14	MTA-FL1-ELA1083RR-SINK-MTA60	Lead, ppb	<1	Less than detection level
MTA61	4/26/2018	5:17	MTA-FL1-1084-SINK-MTA61	Lead, ppb	<1	Less than detection level

**Cincinnati Public Schools - Mt. Airy School - Lead Testing Results**

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
MTA62	4/26/2018	5:17	MTA-FL1-1084-DF-MTA62	Lead, ppb	<1	Less than detection level
MTA63	4/26/2018	5:19	MTA-FL1-1085-SINK-MTA63	Lead, ppb	<1	Less than detection level
MTA64	4/26/2018	5:19	MTA-FL1-1085-DF-MTA64	Lead, ppb	<1	Less than detection level
MTA65	4/26/2018	5:18	MTA-FL1-1086-SINK-MTA65	Lead, ppb	<1	Less than detection level
MTA66	4/26/2018	5:18	MTA-FL1-1086-DF-MTA66	Lead, ppb	<1	Less than detection level
MTA67	4/26/2018	5:20	MTA-FL1-1087-SINK-MTA67	Lead, ppb	<1	Less than detection level
MTA68	4/26/2018	5:20	MTA-FL1-1087-DF-MTA68	Lead, ppb	<1	Less than detection level
MTA69	4/26/2018	5:21	MTA-FL1-1048STAFFLOUNGE-LSINK-MTA69	Lead, ppb	13.5	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MTA70	4/26/2018	5:21	MTA-FL1-1048STAFFLOUNGE-RSINK-MTA70	Lead, ppb	<1	Less than detection level
MTA71	4/26/2018	5:21	MTA-FL1-1048STAFFLOUNGERR-SINK-MTA71	Lead, ppb	<1	Less than detection level
MTA72	4/26/2018	5:22	MTA-FL1-ELA1065-SINK-MTA72	Lead, ppb	1.2	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MTA73	4/26/2018	5:22	MTA-FL1-ELA1065-DF-MTA73	Lead, ppb	<1	Less than detection level
MTA74	4/26/2018	5:23	MTA-FL1-ELA1070RR-SINK-MTA74	Lead, ppb	<1	Less than detection level
MTA75	4/26/2018	5:23	MTA-FL1-ELA1071RR-SINK-MTA75	Lead, ppb	<1	Less than detection level
MTA76	4/26/2018	5:23	MTA-FL1-ELA1072RR-SINK-MTA76	Lead, ppb	7.76	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MTA77	4/26/2018	5:25	MTA-FL1-1069-SINK-MTA77	Lead, ppb	1.13	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MTA78	4/26/2018	5:25	MTA-FL1-1069-DF-MTA78	Lead, ppb	<1	Less than detection level
MTA79	4/26/2018	5:26	MTA-FL1-1068-SINK-MTA79	Lead, ppb	<1	Less than detection level
MTA80	4/26/2018	5:26	MTA-FL1-1068-DF-MTA80	Lead, ppb	<1	Less than detection level
MTA81	4/26/2018	5:27	MTA-FL1-1067-SINK-MTA81	Lead, ppb	1.61	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MTA82	4/26/2018	5:27	MTA-FL1-1067-DF-MTA82	Lead, ppb	<1	Less than detection level

### Cincinnati Public Schools - Mt. Airy School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
MTA83	4/26/2018	5:28	MTA-FL1-1066-SINK-MTA83	Lead, ppb	<1	Less than detection level
MTA84	4/26/2018	5:28	MTA-FL1-1066-DF-MTA84	Lead, ppb	<1	Less than detection level
MTA85	4/26/2018	5:29	MTA-FL1-ELA1056-SINK-MTA85	Lead, ppb	<1	Less than detection level
MTA86	4/26/2018	5:29	MTA-FL1-ELA1056-DF-MTA86	Lead, ppb	<1	Less than detection level
MTA87	4/26/2018	5:31	MTA-FL1-ELA1061RR-SINK-MTA87	Lead, ppb	<1	Less than detection level
MTA88	4/26/2018	5:31	MTA-FL1-ELA1062RR-SINK-MTA88	Lead, ppb	<1	Less than detection level
MTA89	4/26/2018	5:32	MTA-FL1-ELA1063RR-SINK-MTA89	Lead, ppb	<1	Less than detection level
MTA90	4/26/2018	5:32	MTA-FL1-1060-SINK-MTA90	Lead, ppb	1.09	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MTA91	4/26/2018	5:33	MTA-FL1-1060-DF-MTA91	Lead, ppb	<1	Less than detection level
MTA92	4/26/2018	5:33	MTA-FL1-1059-SINK-MTA92	Lead, ppb	<1	Less than detection level
MTA93	4/26/2018	5:33	MTA-FL1-1059-DF-MTA93	Lead, ppb	<1	Less than detection level
MTA94	4/26/2018	5:34	MTA-FL1-1058-SINK-MTA94	Lead, ppb	<1	Less than detection level
MTA95	4/26/2018	5:34	MTA-FL1-1058-DF-MTA95	Lead, ppb	<1	Less than detection level
MTA96	4/26/2018	5:35	MTA-FL1-1057-SINK-MTA96	Lead, ppb	<1	Less than detection level
MTA97	4/26/2018	5:35	MTA-FL1-1057-DF-MTA97	Lead, ppb	<1	Less than detection level
MTA98	4/26/2018	5:37	MTA-FL1-1054ART-LSINK-MTA98	Lead, ppb	<1	Less than detection level
MTA99	4/26/2018	5:37	MTA-FL1-1054ART-MSINK-MTA99	Lead, ppb	1.35	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MTA100	4/26/2018	5:37	MTA-FL1-1054ART-RSINK-MTA100	Lead, ppb	1.44	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MTA101	4/26/2018	5:40	MTA-FL2-HALLWAYNEAR2028-LDF-MTA101	Lead, ppb	<1	Less than detection level
MTA102	4/26/2018	5:40	MTA-FL2-HALLWAYNEAR2028-RDF-MTA102	Lead, ppb	<1	Less than detection level
MTA103	4/26/2018	5:42	MTA-FL2-ELA2001-SINK-MTA103	Lead, ppb	<1	Less than detection level
MTA104	4/26/2018	5:43	MTA-FL2-ELA2006RR-SINK-MTA104	Lead, ppb	7.32	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MTA105	4/26/2018	5:43	MTA-FL2-ELA2007RR-SINK-MTA105	Lead, ppb	<1	Less than detection level
MTA106	4/26/2018	5:43	MTA-FL2-ELA2008RR-SINK-MTA106	Lead, ppb	<1	Less than detection level



**Cincinnati Public Schools - Mt. Airy School - Lead Testing Results**

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
MTA107	4/26/2018	5:45	MTA-FL2-2002-SINK-MTA107	Lead, ppb	<1	Less than detection level
MTA108	4/26/2018	5:45	MTA-FL2-2003-SINK-MTA108	Lead, ppb	<1	Less than detection level
MTA109	4/26/2018	5:46	MTA-FL2-2004-SINK-MTA109	Lead, ppb	<1	Less than detection level
MTA110	4/26/2018	5:46	MTA-FL2-2005-SINK-MTA110	Lead, ppb	1.44	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MTA111	4/26/2018	5:47	MTA-FL2-2028-SINK-MTA111	Lead, ppb	<1	Less than detection level
MTA112	4/26/2018	5:48	MTA-FL2-ELA2009-SINK-MTA112	Lead, ppb	1.29	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MTA113	4/26/2018	5:49	MTA-FL2-ELA2014RR-SINK-MTA113	Lead, ppb	<1	Less than detection level
MTA114	4/26/2018	5:49	MTA-FL2-ELA2015RR-SINK-MTA114	Lead, ppb	<1	Less than detection level
MTA115	4/26/2018	5:49	MTA-FL2-ELA2016RR-SINK-MTA115	Lead, ppb	<1	Less than detection level
MTA116	4/26/2018	5:50	MTA-FL2-2013-SINK-MTA116	Lead, ppb	<1	Less than detection level
MTA117	4/26/2018	5:50	MTA-FL2-2012-SINK-MTA117	Lead, ppb	<1	Less than detection level
MTA118	4/26/2018	5:51	MTA-FL2-2011-SINK-MTA118	Lead, ppb	<1	Less than detection level
MTA119	4/26/2018	5:51	MTA-FL2-2010-SINK-MTA119	Lead, ppb	<1	Less than detection level
MTA120	4/26/2018	5:53	MTA-FL2-ELA2017-SINK-MTA120	Lead, ppb	2.86	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MTA121	4/26/2018	5:54	MTA-FL2-ELA2018RR-SINK-MTA121	Lead, ppb	<1	Less than detection level
MTA122	4/26/2018	5:54	MTA-FL2-ELA2019RR-SINK-MTA122	Lead, ppb	<1	Less than detection level
MTA123	4/26/2018	5:54	MTA-FL2-ELA2020RR-SINK-MTA123	Lead, ppb	<1	Less than detection level
MTA124	4/26/2018	5:55	MTA-FL2-2021-SINK-MTA124	Lead, ppb	<1	Less than detection level
MTA125	4/26/2018	5:55	MTA-FL2-2022-SINK-MTA125	Lead, ppb	<1	Less than detection level
MTA126	4/26/2018	5:56	MTA-FL2-2023-SINK-MTA126	Lead, ppb	2.86	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
MTA127	4/26/2018	5:56	MTA-FL2-2024-SINK-MTA127	Lead, ppb	<1	Less than detection level
MTA128	4/26/2018	5:58	MTA-FL2-2026LWALL-LSINK-MTA128	Lead, ppb	<1	Less than detection level
MTA129	4/26/2018	5:58	MTA-FL2-2026RWALL-LSINK-MTA129	Lead, ppb	<1	Less than detection level
MTA130	4/26/2018	5:59	MTA-KIT-NEARSTOCKPOT-HANDSINK-MTA130	Lead, ppb	<1	Less than detection level

**Cincinnati Public Schools - Mt. Airy School - Lead Testing Results**

<b>SAMPLE #</b>	<b>SAMPLE DATE</b>	<b>SAMPLE TIME</b>	<b>SAMPLE</b>	<b>PARAMETER, CODE</b>	<b>AMOUNT</b>	<b>GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS</b>
N/A	N/A	N/A	MTA-FL2-2026FRONTDESK-SINK	Lead, ppb	N/A	Not sampled; out of service at the time of walkthrough.
N/A	N/A	N/A	MTA-FL2-2026LWALL-MSINK	Lead, ppb	N/A	Not sampled; out of service at the time of walkthrough.
N/A	N/A	N/A	MTA-FL2-2026LWALL-RSINK	Lead, ppb	N/A	Not sampled; out of service at the time of walkthrough.
N/A	N/A	N/A	MTA-FL2-2026RWALL-RSINK	Lead, ppb	N/A	Not sampled; out of service at the time of walkthrough.