



May 25, 2018

Cincinnati Public Schools  
Cynthia Eghbalnia  
2651 Burnet Avenue  
Cincinnati, OH 45219

**Pleasant Ridge  
Montessori School**

Dear Cynthia:

Thank you for taking the responsibility seriously to protect the health of the children by voluntarily testing the water in your school for lead!

Attached please find the results of the lead analyses performed for Pleasant Ridge Montessori School by the Greater Cincinnati Water Works (GCWW). The following comments speak to the process, samples analyzed and additional steps needed to help ensure the safety of all the students within the school.

**School Sampling Process and Results**

GCWW and Cincinnati Public Schools (CPS) staff worked together to finalize a sampling plan for the school. The *USEPA 3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance Document (3Ts Guidelines)* is the process and guidelines used for assisting schools with testing for lead.

In January, one hundred, twenty-six (126) samples were collected from drinking fountains, sinks and cooking outlets throughout the school. Multiple sinks within the schools were not initially considered for testing, however, key nearby indicators (coffee makers, drinking cups, plates, utensils, etc.) prompted additional locations to be tested in the schools. Including these sampling locations speaks to the proactive approach CPS continues to have towards understanding the water quality within the schools. Five additional locations were not sampled. The results show the following:

- 91 samples (72.22%), below the detection level (<1)
- 28 samples (22.22%), between 1ppb and 5ppb
- 4 samples (3.18%), between 5ppb and 10ppb
- 2 samples (1.59%), between 10ppb and 15ppb
- 1 sample (0.79%), greater than 15ppb.

Ninety-nine percent (99%) of the results were below the detection level or below the federal action level.

Fifteen parts per billion (ppb) is the federal Lead and Copper Rule action level; desired results are below 15. The federal action level of 15ppb pertains to water utilities and GCWW's review and comments are based on this action level. However, the USEPA 3Ts Guidelines document outlines practices for schools to put in place if samples are greater than 20 ppb.

While we strive to have results less than 15, we recognize that lead is a pervasive environmental contaminant, and no safe blood lead threshold has been identified in children or adults. Therefore, we provide recommendations to further reduce any lead levels discovered in your school.



### Next steps


GCWW has reviewed the results from your samples and provides some next-steps comments.

1. Good news! The majority of the drinking fountains and bottle fillers had no lead detections. Two locations, PRM-FL2-2204-DF-PRM99 and PRM-FL3-3304-DF-PRM127, had lead detections. To lower these levels, flush the line (let the water run) before use. No further action is suggested.
2. One location had a lead detection greater than 15ppb, PRM-FL2-2204-SINK-PRM98. This location is a sink and it is assumed by the name that it is not used as a drinking water or cooking outlet. However, consider an immediate remedy such as taking the sample location out of service until a more defined plan can be created or post a sign limiting the use at this location. Refer to the USEPA 3Ts Guidelines for more information and suggestions on signage. After the location is out of service, work to reduce the lead level by first removing and cleaning the aerator as particles may be trapped on the aerator and contributing to the lead detection. Consider resampling after the cleaning.
3. Seven (7) of the ten (10) sample locations in the kitchen had lead detections. Most of these locations had low lead levels. Flush the line before use if using these locations for food and drink preparation. No further action is suggested.
4. Several other sinks had low lead detections. Based on the names, these are not used for drinking water or cooking purposes.
  - a. Lead is not an issue for body contact such as bathing, showering, and washing hands.
  - a. To lower the lead levels, consider removing and cleaning the aerator. Particles may be trapped on the aerator and contributing to the lead level.
  - b. If the locations with lead detections are not used on a regular basis, then the infrequent use may be contributing to the lead detections.
5. Review how water is being used within your facility. Again, if water is not used on a regular basis at some of these locations, again, the infrequent use at the outlet may be contributing to the lead detections. Signage at these locations may be helpful (hand washing only, science class purposes only-no drinking, etc.).
6. If it hasn't occurred already, a robust communications plan is suggested. Communications plan steps are outlined in the 3Ts Guidelines. This plan will inform the school community of the sampling work the school has done to date and the steps the school will take to correct any issues discovered. GCWW employees can assist with this plan and are available to attend any school meetings to help explain our lead program, the sample results and our partnership with your school. Suggestions for language and a letter template can be provided if needed. Sampling results will be posted on the GCWW [lead.mycgww.org](http://lead.mycgww.org) website with other school sampling results.

Greater Cincinnati Water Works takes the presence of lead service lines and the removal of those service lines in our system very seriously. In addition, minimizing the exposure of lead within our preschools, schools, and daycares is one of our highest priorities under our Enhanced Lead Program. Please contact Jim Nelson at 591-6869 if you have any questions.

Thanks again for your partnership with Greater Cincinnati Water Works and your work to further understand the water quality within your building. Your extra steps and care to keep the children in our community safe are appreciated!

Sincerely,



Cathy B. Bailey  
Director/Greater Cincinnati Water Works

Cc: Dr. Marilyn Crumpton, Cincinnati Health Department  
Dr. Camille Jones, Cincinnati Health Department  
Chuck DeJonckheere, Hamilton County Public Health  
Patrick Duhaney, City of Cincinnati  
Verna Arnette, Greater Cincinnati Water Works  
Jeff Swertfeger, Greater Cincinnati Water Works  
Jason DeLaet, Greater Cincinnati Water Works  
James Nelson, Greater Cincinnati Water Works

### Cincinnati Public Schools - Pleasant Ridge Montessori - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
PRM1	1/26/2018	5:07:00	PRM-FL1-ELA1109-SINK-PRM1	Lead, ppb	3.37	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PRM2	1/26/2018	5:07:00	PRM-FL1-ELA1109-DF-PRM2	Lead, ppb	<1	Less than detection level
PRM3	1/26/2018	5:09:00	PRM-FL1-1101-SINK-PRM3	Lead, ppb	<1	Less than detection level
PRM4	1/26/2018	5:09:00	PRM-FL1-1101-DF-PRM4	Lead, ppb	<1	Less than detection level
PRM5	1/26/2018	5:09:00	PRM-FL1-1101RR-SINK-PRM5	Lead, ppb	1.22	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PRM6	1/26/2018	5:09:00	PRM-FL1-1105-SINK-PRM6	Lead, ppb	2.77	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PRM7	1/26/2018	5:13:00	PRM-FL1-1105-DF-PRM7	Lead, ppb	<1	Less than detection level
PRM8	1/26/2018	5:13:00	PRM-FL1-1105RR-SINK-PRM8	Lead, ppb	<1	Less than detection level
PRM9	1/26/2018	5:13:00	PRM-FL1-BOYSRRNEAR1109-SINK-PRM9	Lead, ppb	<1	Less than detection level
PRM10	1/26/2018	5:15:00	PRM-FL1-GIRLSRRNEAR1109-SINK-PRM10	Lead, ppb	<1	Less than detection level
PRM11	1/26/2018	5:17:00	PRM-FL1-BOYSRRNEAR1119-SINK-PRM11	Lead, ppb	<1	Less than detection level
PRM12	1/26/2018	5:17:00	PRM-FL1-GIRLSRRNEAR1119-SINK-PRM12	Lead, ppb	<1	Less than detection level
PRM13	1/26/2018	5:19:00	PRM-FL1-1115-SINK-PRM13	Lead, ppb	<1	Less than detection level
PRM14	1/26/2018	5:19:00	PRM-FL1-1115-DF-PRM14	Lead, ppb	<1	Less than detection level
PRM15	1/26/2018	5:21:00	PRM-FL1-1117-SINK-PRM15	Lead, ppb	<1	Less than detection level
PRM16	1/26/2018	5:21:00	PRM-FL1-1117-DF-PRM16	Lead, ppb	<1	Less than detection level
PRM17	1/26/2018	5:22:00	PRM-FL1-ELA1119-SINK-PRM17	Lead, ppb	1.38	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PRM18	1/26/2018	5:22:00	PRM-FL1-ELA1119-DF-PRM18	Lead, ppb	<1	Less than detection level
PRM19	1/26/2018	5:24:00	PRM-FL1-1121-SINK-PRM19	Lead, ppb	<1	Less than detection level

### Cincinnati Public Schools - Pleasant Ridge Montessori - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
PRM20	1/26/2018	5:24:00	PRM-FL1-1121-DF-PRM20	Lead, ppb	<1	Less than detection level
PRM21	1/26/2018	5:25:00	PRM-FL1-1134LIBRARY-SINK-PRM21	Lead, ppb	<1	Less than detection level
PRM22	1/26/2018	5:28:00	PRM-FL1-1141ART-LSINK-PRM22	Lead, ppb	<1	Less than detection level
PRM23	1/26/2018	5:28:00	PRM-FL1-1141ART-MSINK-PRM23	Lead, ppb	<1	Less than detection level
PRM24	1/26/2018	5:28:00	PRM-FL1-1141ART-RSINK-PRM24	Lead, ppb	<1	Less than detection level
PRM25	1/26/2018	5:31:00	PRM-FL1-1147MUSIC-SINK-PRM25	Lead, ppb	2.66	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PRM26	1/26/2018	5:31:00	PRM-FL1-1147MUSIC-DF-PRM26	Lead, ppb	<1	Less than detection level
PRM27	1/26/2018	5:34:00	PRM-FL1-1154STAFFDINE-SINK-PRM27	Lead, ppb	<1	Less than detection level
PRM28	1/26/2018	5:37:00	PRM-FL1-KITNEAR2TUB-HANDSINK-PRM28	Lead, ppb	1.09	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PRM29	1/26/2018	5:39:00	PRM-FL1-KIT2TUB-SINK-PRM29	Lead, ppb	<1	Less than detection level
PRM30	1/26/2018	5:40:00	PRM-FL1-KITSTOCKPOT-LFILLER-PRM30	Lead, ppb	4.37	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PRM31	1/26/2018	5:41:00	PRM-FL1-KITSTOCKPOT-RFILLER-PRM31	Lead, ppb	1.02	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PRM32	1/26/2018	5:42:00	PRM-FL1-KITNEARSERVE-HANDSINK-PRM32	Lead, ppb	1.53	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PRM33	1/26/2018	5:44:00	PRM-FL1-KIT1TUB-SINK-PRM33	Lead, ppb	1.34	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

### Cincinnati Public Schools - Pleasant Ridge Montessori - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
PRM34	1/26/2018	5:44:00	PRM-FL1-KIT1164STAFFLOCKRR-SINK-PRM34	Lead, ppb	1.21	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PRM35	1/26/2018	5:45:00	PRM-FL1-KITDISHRM3TUB-LSINK-PRM35	Lead, ppb	<1	Less than detection level
PRM36	1/26/2018	5:45:00	PRM-FL1-KITDISHRM3TUB-RSINK-PRM36	Lead, ppb	1.04	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PRM37	1/26/2018	5:46:00	PRM-FL1-KITDISHRM-HANDSINK-PRM37	Lead, ppb	<1	Less than detection level
PRM38	1/26/2018	5:49:00	PRM-FL1-GYMGIRLSLOCK-LSINK-PRM38	Lead, ppb	<1	Less than detection level
PRM39	1/26/2018	5:49:00	PRM-FL1-GYMGIRLSLOCK-RSINK-PRM39	Lead, ppb	10.1	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PRM40	1/26/2018	5:49:00	PRM-FL1-GYMGIRLSLOCK-DF-PRM40	Lead, ppb	<1	Less than detection level
PRM41	1/26/2018	5:52:00	PRM-FL1-GYMBOYSLOCK-LSINK-PRM41	Lead, ppb	<1	Less than detection level
PRM42	1/26/2018	5:52:00	PRM-FL1-GYMBOYSLOCK-RSINK-PRM42	Lead, ppb	<1	Less than detection level
PRM43	1/26/2018	5:52:00	PRM-FL1-GYMBOYSLOCK-DF-PRM43	Lead, ppb	<1	Less than detection level
PRM44	1/26/2018	5:54:00	PRM-FL1-1170PEOFFRR-SINK-PRM44	Lead, ppb	<1	Less than detection level
PRM45	1/26/2018	5:55:00	PRM-FL1-GYM-LDF-PRM45	Lead, ppb	<1	Less than detection level
PRM46	1/26/2018	5:55:00	PRM-FL1-GYM-RDF-PRM46	Lead, ppb	<1	Less than detection level
PRM47	1/26/2018	5:57:00	PRM-FL1-CAFE-COMBODF-PRM47	Lead, ppb	<1	Less than detection level
PRM48	1/26/2018	5:57:00	PRM-FL1-CAFE-COMBOBF-PRM48	Lead, ppb	<1	Less than detection level
PRM49	1/26/2018	5:59:00	PRM-FL1-HALLNEAR1146STAFFRR-SINK-PRM49	Lead, ppb	<1	Less than detection level
PRM50	1/26/2018	6:00:00	PRM-FL1-1144-SINK-PRM50	Lead, ppb	1.65	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PRM51	1/26/2018	6:01:00	PRM-FL1-HALLNEAR1144-LDF-PRM51	Lead, ppb	<1	Less than detection level
PRM52	1/26/2018	6:01:00	PRM-FL1-HALLNEAR1144-RDF-PRM52	Lead, ppb	<1	Less than detection level

### Cincinnati Public Schools - Pleasant Ridge Montessori - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
PRM53	1/26/2018	5:06:00	PRM-FL1-GIRLSRRNEAR1136-LSINK-PRM53	Lead, ppb	<1	Less than detection level
PRM54	1/26/2018	5:06:00	PRM-FL1-GIRLSRRNEAR1136-MSINK-PRM54	Lead, ppb	<1	Less than detection level
PRM55	1/26/2018	5:06:00	PRM-FL1-GIRLSRRNEAR1136-RSINK-PRM55	Lead, ppb	<1	Less than detection level
PRM56	1/26/2018	5:12:00	PRM-FL1-BOYSRRNEAR1136-LSINK-PRM56	Lead, ppb	<1	Less than detection level
PRM57	1/26/2018	5:12:00	PRM-FL1-BOYSRRNEAR1136-MSINK-PRM57	Lead, ppb	<1	Less than detection level
PRM58	1/26/2018	5:12:00	PRM-FL1-BOYSRRNEAR1136-RSINK-PRM58	Lead, ppb	<1	Less than detection level
PRM59	1/26/2018	5:13:00	PRM-FL1-1136-SINK-PRM59	Lead, ppb	2.24	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PRM60	1/26/2018	5:14:00	PRM-FL1-HALLNEAR1127UNIRR-SINK-PRM60	Lead, ppb	2.3	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PRM61	1/26/2018	5:14:00	PRM-FL1-1118-SINK-PRM61	Lead, ppb	<1	Less than detection level
PRM62	1/26/2018	5:14:00	PRM-FL1-1118-DF-PRM62	Lead, ppb	<1	Less than detection level
PRM63	1/26/2018	5:19:00	PRM-FL1-1116-SINK-PRM63	Lead, ppb	<1	Less than detection level
PRM64	1/26/2018	5:19:00	PRM-FL1-1116-DF-PRM64	Lead, ppb	<1	Less than detection level
PRM65	1/26/2018	5:20:00	PRM-FL1-1107-SINK-PRM65	Lead, ppb	<1	Less than detection level
PRM66	1/26/2018	5:20:00	PRM-FL1-1107-DF-PRM66	Lead, ppb	<1	Less than detection level
PRM67	1/26/2018	5:20:00	PRM-FL1-1107RR-SINK-PRM67	Lead, ppb	<1	Less than detection level
PRM68	1/26/2018	5:21:00	PRM-FL1-1103-SINK-PRM68	Lead, ppb	<1	Less than detection level
PRM69	1/26/2018	5:21:00	PRM-FL1-1103-DF-PRM69	Lead, ppb	<1	Less than detection level
PRM70	1/26/2018	5:21:00	PRM-FL1-1103RR-SINK-PRM70	Lead, ppb	<1	Less than detection level
PRM71	1/26/2018	5:26:00	PRM-FL2-ELA2205-SINK-PRM71	Lead, ppb	<1	Less than detection level
PRM72	1/26/2018	5:26:00	PRM-FL2-ELA2205-DF-PRM72	Lead, ppb	<1	Less than detection level
PRM73	1/26/2018	5:27:00	PRM-FL2-2201-SINK-PRM73	Lead, ppb	<1	Less than detection level
PRM74	1/26/2018	5:27:00	PRM-FL2-2201-DF-PRM74	Lead, ppb	<1	Less than detection level
PRM75	1/26/2018	5:29:00	PRM-FL2-2203-SINK-PRM75	Lead, ppb	<1	Less than detection level
PRM76	1/26/2018	5:29:00	PRM-FL2-2203-DF-PRM76	Lead, ppb	<1	Less than detection level
PRM77	1/26/2018	5:30:00	PRM-FL2-GIRLSRRNEAR2205-LSINK-PRM77	Lead, ppb	<1	Less than detection level



### Cincinnati Public Schools - Pleasant Ridge Montessori - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
PRM78	1/26/2018	5:30:00	PRM-FL2-GIRLSRRNEAR2205-RSINK-PRM78	Lead, ppb	<1	Less than detection level
PRM79	1/26/2018	5:31:00	PRM-FL2-BOYSRRNEAR2205-LSINK-PRM79	Lead, ppb	<1	Less than detection level
PRM80	1/26/2018	5:31:00	PRM-FL2-BOYSRRNEAR2205-RSINK-PRM80	Lead, ppb	1.38	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PRM81	1/26/2018	5:32:00	PRM-FL2-2212-SINK-PRM81	Lead, ppb	1.65	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PRM82	1/26/2018	5:32:00	PRM-FL2-2212-DF-PRM82	Lead, ppb	<1	Less than detection level
PRM83	1/26/2018	5:33:00	PRM-FL2-2214-SINK-PRM83	Lead, ppb	<1	Less than detection level
PRM84	1/26/2018	5:33:00	PRM-FL2-2214-DF-PRM84	Lead, ppb	<1	Less than detection level
PRM85	1/26/2018	5:34:00	PRM-FL2-ELA2216-SINK-PRM85	Lead, ppb	<1	Less than detection level
PRM86	1/26/2018	5:34:00	PRM-FL2-ELA2216-DF-PRM86	Lead, ppb	<1	Less than detection level
PRM87	1/26/2018	5:35:00	PRM-FL2-2220-SINK-PRM87	Lead, ppb	<1	Less than detection level
PRM88	1/26/2018	5:35:00	PRM-FL2-2220-DF-PRM88	Lead, ppb	<1	Less than detection level
PRM89	1/26/2018	5:36:00	PRM-FL2-2226STAFFWKRM-SINK-PRM89	Lead, ppb	<1	Less than detection level
PRM90	1/26/2018	5:36:00	PRM-FL2-STAFFRRNEAR2230-SINK-PRM90	Lead, ppb	<1	Less than detection level
PRM91	1/26/2018	5:39:00	PRM-FL2-2236HEALTH-SINK-PRM91	Lead, ppb	5.44	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PRM92	1/26/2018	5:39:00	PRM-FL2-2236HEALTH-DF-PRM92	Lead, ppb	<1	Less than detection level
PRM93	1/26/2018	5:39:00	PRM-FL2-2236HEALTHRR-SINK-PRM93	Lead, ppb	11	Less than detection level
PRM94	1/26/2018	5:43:00	PRM-FL2-2215-SINK-PRM94	Lead, ppb	<1	Less than detection level
PRM95	1/26/2018	5:43:00	PRM-FL2-2215-DF-PRM95	Lead, ppb	<1	Less than detection level
PRM96	1/26/2018	5:44:00	PRM-FL2-2213-SINK-PRM96	Lead, ppb	1.02	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.



### Cincinnati Public Schools - Pleasant Ridge Montessori - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
PRM97	1/26/2018	5:44:00	PRM-FL2-2213-DF-PRM97	Lead, ppb	<1	Less than detection level
PRM98	1/26/2018	5:46:00	PRM-FL2-2204-SINK-PRM98	Lead, ppb	17	Above 15ppb federal action level. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
PRM99	1/26/2018	5:46:00	PRM-FL2-2204-DF-PRM99	Lead, ppb	5.37	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PRM100	1/26/2018	5:47:00	PRM-FL2-2202-SINK-PRM100	Lead, ppb	4.36	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PRM101	1/26/2018	5:47:00	PRM-FL2-2202-DF-PRM101	Lead, ppb	<1	Less than detection level
PRM102	1/26/2018	5:51:00	PRM-FL3-ELA3116-SINK-PRM102	Lead, ppb	<1	Less than detection level
PRM103	1/26/2018	5:51:00	PRM-FL3-ELA3116-DF-PRM103	Lead, ppb	<1	Less than detection level
PRM104	1/26/2018	5:52:00	PRM-FL3-3301-SINK-PRM104	Lead, ppb	1.37	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PRM105	N/A	N/A	PRM-FL3-3301-DF-PRM105	Lead, ppb	N/A	Not sampled; out of service at the time of sampling.
PRM106	1/26/2018	5:57:00	PRM-FL3-3303-SINK-PRM106	Lead, ppb	1.95	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PRM107	1/26/2018	5:57:00	PRM-FL3-3303-DF-PRM107	Lead, ppb	<1	Less than detection level
PRM108	1/26/2018	5:59:00	PRM-FL3-GIRLSRRNEAR3116-LSINK-PRM108	Lead, ppb	<1	Less than detection level
PRM109	1/26/2018	5:59:00	PRM-FL3-GIRLSRRNEAR3116-RSINK-PRM109	Lead, ppb	<1	Less than detection level

### Cincinnati Public Schools - Pleasant Ridge Montessori - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
PRM110	1/26/2018	6:00:00	PRM-FL3-BOYSRRNEAR3116-LSINK-PRM110	Lead, ppb	1.2	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PRM111	1/26/2018	6:00:00	PRM-FL3-BOYSRRNEAR3116-RSINK-PRM111	Lead, ppb	<1	Less than detection level
PRM112	1/26/2018	6:00:00	PRM-FL3-3312-SINK-PRM112	Lead, ppb	1.21	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PRM113	1/26/2018	6:00:00	PRM-FL3-3312-DF-PRM113	Lead, ppb	<1	Less than detection level
PRM114	1/26/2018	6:01:00	PRM-FL3-3314-SINK-PRM114	Lead, ppb	2.9	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PRM115	1/26/2018	6:01:00	PRM-FL3-3314-DF-PRM115	Lead, ppb	<1	Less than detection level
PRM116	1/26/2018	5:52:00	PRM-FL3-ELA3316-SINK-PRM116	Lead, ppb	9.28	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PRM117	1/26/2018	5:52:00	PRM-FL3-ELA3316-DF-PRM117	Lead, ppb	<1	Less than detection level
PRM118	1/26/2018	6:04:00	PRM-FL3-3319LWALL-SINK-PRM118	Lead, ppb	<1	Less than detection level
PRM119	1/26/2018	6:04:00	PRM-FL3-3319BWALL-LSINK-PRM119	Lead, ppb	1.58	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PRM120	1/26/2018	6:06:00	PRM-FL3-3319BWALL-RSINK-PRM120	Lead, ppb	1.22	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PRM121	1/26/2018	6:06:00	PRM-FL3-3319RWALL-SINK-PRM121	Lead, ppb	<1	Less than detection level

### Cincinnati Public Schools - Pleasant Ridge Montessori - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
PRM122	1/26/2018	6:08:00	PRM-FL3-3315-SINK-PRM122	Lead, ppb	2.74	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PRM123	1/26/2018	6:08:00	PRM-FL3-3315-DF-PRM123	Lead, ppb	<1	Less than detection level
PRM124	1/26/2018	6:09:00	PRM-FL3-3313-SINK-PRM124	Lead, ppb	<1	Less than detection level
PRM125	1/26/2018	6:09:00	PRM-FL3-3313-DF-PRM125	Lead, ppb	<1	Less than detection level
PRM126	1/26/2018	6:10:00	PRM-FL3-3304-SINK-PRM126	Lead, ppb	2.45	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PRM127	1/26/2018	6:10:00	PRM-FL3-3304-DF-PRM127	Lead, ppb	7.3	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
PRM128	N/A	N/A	PRM-FL3-3302-SINK-PRM128	Lead, ppb	N/A	Not sampled; out of service at the time of sampling.
PRM129	N/A	N/A	PRM-FL3-3302-DF-PRM129	Lead, ppb	N/A	Not sampled; out of service at the time of sampling.
N/A	N/A	N/A	PRM-FL2-HALLWAYMAINENT-ROOKWOOD	Lead, ppb	N/A	Not sampled; out of service at the time of sampling.
N/A	N/A	N/A	PRM-FL3-3319FRONTDESK-SINK	Lead, ppb	N/A	Not sampled; out of service at the time of sampling.