



March 30, 2018

**Rising Stars Academy  
at Vine Resample**

Cincinnati Public Schools  
Cynthia Eghbalnia  
2651 Burnet Avenue  
Cincinnati, OH 45219

Dear Cynthia:

Samples for a few locations were collected in a resample round of lead analyses for Rising Stars Academy. Greater Cincinnati Water works (GCWW) analyzed the samples and compared the results.

**School Sampling Results**

The USEPA 3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance Document (3Ts Guidelines) is the process and guidelines used for assisting schools with testing for lead. The following are the sample results:

Cincinnati Public Schools - Rising Star Academy					
Lead Testing Results-Resamples					
SAMPLE	Initial 1st Draw sample Date 2/17/17 Lead, ppb	Changes made after first round of sampling	1st Draw sample Date 10/11/17 Lead, ppb	30 second flush sample Date 10/11/17 Lead, ppb	60 second flush sample Date 10/11/17 Lead, ppb
RSA-KIT-NEAR2TUBPRODUCE-HANDSINK-RSA2	33.7	Cleaned aerator; flushed the lines	2.83	<1	<1
RSA-KIT-STOCKPOT-FILLER-RSA5	27	Cleaned faucet; flushed the lines	<1	<1	1.06
RSA-FL1-MAINFOFFRR-SINK-RSA13	19.1	Cleaned aerator; flushed the lines	<1	<1	<1

**Changes made and Next Steps**


For the locations in the resample round, fixtures or aerators were cleaned. It is possible that particles had been trapped on the aerator prior to the cleaning. The cleaning greatly reduced the lead levels. No further action is suggested.

Your work and changes in the school continue to improve the water quality for the students and staff. Your decisions and actions throughout this process speak to your care and commitment to ensure students and staff remain safe and healthy



Thanks again for your partnership with Greater Cincinnati Water Works and your work to further understand the water quality within your building. Your extra steps and care to keep the children in our community safe are appreciated!

Sincerely,

A handwritten signature in black ink that reads "Cathy B. Bailey". The signature is written in a cursive style with a large initial 'C' and a long, sweeping tail on the 'y'.

Cathy B. Bailey  
Director/Greater Cincinnati Water Works

Cc: Dr. Marilyn Crumpton, Cincinnati Health Department  
Dr. Camille Jones, Cincinnati Health Department  
Chuck DeJonckheere, Hamilton County Public Health  
Patrick Duhaney, City of Cincinnati  
Verna Arnette, Greater Cincinnati Water Works  
Jeff Swertfeger, Greater Cincinnati Water Works  
Jason DeLaet, Greater Cincinnati Water Works