



April 20, 2018

Cincinnati Public Schools
Cynthia Eghbalnia
2651 Burnet Avenue
Cincinnati, OH 45219

**Riverview East
Academy**

Dear Cynthia:

Thank you for taking the responsibility seriously to protect the health of the children by voluntarily testing the water in your school for lead!

Attached please find the results of the lead analyses performed for Riverview East Academy by the Greater Cincinnati Water Works (GCWW). The following comments speak to the process, samples analyzed and additional steps needed to help ensure the safety of all the students within the school.

School Sampling Process and Results

GCWW and Cincinnati Public Schools (CPS) staff worked together to finalize a sampling plan for the school. The *USEPA 3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance Document (3Ts Guidelines)* is the process and guidelines used for assisting schools with testing for lead.

In February, one hundred, sixty (160) samples were collected from drinking fountains, sinks and cooking outlets throughout the school. Multiple sinks within the schools were not initially considered for testing, however, key nearby indicators (coffee makers, drinking cups, plates, utensils, etc.) prompted additional locations to be tested in the schools. Including these sampling locations speaks to the proactive approach CPS continues to have towards understanding the water quality within the schools. The results show the following:

- 130 samples (81.25%), below the detection level (<1)
- 26 samples (16.25%), between 1ppb and 5ppb
- 3 samples (1.88%), between 5ppb and 10ppb
- 1 sample (0.62%), between 10ppb and 15ppb
- 0 samples (0%), greater than 15ppb.

One hundred percent (100%) of the results were below the detection level or below the federal action level.

Fifteen parts per billion (ppb) is the federal Lead and Copper Rule action level; desired results are below 15. The federal action level of 15ppb pertains to water utilities and GCWW's review and comments are based on this action level. However, the USEPA 3Ts Guidelines document outlines practices for schools to put in place if samples are greater than 20 ppb.

While we strive to have results less than 15, we recognize that lead is a pervasive environmental contaminant, and no safe blood lead threshold has been identified in children or adults. Therefore, we provide recommendations to further reduce any lead levels discovered in your school.

Next steps

GCWW has reviewed the results from your samples and provides some next-steps comments.

1. Great news! Forty-five of forty-six (98%) drinking fountain and bottle filler sample locations had results below the detection level; no further action is needed for the 45. For the one drinking fountain that had a




lead detection, the level was low. Perhaps this fountain was not used often and now has this low lead level. To reduce the level, consider flushing the line (letting the water run) before use.

2. Ten (10) locations were sampled in the kitchen. Nine of the ten (90%) locations had lead detections, however, all were below the federal action level. It is assumed these locations are used for food or drink preparation. Consider flushing the line (letting the water run) before use to reduce the risk of lead.
3. One sink, REA-FL1-ELA31001-SINK-REA99, had a higher lead level, near 15ppb. This sink is 1 of 3 in a restroom and may not be used on a regular basis. Infrequent use may be the reason for the high lead level. Flushing the line may reduce the risk of lead. Also, consider cleaning the aerator in case particles are trapped on the aerator and contributing to the lead result.
4. Several other sinks had lead detections; many of them were low results. Based on the names, these are not used for drinking water or cooking purposes.
 - a. Lead is not an issue for body contact such as bathing, showering, and washing hands.
 - b. Cleaning the aerators at these locations may lower the lead levels.
 - c. If the locations with lead detections are not used on a regular basis, then the infrequent use may be contributing to the lead detections.
5. Review how water is being used within your facility. If water is not used on a regular basis at some of these locations, the infrequent use at the outlet may be contributing to the lead detections. Signage at these locations may be helpful (hand washing only, science class purposes only-no drinking, etc.).
6. If it hasn't occurred already, a robust communications plan is suggested. Communications plan steps are outlined in the 3Ts Guidelines. This plan will inform the school community of the sampling work the school has done to date and the steps the school will take to correct any issues discovered. GCWW employees can assist with this plan and are available to attend any school meetings to help explain our lead program, the sample results and our partnership with your school. Suggestions for language and a letter template can be provided if needed. Sampling results will be posted on the GCWW lead.mycww.org website with other school sampling results.

Greater Cincinnati Water Works takes the presence of lead service lines and the removal of those service lines in our system very seriously. In addition, minimizing the exposure of lead within our preschools, schools, and daycares is one of our highest priorities under our Enhanced Lead Program. Please contact Jim Nelson at 591-6869 if you have any questions.

Thanks again for your partnership with Greater Cincinnati Water Works and your work to further understand the water quality within your building. Your extra steps and care to keep the children in our community safe are appreciated!

Sincerely,



Cathy B. Bailey
Director/Greater Cincinnati Water Works

Cc: Dr. Marilyn Crumpton, Cincinnati Health Department
Dr. Camille Jones, Cincinnati Health Department
Chuck DeJonckheere, Hamilton County Public Health
Patrick Duhaney, City of Cincinnati
Verna Arnette, Greater Cincinnati Water Works
Jeff Swertfeger, Greater Cincinnati Water Works
Jason DeLaet, Greater Cincinnati Water Works
James Nelson, Greater Cincinnati Water Works

Cincinnati Public Schools- Riverview East Academy - Lead Testing Results

| SAMPLE # | SAMPLE DATE | SAMPLE TIME | SAMPLE | PARAMETER CODE | AMOUNT | GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS |
|----------|-------------|-------------|-------------------------------------|----------------|--------|--|
| REA1 | 2/9/2018 | 5:04:00 | REA-FL1CELC-11018ARR-SINK-REA1 | Lead, PPB | <1 | Less than detection level |
| REA2 | 2/9/2018 | 5:05:00 | REA-FL1CELC-11018BRR-SINK-REA2 | Lead, PPB | <1 | Less than detection level |
| REA3 | 2/9/2018 | 5:06:00 | REA-FL1CELC-11018-FSINK-REA3 | Lead, PPB | <1 | Less than detection level |
| REA4 | 2/9/2018 | 5:07:00 | REA-FL1CELC-11018-MSINK-REA4 | Lead, PPB | <1 | Less than detection level |
| REA5 | 2/9/2018 | 5:08:00 | REA-FL1CELC-11018-RSINK-REA5 | Lead, PPB | <1 | Less than detection level |
| REA6 | 2/9/2018 | 5:09:00 | REA-FL1-HALLNEAR11018-LDF-REA6 | Lead, PPB | <1 | Less than detection level |
| REA7 | 2/9/2018 | 5:10:00 | REA-FL1-HALLNEAR11018-RDF-REA7 | Lead, PPB | <1 | Less than detection level |
| REA8 | 2/9/2018 | 5:11:00 | REA-FL1-11005-SINK-REA8 | Lead, PPB | <1 | Less than detection level |
| REA9 | 2/9/2018 | 5:12:00 | REA-FL1-11005-DF-REA9 | Lead, PPB | <1 | Less than detection level |
| REA10 | 2/9/2018 | 5:13:00 | REA-FL1-11007-SINK-REA10 | Lead, PPB | <1 | Less than detection level |
| REA11 | 2/9/2018 | 5:14:00 | REA-FL1-11036BOYSRR-LSINK-REA11 | Lead, PPB | <1 | Less than detection level |
| REA12 | 2/9/2018 | 5:15:00 | REA-FL1-11036BOYSRR-MSINK-REA12 | Lead, PPB | <1 | Less than detection level |
| REA13 | 2/9/2018 | 5:16:00 | REA-FL1-11036BOYSRR-RSINK-REA13 | Lead, PPB | <1 | Less than detection level |
| REA14 | 2/9/2018 | 5:17:00 | REA-FL1-11038GIRLSRR-LSINK-REA14 | Lead, PPB | <1 | Less than detection level |
| REA15 | 2/9/2018 | 5:18:00 | REA-FL1-11038GIRLSRR-MSINK-REA15 | Lead, PPB | <1 | Less than detection level |
| REA16 | 2/9/2018 | 5:19:00 | REA-FL1-11038GIRLSRR-RSINK-REA16 | Lead, PPB | <1 | Less than detection level |
| REA17 | 2/9/2018 | 5:20:00 | REA-FL1-11042UNIRR-SINK-REA17 | Lead, PPB | <1 | Less than detection level |
| REA18 | 2/9/2018 | 5:21:00 | REA-FL1-HALLNEAR11042-COMBODF-REA18 | Lead, PPB | <1 | Less than detection level |
| REA19 | 2/9/2018 | 5:22:00 | REA-FL1-HALLNEAR11042-COMBOBF-REA19 | Lead, PPB | <1 | Less than detection level |
| REA20 | 2/9/2018 | 5:23:00 | REA-FL1-11040UNIRR-SINK-REA20 | Lead, PPB | <1 | Less than detection level |
| REA21 | 2/9/2018 | 5:24:00 | REA-FL1-11030PEOFFRR-SINK-REA21 | Lead, PPB | <1 | Less than detection level |
| REA22 | 2/9/2018 | 5:25:00 | REA-FL1-11050GIRLSLOCK-LSINK-REA22 | Lead, PPB | <1 | Less than detection level |
| REA23 | 2/9/2018 | 5:26:00 | REA-FL1-11050GIRLSLOCK-RSINK-REA23 | Lead, PPB | <1 | Less than detection level |
| REA24 | 2/9/2018 | 5:27:00 | REA-FL1-11050GIRLSLOCK-DF-REA24 | Lead, PPB | <1 | Less than detection level |
| REA25 | 2/9/2018 | 5:28:00 | REA-FL1-11048BOYSLOCK-LSINK-REA25 | Lead, PPB | <1 | Less than detection level |
| REA26 | 2/9/2018 | 5:29:00 | REA-FL1-11048BOYSLOCK-RSINK-REA26 | Lead, PPB | <1 | Less than detection level |
| REA27 | 2/9/2018 | 5:30:00 | REA-FL1-11048BOYSLOCK-DF-REA27 | Lead, PPB | <1 | Less than detection level |
| REA28 | 2/9/2018 | 5:31:00 | REA-KIT-NEARSERVE-HANDSINK-REA28 | Lead, PPB | <1 | Less than detection level |
| REA29 | 2/9/2018 | 5:32:00 | REA-KIT-1TUBNEARCOOL-SINK-REA29 | Lead, PPB | 3.15 | Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead. |

Cincinnati Public Schools- Riverview East Academy - Lead Testing Results

| SAMPLE # | SAMPLE DATE | SAMPLE TIME | SAMPLE | PARAMETER CODE | AMOUNT | GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS |
|----------|-------------|-------------|-------------------------------------|----------------|--------|--|
| REA30 | 2/9/2018 | 5:33:00 | REA-KIT-2TUB-SINK-REA30 | Lead, PPB | 1.29 | Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead. |
| REA31 | 2/9/2018 | 5:34:00 | REA-KIT-1TUBNEARSTOCKPOT-SINK-REA31 | Lead, PPB | 3.92 | Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead. |
| REA32 | 2/9/2018 | 5:35:00 | REA-KIT-STOCKPOT-LFILLER-REA32 | Lead, PPB | 5.39 | Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead. |
| REA33 | 2/9/2018 | 5:36:00 | REA-KIT-STOCKPOT-RFILLER-REA33 | Lead, PPB | 3.13 | Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead. |
| REA34 | 2/9/2018 | 5:37:00 | REA-KIT-DISHRM3TUB-LSINK-REA34 | Lead, PPB | 1.71 | Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead. |
| REA35 | 2/9/2018 | 5:38:00 | REA-KIT-DISHRM3TUB-RSINK-REA35 | Lead, PPB | 7.08 | Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead. |
| REA36 | 2/9/2018 | 5:39:00 | REA-KIT-DISHRM-HANDSINK-REA36 | Lead, PPB | 2.26 | Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead. |
| REA37 | 2/9/2018 | 5:41:00 | REA-KIT-11072STAFFRR-SINK-REA37 | Lead, PPB | 3.05 | Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead. |
| REA38 | 2/9/2018 | 5:42:00 | REA-FL1-MO11068RR-SINK-REA38 | Lead, PPB | <1 | Less than detection level |
| REA39 | 2/9/2018 | 5:43:00 | REA-FL1-MO11070RR-SINK-REA39 | Lead, PPB | <1 | Less than detection level |
| REA40 | 2/9/2018 | 5:44:00 | REA-FL1-MOKITCHENETTE-SINK-REA40 | Lead, PPB | <1 | Less than detection level |
| REA41 | 2/9/2018 | 5:45:00 | REA-FL1-11084WKRM-SINK-REA41 | Lead, PPB | <1 | Less than detection level |

Cincinnati Public Schools- Riverview East Academy - Lead Testing Results

| SAMPLE # | SAMPLE DATE | SAMPLE TIME | SAMPLE | PARAMETER CODE | AMOUNT | GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS |
|----------|-------------|-------------|--------------------------------------|----------------|--------|--|
| REA42 | 2/9/2018 | 5:46:00 | REA-FL1-HALLNEAR11084-LDF-REA42 | Lead, PPB | <1 | Less than detection level |
| REA43 | 2/9/2018 | 5:47:00 | REA-FL1-HALLNEAR11084-RDF-REA43 | Lead, PPB | <1 | Less than detection level |
| REA44 | 2/9/2018 | 5:48:00 | REA-FL1-11015HEALTHRR-SINK-REA44 | Lead, PPB | 1.04 | Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead. |
| REA45 | 2/9/2018 | 5:49:00 | REA-FL1-11015HEALTHEXAM#1-SINK-REA45 | Lead, PPB | <1 | Less than detection level |
| REA46 | 2/9/2018 | 5:50:00 | REA-FL1-11015HEALTHEXAM#2-SINK-REA46 | Lead, PPB | <1 | Less than detection level |
| REA47 | 2/9/2018 | 5:51:00 | REA-FL1-11015HEALTHEXAM#3-SINK-REA47 | Lead, PPB | <1 | Less than detection level |
| REA48 | 2/9/2018 | 5:52:00 | REA-FL1-11015HEALTHEXAM#4-SINK-REA48 | Lead, PPB | <1 | Less than detection level |
| REA49 | 2/9/2018 | 5:53:00 | REA-FL1-11015HEALTHLAB-SINK-REA49 | Lead, PPB | <1 | Less than detection level |
| REA50 | 2/9/2018 | 5:05:00 | REA-FL1-HALLNEAR21006-LDF-REA50 | Lead, PPB | <1 | Less than detection level |
| REA51 | 2/9/2018 | 5:05:00 | REA-FL1-HALLNEAR21006-RDF-REA51 | Lead, PPB | <1 | Less than detection level |
| REA52 | 2/9/2018 | 5:07:00 | REA-FL1-ELA21006-SINK-REA52 | Lead, PPB | <1 | Less than detection level |
| REA53 | 2/9/2018 | 5:07:00 | REA-FL1-ELA21006-DF-REA53 | Lead, PPB | <1 | Less than detection level |
| REA54 | 2/9/2018 | 5:07:00 | REA-FL1-ELA21006RR-SINK-REA54 | Lead, PPB | 9.91 | Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead. |
| REA55 | 2/9/2018 | 5:10:00 | REA-FL1-21008-SINK-REA55 | Lead, PPB | <1 | Less than detection level |
| REA56 | 2/9/2018 | 5:10:00 | REA-FL1-21008-DF-REA56 | Lead, PPB | 1.23 | Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead. |
| REA57 | 2/9/2018 | 5:16:00 | REA-FL1-21008RR-SINK-REA57 | Lead, PPB | <1 | Less than detection level |
| REA58 | 2/9/2018 | 5:13:00 | REA-FL1-21010-SINK-REA58 | Lead, PPB | <1 | Less than detection level |
| REA59 | 2/9/2018 | 5:13:00 | REA-FL1-21010-DF-REA59 | Lead, PPB | <1 | Less than detection level |
| REA60 | 2/9/2018 | 5:13:00 | REA-FL1-21010RR-SINK-REA60 | Lead, PPB | <1 | Less than detection level |
| REA61 | 2/9/2018 | 5:16:00 | REA-FL1-21012-SINK-REA61 | Lead, PPB | <1 | Less than detection level |
| REA62 | 2/9/2018 | 5:16:00 | REA-FL1-21012-DF-REA62 | Lead, PPB | <1 | Less than detection level |
| REA63 | 2/9/2018 | 5:16:00 | REA-FL1-21012RR-SINK-REA63 | Lead, PPB | <1 | Less than detection level |
| REA64 | 2/9/2018 | 5:19:00 | REA-FL1-21014-SINK-REA64 | Lead, PPB | <1 | Less than detection level |
| REA65 | 2/9/2018 | 5:19:00 | REA-FL1-21014-DF-REA65 | Lead, PPB | <1 | Less than detection level |

Cincinnati Public Schools- Riverview East Academy - Lead Testing Results

| SAMPLE # | SAMPLE DATE | SAMPLE TIME | SAMPLE | PARAMETER CODE | AMOUNT | GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS |
|----------|-------------|-------------|---------------------------------|----------------|--------|--|
| REA66 | 2/9/2018 | 5:19:00 | REA-FL1-21014RR-SINK-REA66 | Lead, PPB | 1.37 | Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead. |
| REA67 | 2/9/2018 | 5:22:00 | REA-FL1-ELA21001-SINK-REA67 | Lead, PPB | <1 | Less than detection level |
| REA68 | 2/9/2018 | 5:22:00 | REA-FL1-ELA21001-DF-REA68 | Lead, PPB | <1 | Less than detection level |
| REA69 | 2/9/2018 | 5:23:00 | REA-FL1-A21001RR-SINK-REA69 | Lead, PPB | <1 | Less than detection level |
| REA70 | 2/9/2018 | 5:24:00 | REA-FL1-B21001RR-SINK-REA70 | Lead, PPB | <1 | Less than detection level |
| REA71 | 2/9/2018 | 5:25:00 | REA-FL1-C21001RR-SINK-REA71 | Lead, PPB | <1 | Less than detection level |
| REA72 | 2/9/2018 | 5:27:00 | REA-FL1-21003-SINK-REA72 | Lead, PPB | <1 | Less than detection level |
| REA73 | 2/9/2018 | 5:27:00 | REA-FL1-21003-DF-REA73 | Lead, PPB | <1 | Less than detection level |
| REA74 | 2/9/2018 | 5:28:00 | REA-FL1-21005-SINK-REA74 | Lead, PPB | <1 | Less than detection level |
| REA75 | 2/9/2018 | 5:28:00 | REA-FL1-21005-DF-REA75 | Lead, PPB | <1 | Less than detection level |
| REA76 | 2/9/2018 | 5:30:00 | REA-FL1-21007-SINK-REA76 | Lead, PPB | <1 | Less than detection level |
| REA77 | 2/9/2018 | 5:30:00 | REA-FL1-21007-DF-REA77 | Lead, PPB | <1 | Less than detection level |
| REA78 | 2/9/2018 | 5:32:00 | REA-FL1-21009-SINK-REA78 | Lead, PPB | <1 | Less than detection level |
| REA79 | 2/9/2018 | 5:32:00 | REA-FL1-21009-DF-REA79 | Lead, PPB | <1 | Less than detection level |
| REA80 | 2/9/2018 | 5:39:00 | REA-FL1-HALLNEAR31016-LDF-REA80 | Lead, PPB | <1 | Less than detection level |
| REA81 | 2/9/2018 | 5:39:00 | REA-FL1-HALLNEAR31016-RDF-REA81 | Lead, PPB | <1 | Less than detection level |
| REA82 | 2/9/2018 | 5:41:00 | REA-FL1-ELA31016-SINK-REA82 | Lead, PPB | 1.07 | Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead. |
| REA83 | 2/9/2018 | 5:41:00 | REA-FL1-ELA31016-DF-REA83 | Lead, PPB | <1 | Less than detection level |
| REA84 | 2/9/2018 | 5:42:00 | REA-FL1-A31016RR-SINK-REA84 | Lead, PPB | <1 | Less than detection level |
| REA85 | 2/9/2018 | 5:43:00 | REA-FL1-B31016RR-SINK-REA85 | Lead, PPB | <1 | Less than detection level |
| REA86 | 2/9/2018 | 5:44:00 | REA-FL1-C31016RR-SINK-REA86 | Lead, PPB | <1 | Less than detection level |
| REA87 | 2/9/2018 | 5:46:00 | REA-FL1-31018-SINK-REA87 | Lead, PPB | 4.17 | Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead. |
| REA88 | 2/9/2018 | 5:46:00 | REA-FL1-31018-DF-REA88 | Lead, PPB | <1 | Less than detection level |
| REA89 | 2/9/2018 | 5:48:00 | REA-FL1-31020-SINK-REA89 | Lead, PPB | <1 | Less than detection level |

Cincinnati Public Schools- Riverview East Academy - Lead Testing Results

| SAMPLE # | SAMPLE DATE | SAMPLE TIME | SAMPLE | PARAMETER CODE | AMOUNT | GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS |
|----------|-------------|-------------|--|----------------|--------|--|
| REA90 | 2/9/2018 | 5:48:00 | REA-FL1-31020-DF-REA90 | Lead, PPB | <1 | Less than detection level |
| REA91 | 2/9/2018 | 5:49:00 | REA-FL1-31022-SINK-REA91 | Lead, PPB | <1 | Less than detection level |
| REA92 | 2/9/2018 | 5:49:00 | REA-FL1-31022-DF-REA92 | Lead, PPB | <1 | Less than detection level |
| REA93 | 2/9/2018 | 5:51:00 | REA-FL1-31024-SINK-REA93 | Lead, PPB | <1 | Less than detection level |
| REA94 | 2/9/2018 | 5:51:00 | REA-FL1-31024-DF-REA94 | Lead, PPB | <1 | Less than detection level |
| REA95 | 2/9/2018 | 5:52:00 | REA-FL1-31026STAFFLOUNGE-SINK-REA95 | Lead, PPB | <1 | Less than detection level |
| REA96 | 2/9/2018 | 5:53:00 | REA-FL1-ELA31001-SINK-REA96 | Lead, PPB | 1.44 | Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead. |
| REA97 | 2/9/2018 | 5:53:00 | REA-FL1-ELA31001-DF-REA97 | Lead, PPB | <1 | Less than detection level |
| REA98 | 2/9/2018 | 5:55:00 | REA-FL1-A31001RR-SINK-REA98 | Lead, PPB | <1 | Less than detection level |
| REA99 | 2/9/2018 | 5:55:00 | REA-FL1-B31001RR-SINK-REA99 | Lead, PPB | 14.4 | Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead. |
| REA100 | 2/9/2018 | 5:55:00 | REA-FL1-C31001RR-SINK-REA100 | Lead, PPB | <1 | Less than detection level |
| REA101 | 2/9/2018 | 5:06:00 | REA-FL1-31003-SINK-REA101 | Lead, PPB | <1 | Less than detection level |
| REA102 | 2/9/2018 | 5:06:00 | REA-FL1-31003-DF-REA102 | Lead, PPB | <1 | Less than detection level |
| REA103 | 2/9/2018 | 5:08:00 | REA-FL1-31006-SINK-REA103 | Lead, PPB | <1 | Less than detection level |
| REA104 | 2/9/2018 | 5:08:00 | REA-FL1-31006-DF-REA104 | Lead, PPB | <1 | Less than detection level |
| REA105 | 2/9/2018 | 5:12:00 | REA-FL1-31007-SINK-REA105 | Lead, PPB | <1 | Less than detection level |
| REA106 | 2/9/2018 | 5:12:00 | REA-FL1-31007-DF-REA106 | Lead, PPB | <1 | Less than detection level |
| REA107 | 2/9/2018 | 5:13:00 | REA-FL1-31009-SINK-REA107 | Lead, PPB | <1 | Less than detection level |
| REA108 | 2/9/2018 | 5:13:00 | REA-FL1-31009-DF-REA108 | Lead, PPB | <1 | Less than detection level |
| REA109 | 2/9/2018 | 5:21:00 | REA-FL2-STAFFLOUNGENEAR32004-SINK-REA109 | Lead, PPB | <1 | Less than detection level |
| REA110 | 2/9/2018 | 5:21:00 | REA-FL2-A32001RR-SINK-REA110 | Lead, PPB | <1 | Less than detection level |
| REA111 | 2/9/2018 | 5:21:00 | REA-FL2-B32001RR-SINK-REA111 | Lead, PPB | <1 | Less than detection level |
| REA112 | 2/9/2018 | 5:21:00 | REA-FL2-C32001RR-SINK-REA112 | Lead, PPB | <1 | Less than detection level |
| REA113 | 2/9/2018 | 5:26:00 | REA-FL2-HALLNEAR32016-LDF-REA113 | Lead, PPB | <1 | Less than detection level |
| REA114 | 2/9/2018 | 5:26:00 | REA-FL2-HALLNEAR32016-RDF-REA114 | Lead, PPB | <1 | Less than detection level |
| REA115 | 2/9/2018 | 5:27:00 | REA-FL2-A32016RR-SINK-REA115 | Lead, PPB | <1 | Less than detection level |
| REA116 | 2/9/2018 | 5:27:00 | REA-FL2-B32016RR-SINK-REA116 | Lead, PPB | <1 | Less than detection level |

Cincinnati Public Schools- Riverview East Academy - Lead Testing Results

| SAMPLE # | SAMPLE DATE | SAMPLE TIME | SAMPLE | PARAMETER CODE | AMOUNT | GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS |
|----------|-------------|-------------|----------------------------------|----------------|--------|--|
| REA117 | 2/9/2018 | 5:27:00 | REA-FL2-C32016RR-SINK-REA117 | Lead, PPB | <1 | Less than detection level |
| REA118 | 2/9/2018 | 5:28:00 | REA-FL2-ELA22001-SINK-REA118 | Lead, PPB | 1.7 | Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead. |
| REA119 | 2/9/2018 | 5:28:00 | REA-FL2-ELA22001-DF-REA119 | Lead, PPB | <1 | Less than detection level |
| REA120 | 2/9/2018 | 5:29:00 | REA-FL2-A22001RR-SINK-REA120 | Lead, PPB | <1 | Less than detection level |
| REA121 | 2/9/2018 | 5:29:00 | REA-FL2-B22001RR-SINK-REA121 | Lead, PPB | 1.08 | Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead. |
| REA122 | 2/9/2018 | 5:29:00 | REA-FL2-C22001RR-SINK-REA122 | Lead, PPB | <1 | Less than detection level |
| REA123 | 2/9/2018 | 5:33:00 | REA-FL2-22003-SINK-REA123 | Lead, PPB | <1 | Less than detection level |
| REA124 | 2/9/2018 | 5:33:00 | REA-FL2-22003-DF-REA124 | Lead, PPB | <1 | Less than detection level |
| REA125 | 2/9/2018 | 5:34:00 | REA-FL2-22005-SINK-REA125 | Lead, PPB | <1 | Less than detection level |
| REA126 | 2/9/2018 | 5:34:00 | REA-FL2-22005-DF-REA126 | Lead, PPB | <1 | Less than detection level |
| REA127 | 2/9/2018 | 5:35:00 | REA-FL2-22007-SINK-REA127 | Lead, PPB | <1 | Less than detection level |
| REA128 | 2/9/2018 | 5:35:00 | REA-FL2-22007-DF-REA128 | Lead, PPB | <1 | Less than detection level |
| REA129 | 2/9/2018 | 5:37:00 | REA-FL2-22009-SINK-REA129 | Lead, PPB | <1 | Less than detection level |
| REA130 | 2/9/2018 | 5:37:00 | REA-FL2-22009-DF-REA130 | Lead, PPB | <1 | Less than detection level |
| REA131 | 2/9/2018 | 5:38:00 | REA-FL2-HALLNEAR22001-LDF-REA131 | Lead, PPB | <1 | Less than detection level |
| REA132 | 2/9/2018 | 5:38:00 | REA-FL2-HALLNEAR22001-RDF-REA132 | Lead, PPB | <1 | Less than detection level |
| REA133 | 2/9/2018 | 5:39:00 | REA-FL2-22008-SINK-REA133 | Lead, PPB | <1 | Less than detection level |
| REA134 | 2/9/2018 | 5:39:00 | REA-FL2-22008-DF-REA134 | Lead, PPB | <1 | Less than detection level |
| REA135 | 2/9/2018 | 5:40:00 | REA-FL2-A22010RR-SINK-REA135 | Lead, PPB | 1.34 | Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead. |
| REA136 | 2/9/2018 | 5:40:00 | REA-FL2-22014-SINK-REA136 | Lead, PPB | <1 | Less than detection level |
| REA137 | 2/9/2018 | 5:40:00 | REA-FL2-22014-DF-REA137 | Lead, PPB | <1 | Less than detection level |
| REA138 | 2/9/2018 | 5:44:00 | REA-FL2-22016RWALL-LSINK-REA138 | Lead, PPB | 1.4 | Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead. |

Cincinnati Public Schools- Riverview East Academy - Lead Testing Results

| SAMPLE # | SAMPLE DATE | SAMPLE TIME | SAMPLE | PARAMETER CODE | AMOUNT | GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS |
|----------|-------------|-------------|---------------------------------------|----------------|--------|--|
| REA139 | 2/9/2018 | 5:44:00 | REA-FL2-22016RWALL-MSINK-REA139 | Lead, PPB | 1.45 | Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead. |
| REA140 | 2/9/2018 | 5:44:00 | REA-FL2-22016RWALL-RSINK-REA140 | Lead, PPB | 2.46 | Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead. |
| REA141 | 2/9/2018 | 5:46:00 | REA-FL2-A22016STORAGE-SINK-REA141 | Lead, PPB | 4.13 | Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead. |
| REA142 | 2/9/2018 | 5:46:00 | REA-FL2-22018FRONTDESK-SINK-REA142 | Lead, PPB | 1.78 | Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead. |
| REA143 | 2/9/2018 | 5:47:00 | REA-FL2-22018LWALL-LSINK-REA143 | Lead, PPB | <1 | Less than detection level |
| REA144 | 2/9/2018 | 5:47:00 | REA-FL2-22018LWALL-RSINK-REA144 | Lead, PPB | 1.08 | Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead. |
| REA145 | 2/9/2018 | 5:47:00 | REA-FL2-22018RWALL-LSINK-REA145 | Lead, PPB | 1.29 | Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead. |
| REA146 | 2/9/2018 | 5:47:00 | REA-FL2-22018RWALL-RSINK-REA146 | Lead, PPB | 1.59 | Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead. |
| REA147 | 2/9/2018 | 5:50:00 | REA-FL2-12034ARTNEARFRONT-SINK-REA147 | Lead, PPB | <1 | Less than detection level |
| REA148 | 2/9/2018 | 5:50:00 | REA-FL2-12034ARTLWALL-LSINK-REA148 | Lead, PPB | <1 | Less than detection level |
| REA149 | 2/9/2018 | 5:50:00 | REA-FL2-12034ARTLWALL-RSINK-REA149 | Lead, PPB | <1 | Less than detection level |
| REA150 | 2/9/2018 | 5:52:00 | REA-FL2-HALLNEAR12022-LDF-REA150 | Lead, PPB | <1 | Less than detection level |
| REA151 | 2/9/2018 | 5:52:00 | REA-FL2-HALLNEAR12022-RDF-REA151 | Lead, PPB | <1 | Less than detection level |

Cincinnati Public Schools- Riverview East Academy - Lead Testing Results

| SAMPLE # | SAMPLE DATE | SAMPLE TIME | SAMPLE | PARAMETER CODE | AMOUNT | GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS |
|----------|-------------|-------------|---|----------------|--------|--|
| REA152 | 2/9/2018 | 5:53:00 | REA-FL2-12018OT/PT-SINK-REA152 | Lead, PPB | 1.38 | Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead. |
| REA153 | 2/9/2018 | 5:53:00 | REA-FL2-12018OT/PTRR-SINK-REA153 | Lead, PPB | 3.24 | Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead. |
| REA154 | 2/9/2018 | 5:54:00 | REA-FL2CELC-FRONT12019KIT-SINK-REA154 | Lead, PPB | <1 | Less than detection level |
| REA155 | 2/9/2018 | 5:54:00 | REA-FL2CELC-FRONT12019-HANDSINK-REA155 | Lead, PPB | <1 | Less than detection level |
| REA156 | 2/9/2018 | 5:55:00 | REA-FL2CELC-FRONT12019STAFFRR-SINK-REA156 | Lead, PPB | <1 | Less than detection level |
| REA157 | 2/9/2018 | 5:55:00 | REA-FL2CELC-BACK12019KIT-SINK-REA157 | Lead, PPB | <1 | Less than detection level |
| REA158 | 2/9/2018 | 5:56:00 | REA-FL2CELC-BACK12019-HANDSINK-REA158 | Lead, PPB | <1 | Less than detection level |
| REA159 | 2/14/2018 | 6:30:00 | REA-FL2CELC-FRONT12019KIDSRR-LSINK-REA159 | Lead, PPB | <1 | Less than detection level |
| REA160 | 2/14/2018 | 6:30:00 | REA-FL2CELC-FRONT12019KIDSRR-RSINK-REA160 | Lead, PPB | <1 | Less than detection level |