



September 18, 2018

Cincinnati Public Schools
Cynthia Eghbalnia
2651 Burnet Avenue
Cincinnati, OH 45219

Rockdale Academy School

Dear Cynthia:

Thank you for taking the responsibility seriously to protect the health of the children by voluntarily testing the water in your school for lead!

Attached please find the results of the lead analyses performed for Rockdale Academy School by the Greater Cincinnati Water Works (GCWW). The following comments speak to the process, samples analyzed and additional steps needed to help ensure the safety of all the students within the school.

School Sampling Process and Results

GCWW and Cincinnati Public Schools (CPS) staff worked together to finalize a sampling plan for the school. The *USEPA 3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance Document (3Ts Guidelines)* is the process and guidelines used for assisting schools with testing for lead.

In April, one hundred sixty-six (166) samples were collected from drinking fountains, sinks and cooking outlets throughout the school. Multiple sinks within the schools were not initially considered for testing, however, key nearby indicators (coffee makers, drinking cups, plates, utensils, etc.) prompted additional locations to be tested in the schools. Including these sampling locations speaks to the proactive approach CPS continues to have towards understanding the water quality within the schools. The results show the following:

- 139 samples (83.73%), below the detection level (<1)
- 16 samples (9.64%), between 1ppb and 5ppb
- 0 sample (0.00%), between 5ppb and 10ppb
- 1 samples (0.60%), between 10ppb and 15ppb
- 10 sample (6.02%), greater than 15ppb.

Almost Ninety-four percent (93.98%) of the results were below the detection level or below the federal action level.

Fifteen parts per billion (ppb) is the federal Lead and Copper Rule action level; desired results are below 15. The federal action level of 15ppb pertains to water utilities and GCWW's review and comments are based on this action level. However, the USEPA 3Ts Guidelines document outlines practices for schools to put in place if samples are greater than 20 ppb.

While we strive to have results less than 15, we recognize that lead is a pervasive environmental contaminant, and no safe blood lead threshold has been identified in children or adults. Therefore, we provide recommendations to further reduce any lead levels discovered in your school.

Next steps

GCWW has reviewed the results from your samples and provides some next-steps comments.

1. Great news! All the drinking fountains and bottle fillers had no lead detections; no further action is suggested.




2. Ten (10) location had a lead detection greater than 15ppb. Based on the names and walkthrough comments, they are located in a science lab. These locations are sinks and it is assumed by the name that it is not used as a drinking water or cooking outlet. However, consider an immediate remedy such as taking the sample location out of service until a more defined plan can be created or post a sign limiting the use at this location. Refer to the USEPA 3Ts Guidelines for more information and suggestions on signage. After the location is out of service, work to reduce the lead level by first removing and cleaning the aerator as particles may be trapped on the aerator and contributing to the lead detection. Consider resampling after the cleaning.
 - a. If this science lab is not used often, posting signs limiting use is probably the best option as the infrequent use may contribute to high lead levels if sampled again.
3. Three (3) of the eleven (9) sample locations in the kitchen had lead detections. Flush the line before use if using these locations for food and drink preparation. No further action is suggested.
4. Other sinks had lead detections. Based on the names, they are not used for drinking water or cooking purposes.
 - a. Lead is not an issue for body contact such as bathing, showering, and washing hands.
 - b. To lower the lead levels, consider removing and cleaning the aerator. Particles may be trapped on the aerator and contributing to the lead level.
 - c. If the locations with lead detections are not used on a regular basis, then the infrequent use may be contributing to the lead detections.
5. Review how water is being used within your facility. Again, if water is not used on a regular basis at some of these locations, the infrequent use at the outlet may be contributing to the lead detections. Signage at these locations may be helpful (hand washing only, science class purposes only-no drinking, etc.).
6. If it hasn't occurred already, a robust communications plan is suggested. Communications plan steps are outlined in the 3Ts Guidelines. This plan will inform the school community of the sampling work the school has done to date and the steps the school will take to correct any issues discovered. GCWW employees can assist with this plan and are available to attend any school meetings to help explain our lead program, the sample results and our partnership with your school. Suggestions for language and a letter template can be provided if needed. Sampling results will be posted on the GCWW lead.mygcww.org website with other school sampling results.

Greater Cincinnati Water Works takes the presence of lead service lines and the removal of these lines in our system very seriously. In addition, minimizing the exposure of lead within our preschools, schools, and daycares is one of our highest priorities under our Enhanced Lead Program. Please contact Jim Nelson at 591-6869 if you have any questions.

Thanks again for your partnership with Greater Cincinnati Water Works and your work to further understand the water quality within your building. Your extra steps and care to keep the children in our community safe are appreciated!

Sincerely,



Cathy B. Bailey

Director/Greater Cincinnati Water Works

Cc: Melba Moore, Cincinnati Health Department
Dr. Camille Jones, Cincinnati Health Department
Chuck DeJonckheere, Hamilton County Public Health
Sheila Hill-Christian, City of Cincinnati
Verna Arnette, Greater Cincinnati Water Works
Jeff Swertfeger, Greater Cincinnati Water Works
Jason DeLaet, Greater Cincinnati Water Works
James Nelson, Greater Cincinnati Water Works

Cincinnati Public Schools -Rockdale Academy - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
ROK1	4/27/2018	5:09	ROK-KIT-NEARSERVE-HANDSINK-ROK1	Lead, ppb	1.35	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ROK2	4/27/2018	5:10	ROK-KIT-STOCKPOT-LFILLER-ROK2	Lead, ppb	1.7	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ROK3	4/27/2018	5:11	ROK-KIT-STOCKPOT-RFILLER-ROK3	Lead, ppb	<1	Less than detection level
ROK4	4/27/2018	5:12	ROK-KIT-NEARDISHRM-HANDSINK-ROK4	Lead, ppb	1.88	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ROK5	4/27/2018	5:13	ROK-KIT-1019STAFFRR-SINK-ROK5	Lead, ppb	<1	Less than detection level
ROK6	4/27/2018	5:14	ROK-KIT-3TUB-LSINK-ROK6	Lead, ppb	<1	Less than detection level
ROK7	4/27/2018	5:15	ROK-KIT-3TUB-RSINK-ROK7	Lead, ppb	<1	Less than detection level
ROK8	4/27/2018	5:16	ROK-KIT-2TUB-LSINK-ROK8	Lead, ppb	<1	Less than detection level
ROK9	4/27/2018	5:17	ROK-KIT-NEAR1021-HANDSINK-ROK9	Lead, ppb	<1	Less than detection level
ROK10	4/27/2018	5:20	ROK-FL1-1010PEOFFRR-SINK-ROK10	Lead, ppb	3.72	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ROK11	4/27/2018	5:21	ROK-FL1-1008BOYSLOCK-LSINK-ROK11	Lead, ppb	<1	Less than detection level
ROK12	4/27/2018	5:22	ROK-FL1-1008BOYSLOCK-RSINK-ROK12	Lead, ppb	<1	Less than detection level
ROK13	4/27/2018	5:23	ROK-FL1-1008GIRLSLOCK-LSINK-ROK13	Lead, ppb	<1	Less than detection level
ROK14	4/27/2018	5:24	ROK-FL1-1008GIRLSLOCK-RSINK-ROK14	Lead, ppb	<1	Less than detection level
ROK15	4/27/2018	5:25	ROK-FL1-GYM-LDF-ROK15	Lead, ppb	<1	Less than detection level
ROK16	4/27/2018	5:26	ROK-FL1-GYM-RCOMBODF-ROK16	Lead, ppb	<1	Less than detection level
ROK17	4/27/2018	5:27	ROK-FL1-GYM-RCOMBOBF-ROK17	Lead, ppb	<1	Less than detection level
ROK18	4/27/2018	5:28	ROK-FL1-1034BOYSRR-LSINK-ROK18	Lead, ppb	<1	Less than detection level
ROK19	4/27/2018	5:29	ROK-FL1-1034BOYSRR-RSINK-ROK19	Lead, ppb	<1	Less than detection level
ROK20	4/27/2018	5:30	ROK-FL1-NEAR1034/1035-COMBODF-ROK20	Lead, ppb	<1	Less than detection level

Cincinnati Public Schools -Rockdale Academy - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
ROK21	4/27/2018	5:31	ROK-FL1-NEAR1034/1035-COMBOBF-ROK21	Lead, ppb	<1	Less than detection level
ROK22	4/27/2018	5:32	ROK-FL1-1034GIRLSRR-LSINK-ROK22	Lead, ppb	<1	Less than detection level
ROK23	4/27/2018	5:33	ROK-FL1-1034GIRLSRR-RSINK-ROK23	Lead, ppb	<1	Less than detection level
ROK24	4/27/2018	5:34	ROK-FL1-1052-SINK-ROK24	Lead, ppb	<1	Less than detection level
ROK25	4/27/2018	5:35	ROK-FL1-1052-DF-ROK25	Lead, ppb	<1	Less than detection level
ROK26	4/27/2018	5:36	ROK-FL1-1051-SINK-ROK26	Lead, ppb	1.3	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ROK27	4/27/2018	5:37	ROK-FL1-1051-DF-ROK27	Lead, ppb	<1	Less than detection level
ROK28	4/27/2018	5:38	ROK-FL1-1050-SINK-ROK28	Lead, ppb	<1	Less than detection level
ROK29	4/27/2018	5:39	ROK-FL1-1050-DF-ROK29	Lead, ppb	<1	Less than detection level
ROK30	4/27/2018	5:40	ROK-FL1-1049-SINK-ROK30	Lead, ppb	<1	Less than detection level
ROK31	4/27/2018	5:41	ROK-FL1-1049-DF-ROK31	Lead, ppb	<1	Less than detection level
ROK32	4/27/2018	5:42	ROK-FL1-ELA1048-SINK-ROK32	Lead, ppb	<1	Less than detection level
ROK33	4/27/2018	5:43	ROK-FL1-ELA1048-DF-ROK33	Lead, ppb	<1	Less than detection level
ROK34	4/27/2018	5:44	ROK-FL1-A1041RR-SINK-ROK34	Lead, ppb	<1	Less than detection level
ROK35	4/27/2018	5:45	ROK-FL1-B1041RR-SINK-ROK35	Lead, ppb	<1	Less than detection level
ROK36	4/27/2018	5:46	ROK-FL1-C1041RR-SINK-ROK36	Lead, ppb	<1	Less than detection level
ROK37	4/27/2018	5:47	ROK-FL1-1043-SINK-ROK37	Lead, ppb	<1	Less than detection level
ROK38	4/27/2018	5:48	ROK-FL1-1043-DF-ROK38	Lead, ppb	<1	Less than detection level
ROK39	4/27/2018	5:49	ROK-FL1-1044-SINK-ROK39	Lead, ppb	<1	Less than detection level
ROK40	4/27/2018	5:50	ROK-FL1-1044-DF-ROK40	Lead, ppb	<1	Less than detection level
ROK41	4/27/2018	5:51	ROK-FL1-1045-SINK-ROK41	Lead, ppb	<1	Less than detection level
ROK42	4/27/2018	5:52	ROK-FL1-1045-DF-ROK42	Lead, ppb	<1	Less than detection level
ROK43	4/27/2018	5:53	ROK-FL1-1046-SINK-ROK43	Lead, ppb	<1	Less than detection level
ROK44	4/27/2018	5:54	ROK-FL1-1046-DF-ROK44	Lead, ppb	<1	Less than detection level
ROK45	4/27/2018	5:55	ROK-FL1-ELA1042-SINK-ROK45	Lead, ppb	<1	Less than detection level
ROK46	4/27/2018	5:56	ROK-FL1-ELA1042-DF-ROK46	Lead, ppb	<1	Less than detection level
ROK47	4/27/2018	5:57	ROK-FL1-A1035RR-SINK-ROK47	Lead, ppb	<1	Less than detection level
ROK48	4/27/2018	5:58	ROK-FL1-B1035RR-SINK-ROK48	Lead, ppb	<1	Less than detection level

Cincinnati Public Schools -Rockdale Academy - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
ROK49	4/27/2018	5:59	ROK-FL1-C1035RR-SINK-ROK49	Lead, ppb	<1	Less than detection level
ROK50	4/27/2018	5:11	ROK-FL2-2084RR-SINK-ROK50	Lead, ppb	<1	Less than detection level
ROK51	4/27/2018	5:11	ROK-FL2-2085RR-SINK-ROK51	Lead, ppb	<1	Less than detection level
ROK52	4/27/2018	5:12	ROK-FL2-2082EXAM#3-SINK-ROK52	Lead, ppb	<1	Less than detection level
ROK53	4/27/2018	5:12	ROK-FL2-2067NURSE-SINK-ROK53	Lead, ppb	<1	Less than detection level
ROK54	4/27/2018	5:12	ROK-FL2-2067NURSERR-SINK-ROK54	Lead, ppb	<1	Less than detection level
ROK55	4/27/2018	5:13	ROK-FL2-2064RR-SINK-ROK55	Lead, ppb	<1	Less than detection level
ROK56	4/27/2018	5:13	ROK-FL2-2081EXAM#2-SINK-ROK56	Lead, ppb	<1	Less than detection level
ROK57	4/27/2018	5:14	ROK-FL2-SH/RECEPTION-SINK-ROK57	Lead, ppb	<1	Less than detection level
ROK58	4/27/2018	5:14	ROK-FL2-2080EXAM#1-SINK-ROK58	Lead, ppb	<1	Less than detection level
ROK59	4/27/2018	5:16	ROK-FL2-2023COMMUNITYRM-SINK-ROK59	Lead, ppb	1.07	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ROK60	4/27/2018	5:16	ROK-FL2-2023COMMUNITYRM-DF-ROK60	Lead, ppb	<1	Less than detection level
ROK61	4/27/2018	5:19	ROK-FL2-2014STAFFRR-SINK-ROK61	Lead, ppb	<1	Less than detection level
ROK62	4/27/2018	5:20	ROK-FL2-2022WKRM-SINK-ROK62	Lead, ppb	3.31	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ROK63	4/27/2018	5:20	ROK-FL2-2022WKRM-DF-ROK63	Lead, ppb	<1	Less than detection level
ROK64	4/27/2018	5:21	ROK-FL2-2024-SINK-ROK64	Lead, ppb	<1	Less than detection level
ROK65	4/27/2018	5:21	ROK-FL2-2024-DF-ROK65	Lead, ppb	<1	Less than detection level
ROK66	4/27/2018	5:21	ROK-FL2-2024RR-SINK-ROK66	Lead, ppb	<1	Less than detection level
ROK67	4/27/2018	5:22	ROK-FL2-ELA2025-SINK-ROK67	Lead, ppb	<1	Less than detection level
ROK68	4/27/2018	5:22	ROK-FL2-ELA2025-DF-ROK68	Lead, ppb	<1	Less than detection level
ROK69	4/27/2018	5:22	ROK-FL2-ELA2025RR-SINK-ROK69	Lead, ppb	<1	Less than detection level
ROK70	4/27/2018	5:23	ROK-FL2-2026-SINK-ROK70	Lead, ppb	<1	Less than detection level
ROK71	4/27/2018	5:23	ROK-FL2-2026-DF-ROK71	Lead, ppb	<1	Less than detection level
ROK72	4/27/2018	5:23	ROK-FL2-2026RR-SINK-ROK72	Lead, ppb	<1	Less than detection level
ROK73	4/27/2018	5:25	ROK-FL2-2027-SINK-ROK73	Lead, ppb	<1	Less than detection level

Cincinnati Public Schools -Rockdale Academy - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
ROK74	4/27/2018	5:25	ROK-FL2-2027-DF-ROK74	Lead, ppb	<1	Less than detection level
ROK75	4/27/2018	5:25	ROK-FL2-2027RR-SINK-ROK75	Lead, ppb	<1	Less than detection level
ROK76	4/27/2018	5:26	ROK-FL2-2028RR-SINK-ROK76	Lead, ppb	<1	Less than detection level
ROK77	4/27/2018	5:28	ROK-FL2-2004WKRM-SINK-ROK77	Lead, ppb	2.1	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ROK78	4/27/2018	5:28	ROK-FL2-2004WKRM-DF-ROK78	Lead, ppb	<1	Less than detection level
ROK79	4/27/2018	5:29	ROK-FL2-2005RR-SINK-ROK79	Lead, ppb	<1	Less than detection level
ROK80	4/27/2018	5:29	ROK-FL2-2008STAFFLOUNGE-SINK-ROK80	Lead, ppb	<1	Less than detection level
ROK81	4/27/2018	5:29	ROK-FL2-2008STAFFLOUNGE-DF-ROK81	Lead, ppb	<1	Less than detection level
ROK82	4/27/2018	5:30	ROK-FL2-HALLWAYNEAR2016-DF-ROK82	Lead, ppb	<1	Less than detection level
ROK83	4/27/2018	5:35	ROK-FL2-2037GIRLSRR-LSINK-ROK83	Lead, ppb	<1	Less than detection level
ROK84	4/27/2018	5:35	ROK-FL2-2037GIRLSRR-RSINK-ROK84	Lead, ppb	<1	Less than detection level
ROK85	4/27/2018	5:35	ROK-FL2-2039BOYSRR-LSINK-ROK85	Lead, ppb	<1	Less than detection level
ROK86	4/27/2018	5:35	ROK-FL2-2039BOYSRR-RSINK-ROK86	Lead, ppb	<1	Less than detection level
ROK87	4/27/2018	5:37	ROK-FL2-2043-SINK-ROK87	Lead, ppb	<1	Less than detection level
ROK88	4/27/2018	5:37	ROK-FL2-2043-DF-ROK88	Lead, ppb	<1	Less than detection level
ROK89	4/27/2018	5:38	ROK-FL2-2044-SINK-ROK89	Lead, ppb	<1	Less than detection level
ROK90	4/27/2018	5:38	ROK-FL2-2044-DF-ROK90	Lead, ppb	<1	Less than detection level
ROK91	4/27/2018	5:39	ROK-FL2-2045-SINK-ROK91	Lead, ppb	1.08	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ROK92	4/27/2018	5:39	ROK-FL2-2045-DF-ROK92	Lead, ppb	<1	Less than detection level
ROK93	4/27/2018	5:40	ROK-FL2-2046-SINK-ROK93	Lead, ppb	<1	Less than detection level
ROK94	4/27/2018	5:40	ROK-FL2-2046-DF-ROK94	Lead, ppb	<1	Less than detection level
ROK95	4/27/2018	5:41	ROK-FL2-ELA2042-SINK-ROK95	Lead, ppb	1.11	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ROK96	4/27/2018	5:41	ROK-FL2-ELA2042-DF-ROK96	Lead, ppb	<1	Less than detection level

Cincinnati Public Schools -Rockdale Academy - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
ROK97	4/27/2018	5:42	ROK-FL2-A2035RR-SINK-ROK97	Lead, ppb	<1	Less than detection level
ROK98	4/27/2018	5:42	ROK-FL2-B2035RR-SINK-ROK98	Lead, ppb	1.45	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ROK99	4/27/2018	5:42	ROK-FL2-C2035RR-SINK-ROK99	Lead, ppb	<1	Less than detection level
ROK100	4/27/2018	5:43	ROK-FL2-ELA2048-SINK-ROK100	Lead, ppb	<1	Less than detection level
ROK101	4/27/2018	5:43	ROK-FL2-ELA2048-DF-ROK101	Lead, ppb	<1	Less than detection level
ROK102	4/27/2018	5:45	ROK-FL2-2049-SINK-ROK102	Lead, ppb	<1	Less than detection level
ROK103	4/27/2018	5:45	ROK-FL2-2049-DF-ROK103	Lead, ppb	<1	Less than detection level
ROK104	4/27/2018	5:46	ROK-FL2-2050-SINK-ROK104	Lead, ppb	<1	Less than detection level
ROK105	4/27/2018	5:46	ROK-FL2-2050-DF-ROK105	Lead, ppb	<1	Less than detection level
ROK106	4/27/2018	5:47	ROK-FL2-2051-SINK-ROK106	Lead, ppb	<1	Less than detection level
ROK107	4/27/2018	5:47	ROK-FL2-2051-DF-ROK107	Lead, ppb	<1	Less than detection level
ROK108	4/27/2018	5:50	ROK-FL2-2052-SINK-ROK108	Lead, ppb	<1	Less than detection level
ROK109	4/27/2018	5:50	ROK-FL2-2052-DF-ROK109	Lead, ppb	<1	Less than detection level
ROK110	4/27/2018	5:51	ROK-FL2-A2041RR-SINK-ROK110	Lead, ppb	<1	Less than detection level
ROK111	4/27/2018	5:51	ROK-FL2-B2041RR-SINK-ROK111	Lead, ppb	<1	Less than detection level
ROK112	4/27/2018	5:51	ROK-FL2-C2041RR-SINK-ROK112	Lead, ppb	<1	Less than detection level
ROK113	4/27/2018	6:00	ROK-FL3-3022FRONTDESK-SINK-ROK113	Lead, ppb	54.1	Science Room. At the 15ppb federal action level. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
ROK114	4/27/2018	6:01	ROK-FL3-3022LWALL-FLSINK-ROK114	Lead, ppb	16.2	Science Room. At the 15ppb federal action level. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).

Cincinnati Public Schools -Rockdale Academy - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
ROK115	4/27/2018	6:01	ROK-FL3-3022LWALL-LSINK-ROK115	Lead, ppb	50.6	Science Room. At the 15ppb federal action level. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
ROK116	4/27/2018	6:01	ROK-FL3-3022LWALL-RSINK-ROK116	Lead, ppb	102	Science Room. At the 15ppb federal action level. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
ROK117	4/27/2018	6:01	ROK-FL3-3022LWALL-FRSINK-ROK117	Lead, ppb	22.9	Science Room. At the 15ppb federal action level. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
ROK118	4/27/2018	6:03	ROK-FL3-3022BWALL-LSINK-ROK118	Lead, ppb	42	Science Room. At the 15ppb federal action level. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
ROK119	4/27/2018	6:03	ROK-FL3-3022BWALL-RSINK-ROK119	Lead, ppb	57.1	Science Room. At the 15ppb federal action level. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).

Cincinnati Public Schools -Rockdale Academy - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
ROK120	4/27/2018	6:06	ROK-FL3-3022RWALL-FLSINK-ROK120	Lead, ppb	41.8	Science Room. At the 15ppb federal action level. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
ROK121	4/27/2018	6:06	ROK-FL3-3022RWALL-LSINK-ROK121	Lead, ppb	25	Science Room. At the 15ppb federal action level. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
ROK122	4/27/2018	6:06	ROK-FL3-3022RWALL-RSINK-ROK122	Lead, ppb	14.5	Science Room. Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ROK123	4/27/2018	6:06	ROK-FL3-3022RWALL-FRSINK-ROK123	Lead, ppb	17.4	Science Room. At the 15ppb federal action level. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
ROK124	4/27/2018	5:09	ROK-FL3-3032ART-LSINK-ROK124	Lead, ppb	<1	Less than detection level
ROK125	4/27/2018	5:09	ROK-FL3-3032ART-LDF-ROK125	Lead, ppb	<1	Less than detection level
ROK126	4/27/2018	5:10	ROK-FL3-3032ART-RSINK-ROK126	Lead, ppb	1.84	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ROK127	4/27/2018	5:10	ROK-FL3-3032ART-RDF-ROK127	Lead, ppb	<1	Less than detection level
ROK128	4/27/2018	5:12	ROK-FL3-3030MUSIC-SINK-ROK128	Lead, ppb	<1	Less than detection level
ROK129	4/27/2018	5:12	ROK-FL3-3030MUSIC-DF-ROK129	Lead, ppb	<1	Less than detection level

Cincinnati Public Schools -Rockdale Academy - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
ROK130	4/27/2018	5:14	ROK-FL3-3027-SINK-ROK130	Lead, ppb	<1	Less than detection level
ROK131	4/27/2018	5:14	ROK-FL3-3027-DF-ROK131	Lead, ppb	<1	Less than detection level
ROK132	4/27/2018	5:16	ROK-FL3-3026-SINK-ROK132	Lead, ppb	<1	Less than detection level
ROK133	4/27/2018	5:16	ROK-FL3-3026-DF-ROK133	Lead, ppb	<1	Less than detection level
ROK134	4/27/2018	5:18	ROK-FL3-3024OFFRR-SINK-ROK134	Lead, ppb	<1	Less than detection level
ROK135	4/27/2018	5:20	ROK-FL3-3037GIRLSRR-LSINK-ROK135	Lead, ppb	<1	Less than detection level
ROK136	4/27/2018	5:20	ROK-FL3-3037GIRLSRR-RSINK-ROK136	Lead, ppb	2.12	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ROK137	4/27/2018	5:21	ROK-FL3-3039BOYSRR-LSINK-ROK137	Lead, ppb	<1	Less than detection level
ROK138	4/27/2018	5:21	ROK-FL3-3039BOYSRR-RSINK-ROK138	Lead, ppb	1.35	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ROK139	4/27/2018	5:23	ROK-FL3-3052-SINK-ROK139	Lead, ppb	<1	Less than detection level
ROK140	4/27/2018	5:23	ROK-FL3-3052-DF-ROK140	Lead, ppb	<1	Less than detection level
ROK141	4/27/2018	5:24	ROK-FL3-A3041RR-SINK-ROK141	Lead, ppb	<1	Less than detection level
ROK142	4/27/2018	5:25	ROK-FL3-B3041RR-SINK-ROK142	Lead, ppb	<1	Less than detection level
ROK143	4/27/2018	5:26	ROK-FL3-C3041RR-SINK-ROK143	Lead, ppb	<1	Less than detection level
ROK144	4/27/2018	5:27	ROK-FL3-ELA3043-SINK-ROK144	Lead, ppb	<1	Less than detection level
ROK145	4/27/2018	5:27	ROK-FL3-ELA3043-DF-ROK145	Lead, ppb	<1	Less than detection level
ROK146	4/27/2018	5:29	ROK-FL3-3049-SINK-ROK146	Lead, ppb	<1	Less than detection level
ROK147	4/27/2018	5:29	ROK-FL3-3049-DF-ROK147	Lead, ppb	<1	Less than detection level
ROK148	4/27/2018	5:30	ROK-FL3-3050-SINK-ROK148	Lead, ppb	<1	Less than detection level
ROK149	4/27/2018	5:30	ROK-FL3-3050-DF-ROK149	Lead, ppb	<1	Less than detection level
ROK150	4/27/2018	5:33	ROK-FL3-3051-SINK-ROK150	Lead, ppb	<1	Less than detection level
ROK151	4/27/2018	5:33	ROK-FL3-3051-DF-ROK151	Lead, ppb	<1	Less than detection level
ROK152	4/27/2018	5:34	ROK-FL3-A3035RR-SINK-ROK152	Lead, ppb	<1	Less than detection level
ROK153	4/27/2018	5:35	ROK-FL3-B3035RR-SINK-ROK153	Lead, ppb	<1	Less than detection level

Cincinnati Public Schools -Rockdale Academy - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
ROK154	4/27/2018	5:35	ROK-FL3-C3035RR-SINK-ROK154	Lead, ppb	1.34	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ROK155	4/27/2018	5:36	ROK-FL3-ELA3042-SINK-ROK155	Lead, ppb	1.01	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
ROK156	4/27/2018	5:36	ROK-FL3-ELA3042-DF-ROK156	Lead, ppb	<1	Less than detection level
ROK157	4/27/2018	5:38	ROK-FL3-3046-SINK-ROK157	Lead, ppb	<1	Less than detection level
ROK158	4/27/2018	5:38	ROK-FL3-3046-DF-ROK158	Lead, ppb	<1	Less than detection level
ROK159	4/27/2018	5:40	ROK-FL3-3045-SINK-ROK159	Lead, ppb	<1	Less than detection level
ROK160	4/27/2018	5:40	ROK-FL3-3045-DF-ROK160	Lead, ppb	<1	Less than detection level
ROK161	4/27/2018	5:42	ROK-FL3-3044-SINK-ROK161	Lead, ppb	<1	Less than detection level
ROK162	4/27/2018	5:42	ROK-FL3-3044-DF-ROK162	Lead, ppb	<1	Less than detection level
ROK163	4/27/2018	5:44	ROK-FL3-3043-SINK-ROK163	Lead, ppb	<1	Less than detection level
ROK164	4/27/2018	5:44	ROK-FL3-3043-DF-ROK164	Lead, ppb	<1	Less than detection level
ROK165	4/27/2018	5:52	ROK-FL2-SH/RECEPTION-DF-ROK165	Lead, ppb	<1	Less than detection level
ROK166	4/27/2018	5:55	ROK-FL2-2028-SINK-ROK166	Lead, ppb	<1	Less than detection level
N/A	N/A	N/A	ROK-FL2-2028-DF	Lead, ppb	N/A	Not sampled, turned off. Drinking fountain was off during the walkthrough.