



June 1, 2018

Cincinnati Public Schools  
Cynthia Eghbalnia  
2651 Burnet Avenue  
Cincinnati, OH 45219

## Sands Montessori School

Dear Cynthia:

Thank you for taking the responsibility seriously to protect the health of the children by voluntarily testing the water in your school for lead!

Attached please find the results of the lead analyses performed for Sands Montessori School by the Greater Cincinnati Water Works (GCWW). The following comments speak to the process, samples analyzed and additional steps needed to help ensure the safety of all the students within the school.

### School Sampling Process and Results

GCWW and Cincinnati Public Schools (CPS) staff worked together to finalize a sampling plan for the school. The *USEPA 3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance Document (3Ts Guidelines)* is the process and guidelines used for assisting schools with testing for lead.

In May, one hundred, fifty-six (156) samples were collected from drinking fountains, sinks and cooking outlets throughout the school. Multiple sinks within the schools were not initially considered for testing, however, key nearby indicators (coffee makers, drinking cups, plates, utensils, etc.) prompted additional locations to be tested in the schools. Including these sampling locations speaks to the proactive approach CPS continues to have towards understanding the water quality within the schools. The results show the following:

- 134 samples (85.9%), below the detection level (<1)
- 20 samples (12.82%), between 1ppb and 5ppb
- 1 sample (.64%), between 5ppb and 10ppb
- 0 samples (0%), between 10ppb and 15ppb
- 1 sample (.64%), greater than 15ppb.

Ninety-nine percent (99.36%) of the results were below the detection level or below the federal action level.

Fifteen parts per billion (ppb) is the federal Lead and Copper Rule action level; desired results are below 15. The federal action level of 15ppb pertains to water utilities and GCWW's review and comments are based on this action level. However, the USEPA 3Ts Guidelines document outlines practices for schools to put in place if samples are greater than 20 ppb.

While we strive to have results less than 15, we recognize that lead is a pervasive environmental contaminant, and no safe blood lead threshold has been identified in children or adults. Therefore, we provide recommendations to further reduce any lead levels discovered in your school.

### Next steps

GCWW has reviewed the results from your samples and provides some next-steps comments.

1. Great news! All the drinking fountains had no lead detections except for one location, SAM-FL2-2004-DF-SAM108. This location had a trace amount of lead. The amount is very low, however, flushing the line before use (letting the water run) will reduce the risk of lead. No further action is suggested.




2. One location had a lead detection greater than 15ppb, SAM-FL2-2003-SINK-SAM109. This location is a sink and it is assumed by the name that it is not used as a drinking water or cooking outlet. However, consider an immediate remedy such as taking the sample location out of service until a more defined plan can be created or post a sign limiting the use at this location. Refer to the USEPA 3Ts Guidelines for more information and suggestions on signage. After the location is out of service, work to reduce the lead level by first removing and cleaning the aerator as particles may be trapped on the aerator and contributing to the lead detection. Consider resampling after the cleaning.
3. Great news in the cafeteria; all locations were free of lead detections! Three (3) of the eleven (11) sample locations in the kitchen had lead detections. Flush the line before use if using these locations for food and drink preparation. No further action is suggested.
4. Other sinks had lead detections. Based on the names, they are not used for drinking water or cooking purposes.
  - a. Lead is not an issue for body contact such as bathing, showering, and washing hands.
  - a. To lower the lead levels, consider removing and cleaning the aerator. Particles may be trapped on the aerator and contributing to the lead level.
  - b. If the locations with lead detections are not used on a regular basis, then the infrequent use may be contributing to the lead detections.
5. Review how water is being used within your facility. Again, if water is not used on a regular basis at some of these locations, the infrequent use at the outlet may be contributing to the lead detections. Signage at these locations may be helpful (hand washing only, science class purposes only-no drinking, etc.).
6. If it hasn't occurred already, a robust communications plan is suggested. Communications plan steps are outlined in the 3Ts Guidelines. This plan will inform the school community of the sampling work the school has done to date and the steps the school will take to correct any issues discovered. GCWW employees can assist with this plan and are available to attend any school meetings to help explain our lead program, the sample results and our partnership with your school. Suggestions for language and a letter template can be provided if needed. Sampling results will be posted on the GCWW lead.mygcww.org website with other school sampling results.

Greater Cincinnati Water Works takes the presence of lead service lines and the removal of these lines in our system very seriously. In addition, minimizing the exposure of lead within our preschools, schools, and daycares is one of our highest priorities under our Enhanced Lead Program. Please contact Jim Nelson at 591-6869 if you have any questions.

Thanks again for your partnership with Greater Cincinnati Water Works and your work to further understand the water quality within your building. Your extra steps and care to keep the children in our community safe are appreciated!

Sincerely,



Cathy B. Bailey  
Director/Greater Cincinnati Water Works

Cc: Dr. Marilyn Crumpton, Cincinnati Health Department  
Dr. Camille Jones, Cincinnati Health Department  
Chuck DeJonckheere, Hamilton County Public Health  
Sheila Hill-Christian, City of Cincinnati  
Verna Arnette, Greater Cincinnati Water Works  
Jeff Swertfeger, Greater Cincinnati Water Works  
Jason DeLaet, Greater Cincinnati Water Works  
James Nelson, Greater Cincinnati Water Works

### Cincinnati Public Schools - Sands Montessori School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SAM1	5/4/2018	5:01:00	SAM-FL1-MOFF/WKRM-SINK-SAM1	Lead, ppb	<1	Less than detection level
SAM2	5/4/2018	5:02:00	SAM-FL1-MOFF/WKRMRR-SINK-SAM2	Lead, ppb	<1	Less than detection level
SAM3	5/4/2018	5:04:00	SAM-FL1-1060HEALTH-SINK-SAM3	Lead, ppb	<1	Less than detection level
SAM4	5/4/2018	5:04:00	SAM-FL1-1060HEALTHRR-SINK-SAM4	Lead, ppb	<1	Less than detection level
SAM5	5/4/2018	5:06:00	SAM-FL1-1070WKRM-SINK-SAM5	Lead, ppb	1.14	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAM6	5/4/2018	5:08:00	SAM-FL1-1069COMMUNITY-SINK-SAM6	Lead, ppb	<1	Less than detection level
SAM7	5/4/2018	5:08:00	SAM-FL1-1069COMMUNITY-IM-SAM7	Lead, ppb	2.37	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAM8	5/4/2018	5:11:00	SAM-FL1-HALLWAYNEAR1050RR-SINK-SAM8	Lead, ppb	<1	Less than detection level
SAM9	5/4/2018	5:12:00	SAM-FL1-1050-SINK-SAM9	Lead, ppb	1.15	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAM10	5/4/2018	5:14:00	SAM-FL1-1014-SINK-SAM10	Lead, ppb	<1	Less than detection level
SAM11	5/4/2018	5:14:00	SAM-FL1-1014-DF-SAM11	Lead, ppb	<1	Less than detection level
SAM12	5/4/2018	5:14:00	SAM-FL1-1014RR-SINK-SAM12	Lead, ppb	<1	Less than detection level
SAM13	5/4/2018	5:17:00	SAM-FL1-1012-SINK-SAM13	Lead, ppb	<1	Less than detection level
SAM14	5/4/2018	5:17:00	SAM-FL1-1012-DF-SAM14	Lead, ppb	<1	Less than detection level
SAM15	5/4/2018	5:17:00	SAM-FL1-1012RR-SINK-SAM15	Lead, ppb	<1	Less than detection level
SAM16	5/4/2018	5:19:00	SAM-FL1-ELA1203-SINK-SAM16	Lead, ppb	<1	Less than detection level
SAM17	5/4/2018	5:19:00	SAM-FL1-ELA1203-DF-SAM17	Lead, ppb	<1	Less than detection level
SAM18	5/4/2018	5:21:00	SAM-FL1-ELA1203STAFFRR-SINK-SAM18	Lead, ppb	<1	Less than detection level
SAM19	5/4/2018	5:23:00	SAM-FL1-1015-SINK-SAM19	Lead, ppb	<1	Less than detection level
SAM20	5/4/2018	5:23:00	SAM-FL1-1015-DF-SAM20	Lead, ppb	<1	Less than detection level
SAM21	5/4/2018	5:23:00	SAM-FL1-1015RR-SINK-SAM21	Lead, ppb	<1	Less than detection level
SAM22	5/4/2018	5:26:00	SAM-FL1-1013-SINK-SAM22	Lead, ppb	<1	Less than detection level
SAM23	5/4/2018	5:26:00	SAM-FL1-1013-DF-SAM23	Lead, ppb	<1	Less than detection level
SAM24	5/4/2018	5:26:00	SAM-FL1-1013RR-SINK-SAM24	Lead, ppb	<1	Less than detection level

### Cincinnati Public Schools - Sands Montessori School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SAM25	5/4/2018	5:28:00	SAM-FL1-HALLWAYNEAR1035-LDF-SAM25	Lead, ppb	<1	Less than detection level
SAM26	5/4/2018	5:28:00	SAM-FL1-HALLWAYNEAR1035-RDF-SAM26	Lead, ppb	<1	Less than detection level
SAM27	5/4/2018	5:30:00	SAM-FL1-1035WKRM-SINK-SAM27	Lead, ppb	<1	Less than detection level
SAM28	5/4/2018	5:32:00	SAM-FL1-1011-SINK-SAM28	Lead, ppb	<1	Less than detection level
SAM29	5/4/2018	5:32:00	SAM-FL1-1011-DF-SAM29	Lead, ppb	<1	Less than detection level
SAM30	5/4/2018	5:32:00	SAM-FL1-1011RR-SINK-SAM30	Lead, ppb	<1	Less than detection level
SAM31	5/4/2018	5:35:00	SAM-FL1-1010-SINK-SAM31	Lead, ppb	<1	Less than detection level
SAM32	5/4/2018	5:35:00	SAM-FL1-1010-DF-SAM32	Lead, ppb	<1	Less than detection level
SAM33	5/4/2018	5:35:00	SAM-FL1-1010RR-SINK-SAM33	Lead, ppb	<1	Less than detection level
SAM34	5/4/2018	5:37:00	SAM-FL1-ELA1202-SINK-SAM34	Lead, ppb	<1	Less than detection level
SAM35	5/4/2018	5:37:00	SAM-FL1-ELA1202-DF-SAM35	Lead, ppb	<1	Less than detection level
SAM36	5/4/2018	5:39:00	SAM-FL1-1008-SINK-SAM36	Lead, ppb	<1	Less than detection level
SAM37	5/4/2018	5:39:00	SAM-FL1-1008-DF-SAM37	Lead, ppb	<1	Less than detection level
SAM38	5/4/2018	5:39:00	SAM-FL1-1008RR-SINK-SAM38	Lead, ppb	<1	Less than detection level
SAM39	5/4/2018	5:45:00	SAM-FL1-1023-SINK-SAM39	Lead, ppb	<1	Less than detection level
SAM40	5/4/2018	5:45:00	SAM-FL1-1023-DF-SAM40	Lead, ppb	<1	Less than detection level
SAM41	5/4/2018	5:47:00	SAM-FL1-HALLWAYNEAR1007RR-SINK-SAM41	Lead, ppb	<1	Less than detection level
SAM42	5/4/2018	5:53:00	SAM-FL1-1006ART-LSINK-SAM42	Lead, ppb	1.08	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAM43	5/4/2018	5:53:00	SAM-FL1-1006ART-MSINK-SAM43	Lead, ppb	<1	Less than detection level
SAM44	5/4/2018	5:53:00	SAM-FL1-1006ART-RSINK-SAM44	Lead, ppb	1.18	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAM45	5/4/2018	5:52:00	SAM-FL1-HALLWAYNEAR1005RR-SINK-SAM45	Lead, ppb	<1	Less than detection level
SAM46	5/4/2018	5:52:00	SAM-FL1-1022-SINK-SAM46	Lead, ppb	<1	Less than detection level
SAM47	5/4/2018	5:49:00	SAM-FL1-1005-SINK-SAM47	Lead, ppb	<1	Less than detection level
SAM48	5/4/2018	5:49:00	SAM-FL1-1005-DF-SAM48	Lead, ppb	<1	Less than detection level
SAM49	5/4/2018	5:05:00	SAM-FL1-ELA1201RR#1-SINK-SAM49	Lead, ppb	<1	Less than detection level
SAM50	5/4/2018	5:06:00	SAM-FL1-ELA1201RR#2-SINK-SAM50	Lead, ppb	<1	Less than detection level

### Cincinnati Public Schools - Sands Montessori School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SAM51	5/4/2018	5:07:00	SAM-FL1-ELA1201RR#3-SINK-SAM51	Lead, ppb	<1	Less than detection level
SAM52	5/4/2018	5:08:00	SAM-FL1-ELA1201RR#4-SINK-SAM52	Lead, ppb	<1	Less than detection level
SAM53	5/4/2018	5:09:00	SAM-FL1-HALLWAYNEAR1005-LDF-SAM53	Lead, ppb	<1	Less than detection level
SAM54	5/4/2018	5:10:00	SAM-FL1-HALLWAYNEAR1005-RDF-SAM54	Lead, ppb	<1	Less than detection level
SAM55	5/4/2018	5:11:00	SAM-FL1-1003-SINK-SAM55	Lead, ppb	2.27	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAM56	5/4/2018	5:12:00	SAM-FL1-1003-DF-SAM56	Lead, ppb	<1	Less than detection level
SAM57	5/4/2018	5:13:00	SAM-FL1-1001-SINK-SAM57	Lead, ppb	<1	Less than detection level
SAM58	5/4/2018	5:14:00	SAM-FL1-1001-DF-SAM58	Lead, ppb	<1	Less than detection level
SAM59	5/4/2018	5:15:00	SAM-FL1-ELA1201-SINK-SAM59	Lead, ppb	<1	Less than detection level
SAM60	5/4/2018	5:16:00	SAM-FL1-ELA1201-DF-SAM60	Lead, ppb	<1	Less than detection level
SAM61	5/4/2018	5:17:00	SAM-FL1-1002-SINK-SAM61	Lead, ppb	1.08	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAM62	5/4/2018	5:18:00	SAM-FL1-1002-DF-SAM62	Lead, ppb	<1	Less than detection level
SAM63	5/4/2018	5:19:00	SAM-FL1-1004-SINK-SAM63	Lead, ppb	<1	Less than detection level
SAM64	5/4/2018	5:20:00	SAM-FL1-1004-DF-SAM64	Lead, ppb	<1	Less than detection level
SAM65	5/4/2018	5:22:00	SAM-KIT-NEARSTORAGE-HANDSINK-SAM65	Lead, ppb	1.55	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAM66	5/4/2018	5:23:00	SAM-KIT-NEAR2TUB-HANDSINK-SAM66	Lead, ppb	<1	Less than detection level
SAM67	5/4/2018	5:24:00	SAM-KIT-2TUB-SINK-SAM67	Lead, ppb	<1	Less than detection level
SAM68	5/4/2018	5:25:00	SAM-KIT-STOCKPOT-LFILLER-SAM68	Lead, ppb	1.29	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAM69	5/4/2018	5:26:00	SAM-KIT-STOCKPOT-RFILLER-SAM69	Lead, ppb	<1	Less than detection level
SAM70	5/4/2018	5:27:00	SAM-KIT-ISLAND1TUBNEARCOOL-SINK-SAM70	Lead, ppb	<1	Less than detection level
SAM71	5/4/2018	5:28:00	SAM-KIT-STAFFLOCKRR-SINK-SAM71	Lead, ppb	<1	Less than detection level

### Cincinnati Public Schools - Sands Montessori School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SAM72	5/4/2018	5:29:00	SAM-KIT-ISLAND1TUBNEAROFF-SINK-SAM72	Lead, ppb	6.96	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAM73	5/4/2018	5:30:00	SAM-KIT-NEARDISHRM-HANDSINK-SAM73	Lead, ppb	<1	Less than detection level
SAM74	5/4/2018	5:31:00	SAM-KIT-DISHRM3TUB-LSINK-SAM74	Lead, ppb	<1	Less than detection level
SAM75	5/4/2018	5:32:00	SAM-KIT-DISHRM3TUB-RSINK-SAM75	Lead, ppb	<1	Less than detection level
SAM76	5/4/2018	5:34:00	SAM-FL1-1094MUSIC-SINK-SAM76	Lead, ppb	3.17	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAM77	5/4/2018	5:35:00	SAM-FL1-1094MUSIC-DF-SAM77	Lead, ppb	<1	Less than detection level
SAM78	5/4/2018	5:36:00	SAM-FL1-LSUZUKI-LSINK-SAM78	Lead, ppb	3.12	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAM79	5/4/2018	5:37:00	SAM-FL1-LSUZUKI-RSINK-SAM79	Lead, ppb	<1	Less than detection level
SAM80	5/4/2018	5:38:00	SAM-FL1-HALLWAYNEAR1094-LDF-SAM80	Lead, ppb	<1	Less than detection level
SAM81	5/4/2018	5:39:00	SAM-FL1-HALLWAYNEAR1094-RDF-SAM81	Lead, ppb	<1	Less than detection level
SAM82	5/4/2018	5:40:00	SAM-FL1-CAFEHANDWASH-LSINK-SAM82	Lead, ppb	<1	Less than detection level
SAM83	5/4/2018	5:41:00	SAM-FL1-CAFEHANDWASH-RSINK-SAM83	Lead, ppb	<1	Less than detection level
SAM84	5/4/2018	5:42:00	SAM-FL1-CAFE-LDF-SAM84	Lead, ppb	<1	Less than detection level
SAM85	5/4/2018	5:43:00	SAM-FL1-CAFE-RCOMBOBF-SAM85	Lead, ppb	<1	Less than detection level
SAM86	5/4/2018	5:44:00	SAM-FL1-CAFE-RCOMBODF-SAM86	Lead, ppb	<1	Less than detection level
SAM87	5/4/2018	5:45:00	SAM-FL1-GYMPEOFFRR-SINK-SAM87	Lead, ppb	<1	Less than detection level
SAM88	5/4/2018	5:48:00	SAM-FL1-GIRLSRRNEARGYM-FLSINK-SAM88	Lead, ppb	<1	Less than detection level
SAM89	5/4/2018	5:49:00	SAM-FL1-GIRLSRRNEARGYM-LSINK-SAM89	Lead, ppb	<1	Less than detection level
SAM90	5/4/2018	5:50:00	SAM-FL1-GIRLSRRNEARGYM-MSINK-SAM90	Lead, ppb	<1	Less than detection level
SAM91	5/4/2018	5:51:00	SAM-FL1-GIRLSRRNEARGYM-RSINK-SAM91	Lead, ppb	<1	Less than detection level
SAM92	5/4/2018	5:52:00	SAM-FL1-GIRLSRRNEARGYM-FRSINK-SAM92	Lead, ppb	<1	Less than detection level
SAM93	5/4/2018	5:53:00	SAM-FL1-HALLWAYNEARMECHRR-SINK-SAM93	Lead, ppb	<1	Less than detection level
SAM94	5/4/2018	5:03:00	SAM-FL1-BOYSRRNEARGYM-FLSINK-SAM94	Lead, ppb	<1	Less than detection level
SAM95	5/4/2018	5:03:00	SAM-FL1-BOYSRRNEARGYM-LSINK-SAM95	Lead, ppb	<1	Less than detection level

### Cincinnati Public Schools - Sands Montessori School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SAM96	5/4/2018	5:03:00	SAM-FL1-BOYSRRNEARGYM-MSINK-SAM96	Lead, ppb	<1	Less than detection level
SAM97	5/4/2018	5:03:00	SAM-FL1-BOYSRRNEARGYM-RSINK-SAM97	Lead, ppb	<1	Less than detection level
SAM98	5/4/2018	5:03:00	SAM-FL1-BOYSRRNEARGYM-FRSINK-SAM98	Lead, ppb	<1	Less than detection level
SAM99	5/4/2018	5:05:00	SAM-FL1-HALLWAYNEARGYM-LDF-SAM99	Lead, ppb	<1	Less than detection level
SAM100	5/4/2018	5:05:00	SAM-FL1-HALLWAYNEARGYM-RDF-SAM100	Lead, ppb	<1	Less than detection level
SAM101	5/4/2018	5:09:00	SAM-FL2-ELA2201-SINK-SAM101	Lead, ppb	2.21	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAM102	5/4/2018	5:09:00	SAM-FL2-ELA2201-DF-SAM102	Lead, ppb	<1	Less than detection level
SAM103	5/4/2018	5:10:00	SAM-FL2-2001-SINK-SAM103	Lead, ppb	<1	Less than detection level
SAM104	5/4/2018	5:10:00	SAM-FL2-2001-DF-SAM104	Lead, ppb	<1	Less than detection level
SAM105	5/4/2018	5:11:00	SAM-FL2-2002-SINK-SAM105	Lead, ppb	<1	Less than detection level
SAM106	5/4/2018	5:11:00	SAM-FL2-2002-DF-SAM106	Lead, ppb	<1	Less than detection level
SAM107	5/4/2018	5:12:00	SAM-FL2-2004-SINK-SAM107	Lead, ppb	<1	Less than detection level
SAM108	5/4/2018	5:12:00	SAM-FL2-2004-DF-SAM108	Lead, ppb	1.18	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAM109	5/4/2018	5:13:00	SAM-FL2-2003-SINK-SAM109	Lead, ppb	18.1	At the 15ppb federal action level. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
SAM110	5/4/2018	5:13:00	SAM-FL2-2003-DF-SAM110	Lead, ppb	<1	Less than detection level
SAM111	5/4/2018	5:15:00	SAM-FL2-ELA2201RR#1-SINK-SAM111	Lead, ppb	<1	Less than detection level
SAM112	5/4/2018	5:15:00	SAM-FL2-ELA2201RR#2-SINK-SAM112	Lead, ppb	<1	Less than detection level
SAM113	5/4/2018	5:19:00	SAM-FL2-ELA2201RR#3-SINK-SAM113	Lead, ppb	<1	Less than detection level
SAM114	5/4/2018	5:19:00	SAM-FL2-ELA2201RR#4-SINK-SAM114	Lead, ppb	<1	Less than detection level
SAM115	5/4/2018	5:17:00	SAM-FL2-HALLWAYNEAR2004-LDF-SAM115	Lead, ppb	<1	Less than detection level
SAM116	5/4/2018	5:17:00	SAM-FL2-HALLWAYNEAR2004-RDF-SAM116	Lead, ppb	<1	Less than detection level

### Cincinnati Public Schools - Sands Montessori School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SAM117	5/4/2018	5:20:00	SAM-FL2-2212-SINK-SAM117	Lead, ppb	1.02	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAM118	5/4/2018	5:21:00	SAM-FL2-HALLWAYNEAR2212RR-SINK-SAM118	Lead, ppb	<1	Less than detection level
SAM119	5/4/2018	5:22:00	SAM-FL2-2005-SINK-SAM119	Lead, ppb	1.19	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAM120	5/4/2018	5:22:00	SAM-FL2-2005-DF-SAM120	Lead, ppb	<1	Less than detection level
SAM121	5/4/2018	5:23:00	SAM-FL2-2006-SINK-SAM121	Lead, ppb	<1	Less than detection level
SAM122	5/4/2018	5:23:00	SAM-FL2-2006-DF-SAM122	Lead, ppb	<1	Less than detection level
SAM123	5/4/2018	5:24:00	SAM-FL2-ELA2202-SINK-SAM123	Lead, ppb	<1	Less than detection level
SAM124	5/4/2018	5:24:00	SAM-FL2-ELA2202-DF-SAM124	Lead, ppb	<1	Less than detection level
SAM125	5/4/2018	5:25:00	SAM-FL2-2008-SINK-SAM125	Lead, ppb	<1	Less than detection level
SAM126	5/4/2018	5:25:00	SAM-FL2-2008-DF-SAM126	Lead, ppb	<1	Less than detection level
SAM127	5/4/2018	5:26:00	SAM-FL2-2009-SINK-SAM127	Lead, ppb	1.08	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAM128	5/4/2018	5:26:00	SAM-FL2-2009-DF-SAM128	Lead, ppb	<1	Less than detection level
SAM129	5/4/2018	5:27:00	SAM-FL2-2010-SINK-SAM129	Lead, ppb	<1	Less than detection level
SAM130	5/4/2018	5:27:00	SAM-FL2-2010-DF-SAM130	Lead, ppb	<1	Less than detection level
SAM131	5/4/2018	5:28:00	SAM-FL2-ELA2203-SINK-SAM131	Lead, ppb	<1	Less than detection level
SAM132	5/4/2018	5:28:00	SAM-FL2-ELA2203-DF-SAM132	Lead, ppb	<1	Less than detection level
SAM133	5/4/2018	5:29:00	SAM-FL2-2011-SINK-SAM133	Lead, ppb	<1	Less than detection level
SAM134	5/4/2018	5:29:00	SAM-FL2-2011-DF-SAM134	Lead, ppb	<1	Less than detection level
SAM135	5/4/2018	5:31:00	SAM-FL2-2012-SINK-SAM135	Lead, ppb	<1	Less than detection level
SAM136	5/4/2018	5:31:00	SAM-FL2-2012-DF-SAM136	Lead, ppb	<1	Less than detection level
SAM137	5/4/2018	5:32:00	SAM-FL2-ELA2204RR#5-SINK-SAM137	Lead, ppb	<1	Less than detection level
SAM138	5/4/2018	5:32:00	SAM-FL2-ELA2204RR#6-SINK-SAM138	Lead, ppb	<1	Less than detection level
SAM139	5/4/2018	5:33:00	SAM-FL2-ELA2204RR#7-SINK-SAM139	Lead, ppb	<1	Less than detection level
SAM140	5/4/2018	5:33:00	SAM-FL2-ELA2204RR#8-SINK-SAM140	Lead, ppb	<1	Less than detection level



### Cincinnati Public Schools - Sands Montessori School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SAM141	5/4/2018	5:34:00	SAM-FL2-HALLWAYNEAR2013-LDF-SAM141	Lead, ppb	<1	Less than detection level
SAM142	5/4/2018	5:34:00	SAM-FL2-HALLWAYNEAR2013-RDF-SAM142	Lead, ppb	<1	Less than detection level
SAM143	5/4/2018	5:39:00	SAM-FL2-2013-SINK-SAM143	Lead, ppb	1.28	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAM144	5/4/2018	5:39:00	SAM-FL2-2013-DF-SAM144	Lead, ppb	<1	Less than detection level
SAM145	5/4/2018	5:40:00	SAM-FL2-2235-SINK-SAM145	Lead, ppb	2.04	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAM146	5/4/2018	5:40:00	SAM-FL2-HALLWAYNEAR2235RR-SINK-SAM146	Lead, ppb	<1	Less than detection level
SAM147	5/4/2018	5:42:00	SAM-FL2-2014-SINK-SAM147	Lead, ppb	1.28	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAM148	5/4/2018	5:42:00	SAM-FL2-2014-DF-SAM148	Lead, ppb	<1	Less than detection level
SAM149	5/4/2018	5:43:00	SAM-FL2-2015-SINK-SAM149	Lead, ppb	<1	Less than detection level
SAM150	5/4/2018	5:43:00	SAM-FL2-2015-DF-SAM150	Lead, ppb	<1	Less than detection level
SAM151	5/4/2018	5:44:00	SAM-FL2-2017-SINK-SAM151	Lead, ppb	<1	Less than detection level
SAM152	5/4/2018	5:44:00	SAM-FL2-2017-DF-SAM152	Lead, ppb	<1	Less than detection level
SAM153	5/4/2018	5:45:00	SAM-FL2-2016-SINK-SAM153	Lead, ppb	<1	Less than detection level
SAM154	5/4/2018	5:45:00	SAM-FL2-2016-DF-SAM154	Lead, ppb	<1	Less than detection level
SAM155	5/4/2018	5:46:00	SAM-FL2-ELA2204-SINK-SAM155	Lead, ppb	1.7	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAM156	5/4/2018	5:46:00	SAM-FL2-ELA2204-DF-SAM156	Lead, ppb	<1	Less than detection level