



April 24, 2017

St. Rita School for the Deaf
Ken Raupach
1720 Glendale Milford Rd.
Cincinnati, OH 45215

Dear Mr. Raupach:

Thank you for taking the responsibility seriously to protect the health of the children by voluntarily testing the water in your school for lead!

Attached please find the results of the lead analyses performed for St. Rita School for the Deaf by the Greater Cincinnati Water Works (GCWW). The following comments speak to the process, samples analyzed and additional steps needed to help ensure the safety of all the students within the school.

School Sampling Process and Results

GCWW and St. Rita staff worked together to finalize a sampling plan for the school. The *USEPA 3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance Document (3Ts Guidelines)* is the process and guidelines used for assisting schools with testing for lead.

In March, one hundred, sixty-one (161) samples were collected from drinking fountains, sinks, showers, tubs, and cooking outlets throughout the school. Including these sampling locations speaks to the proactive approach St. Rita has towards understanding the water quality within the school. Eight additional sample locations were not in service during the sampling process (turned off for the season). Given that showers and tubs were included, your samples were separated into 2 groups: Group 1-drinking fountains, sinks, and cooking outlets and Group 2-showers and tubs. The results for Group 1 (124 samples) show the following:

GROUP 1

- 59 samples (47.58%), below the detection level (<1)
- 47 samples (37.90%), between 1ppb and 5ppb
- 11 samples (8.87%), between 5ppb and 10ppb
- 3 samples (2.42%) between 10ppb and 15ppb
- 3 samples (2.42%) greater than 15ppb
- 1 sample (0.81%) greater than 100ppb.

Ninety-six percent (96.77%) of the samples results in Group 1 were below the detection level or below the federal action level of 15ppb.

Fifteen parts per billion (ppb) is the federal Lead and Copper Rule action level; desired results are below 15. The federal action level of 15ppb pertains to water utilities and GCWW's review and comments are based on this action level. However, the USEPA 3Ts Guidelines document outlines practices for schools to put in place if samples are greater than 20 ppb.



While we strive to have results less than 15, we recognize that lead is a pervasive environmental contaminant, and no safe blood lead threshold has been identified in children or adults. Therefore, we provide recommendations to further reduce any lead levels discovered in your school.

Next steps

A number of next steps and suggestions to reduce the risk of lead are outlined below. GCWW is available to discuss these suggestions with you if you desire.

GROUP 1

1. Great news! Two (2) out of ten (10) drinking fountains had minimum lead detections; the rest were below the detection level. To further reduce the lead at these 2 locations, flush the line (let the water run) before use. No further action is needed.
2. One sink, sample SRSD-GFL-G2OFFICE-SINK-SRSD26, had an extremely high lead detection. Three additional sinks, SRSD-GFL-HSSCIENCEDESK-LSINK-SRSD29, SRSD-GFL-HSSCIENCEDESK-LSINK-SRSD31 and SRSD-GFL-HSSCIENCERDESK-LSINK-SRSD33, had results greater than 15ppb. Based on the sample names, it is assumed these are not drinking water or cooking outlets. Although the locations are not used for these purposes, consider immediate remedies such as taking the sample locations out of service until a more defined plan can be created OR post a sign above the locations limiting the purpose of the sinks ('hand washing only', 'work sink only'). Posting a sign will deter students and staff from potentially using the sinks to fill a water bottle, etc. For more information, refer to the 3Ts Guidelines that suggest shutting off or disconnecting problem outlets until the problem is resolved.
3. Seven (7) of the nine (9) kitchen samples had some level of lead detected. To further reduce the risk of lead when preparing drinks, food and meals, flush the line (let the water run) before use.
4. Four (4) sample locations were in a daycare (SRSDBH-UL-LOFTSTAFFRR-SINK-SRSD151, SRSDBH-UL-LOFTKIT-SINK-SRSD152, SRSDBH-UL-LOFTINFENTSRM-SINK-SRSD153, and SRSDBH-UL-LOFTRR-SINK-SRSD154). Two of the four samples had minimal lead detections. If interested in further reducing these low values, flush the line (let the water run) before use. However, no further action is needed at these sample locations.
5. All eight (8) samples in the science room had lead detections. Post signs in this room to deter students and staff from potentially using the sinks to fill a water bottle, etc.
6. Eight (8) additional sample locations were turned off for the season. GCWW can assist with analyzing samples from these locations at a later date.

GROUP 2

Results for Group 2 show the following:

7. Thirty-seven sample locations were showers and tubs.
 - 4 samples (10.81%), below the detection level (<1)
 - 7 samples (18.92%), between 1ppb and 5ppb
 - 6 samples (16.22%), between 5ppb and 10ppb
 - 0 samples (0%) between 10ppb and 15ppb
 - 11 samples (29.73%) greater than 15ppb and less than 100ppb
 - 9 samples (24.32%) greater than 100ppb.

Lead is not an issue for body contact such as bathing, showering, and washing hands. However, it is assumed that the school wants to identify ways to further reduce the risk of lead at all locations. Assuming this, until the showers and tubs are remediated (ex: plumbing profile, consideration of fixes at each location), the school should take steps to ensure that water is not obtained from these outlets for making sports drinks, filling water coolers or bottles, etc. that are intended for drinking. Again posting signs limiting the use and explaining this will be helpful to deter students and staff from using these locations as drinking water outlets.

General comments for both Groups

8. Although lower than the 15 ppb action level, for other samples with lead detections, consider flushing the line before using the water. Refer to the USEPA 3Ts Guidelines for more information. As an added precaution, again, consider posting signs at sink locations indicating 'hand washing only' (or other specific purposes) as these locations should not be used as drinking water or cooking outlets.
9. Review how water is being used within your facility. If water is not used on a regular basis at some of these outlets, the infrequent use at the outlet may be contributing to the lead detections. This could be the case in the science room. Again, signage at these locations may be helpful (hand washing only, etc.).
10. Consider completing a plumbing profile to review the fixtures in the school as some fixtures may be contributing to the lead detections in samples. If the fixtures are the source of the lead, plan to replace them. The USEPA 3Ts Guidelines outlines a great approach to creating and implementing a remediation plan. A copy of the Guidelines can be found on our website <http://www.cincinnati-oh.gov/water/assets/File/3T%20Guidance%20Manual%20for%20Schools.pdf>.

State funds are available through the new Lead Plumbing Fixture Replacement Assistance Grant Program established to provide reimbursement to eligible schools for the assessment and replacement of certain plumbing fixtures. The Program was established in House Bill 390 to provide \$12,000,000 in funding to eligible schools to reimburse for the sampling and replacement of drinking fountains, water coolers, plumbing fixtures, and limited connected piping. Schools built before 1990 can apply for reimbursement up to \$15,000 for sampling of eligible fixtures and the material costs to replace those fixtures if they are identified as being over the federal action level for lead. The program is open to traditional public schools, community schools, and chartered non-public schools. Program information can be found on the Ohio Facilities Construction Commission (OFCC) Services and Programs website <http://ofcc.ohio.gov/ServicesPrograms/LeadFixtureReplacementGrants.aspx>.


11. For the sample locations with lead detections, we have known and learned from other schools (that are participating in this program) that cleaning the faucet and aerator may reduce the lead levels. This is due to the cleaning that removes trapped particles on the aerator. Cleaning may help reduce the lead levels further and may prove to be more helpful than a complete plumbing profile. Follow-up sampling can occur at these locations; GCWW can assist with this.

12. If it hasn't occurred already, a robust communications plan is suggested. Communications plan steps are outlined in the 3Ts Guidelines. This plan will inform the school community of the sampling work the school has done to date and the steps the school will take to correct any issues discovered. GCWW employees can assist with this plan and are available to attend any school meetings to help explain our lead program, the sample results and our partnership with your school. Suggestions for language and a letter template can be provided if needed. Sampling results will be posted on the GCWW lead.mycww.org website with other school sampling results.

Greater Cincinnati Water Works takes the presence of lead service lines and the removal of those service lines in our system very seriously. In addition, minimizing the exposure of lead within our preschools, schools, and daycares is one of our highest priorities under our Enhanced Lead Program. Please contact Jim Nelson at 591-6869 if you have any questions.

Thanks again for your partnership with Greater Cincinnati Water Works and your work to further understand the water quality within your building. Your extra steps and care to keep the children in our community safe are appreciated!

Sincerely,



Cathy B. Bailey
Director/Greater Cincinnati Water Works

Cc: Dr. Marilyn Crumpton, Cincinnati Health Department
Dr. Camille Jones, Cincinnati Health Department
Chuck DeJonckheere, Hamilton County Public Health
Sheila Hill-Christian, City of Cincinnati
Verna Arnette, Greater Cincinnati Water Works
Jeff Swertfeger, Greater Cincinnati Water Works
Jason DeLaet, Greater Cincinnati Water Works

St. Rita School for the Deaf - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SRSD1	3/4/2017	6:40:00	SRSD-GFL-GIRLSLOCK-FLSINK-SRSD1	Lead, ppb	2.57	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD2	3/4/2017	6:40:00	SRSD-GFL-GIRLSLOCK-LSINK-SRSD2	Lead, ppb	5.18	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD3	3/4/2017	6:41:00	SRSD-GFL-GIRLSLOCK-RSINK-SRSD3	Lead, ppb	1.97	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD4	3/4/2017	6:40:00	SRSD-GFL-GIRLSLOCK-FRSINK-SRSD4	Lead, ppb	1.46	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD11	3/4/2017	6:35:00	SRSD-GFL-HALLWAYNEARBOYSLOCK-DF-SRSD11	Lead, ppb	<1	Less than detection level
SRSD12	3/4/2017	6:34:00	SRSD-GFL-BOYSLOCK-FLSINK-SRSD12	Lead, ppb	<1	Less than detection level
SRSD13	3/4/2017	6:34:00	SRSD-GFL-BOYSLOCK-LSINK-SRSD13	Lead, ppb	4.27	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD14	3/4/2017	6:34:00	SRSD-GFL-BOYSLOCK-RSINK-SRSD14	Lead, ppb	12.8	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

St. Rita School for the Deaf - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SRSD15	3/4/2017	6:34:00	SRSD-GFL-BOYSLOCK-FRSINK-SRSD15	Lead, ppb	9.91	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD23	3/4/2017	6:25:00	SRSD-GFL-MSABOYSRR-SINK-SRSD23	Lead, ppb	<1	Less than detection level
SRSD24	3/4/2017	6:24:00	SRSD-GFL-MSAGIRLSRR-SINK-SRSD24	Lead, ppb	<1	Less than detection level
SRSD25	3/4/2017	6:24:00	SRSD-GFL-MSA-DF-SRSD25	Lead, ppb	1.12	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD26	3/4/2017	6:22:00	SRSD-GFL-G2OFFICE-SINK-SRSD26	Lead, ppb	198	Above 15ppb federal action level and the 20ppb trigger level to take action as explained in the USEPA 3Ts Guidelines for schools. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
SRSD27	3/4/2017	6:20:00	SRSD-GFL-JRSCIENCEFRONTDESK-SINK-SRSD27	Lead, ppb	3.62	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD28	3/4/2017	6:20:00	SRSD-GFL-HALLWAYSCIENCE-DF-SRSD28	Lead, ppb	<1	Less than detection level

St. Rita School for the Deaf - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SRSD29	3/4/2017	6:18:00	SRSD-GFL-HSSCIENCEDESK-LSINK-SRSD29	Lead, ppb	17.8	Above 15ppb federal action level. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
SRSD30	3/4/2017	6:18:00	SRSD-GFL-HSSCIENCEDESK-RSINK-SRSD30	Lead, ppb	14.3	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD31	3/4/2017	6:17:00	SRSD-GFL-HSSCIENCEMDESK-LSINK-SRSD31	Lead, ppb	20.9	Above 15ppb federal action level and the 20ppb trigger level to take action as explained in the USEPA 3Ts Guidelines for schools. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
SRSD32	3/4/2017	6:17:00	SRSD-GFL-HSSCIENCEMDESK-RSINK-SRSD32	Lead, ppb	5.82	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD33	3/4/2017	6:16:00	SRSD-GFL-HSSCIENCERDESK-LSINK-SRSD33	Lead, ppb	15.2	Above 15ppb federal action level. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).

St. Rita School for the Deaf - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SRSD34	3/4/2017	6:16:00	SRSD-GFL-HSSCIENCERDESK-RSINK-SRSD34	Lead, ppb	4.36	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD35	3/4/2017	6:13:00	SRSD-GFL-HSSCIENCEBWALLDESK-SINK-SRSD35	Lead, ppb	4.51	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD36	3/4/2017	6:46:00	SRSD-FL1-ANNEX-SINK-SRSD36	Lead, ppb	<1	Less than detection level
SRSD37	3/4/2017	6:46:00	SRSD-FL1-ANNEX-IM-SRSD37	Lead, ppb	<1	Less than detection level
SRSD38	3/4/2017	6:47:00	SRSD-FL1-ANNEX-BF-SRSD38	Lead, ppb	<1	Less than detection level
SRSD39	3/4/2017	6:48:00	SRSD-FL1-ANNEX-DF-SRSD39	Lead, ppb	<1	Less than detection level
SRSD40	3/4/2017	6:49:00	SRSD-FL1-BOYSRRNEARANNEX-LSINK-SRSD40	Lead, ppb	<1	Less than detection level
SRSD41	3/4/2017	6:49:00	SRSD-FL1-BOYSRRNEARANNEX-MSINK-SRSD41	Lead, ppb	<1	Less than detection level
SRSD42	3/4/2017	6:49:00	SRSD-FL1-BOYSRRNEARANNEX-RSINK-SRSD42	Lead, ppb	<1	Less than detection level
SRSD43	3/4/2017	6:50:00	SRSD-FL1-GIRLSRRNEARANNEX-LSINK-SRSD43	Lead, ppb	<1	Less than detection level
SRSD44	3/4/2017	6:50:00	SRSD-FL1-GIRLSRRNEARANNEX-RSINK-SRSD44	Lead, ppb	<1	Less than detection level
SRSD45	3/4/2017	6:52:00	SRSD-FL1-HALLWAYNEARUSA-DF-SRSD45	Lead, ppb	<1	Less than detection level
SRSD46	3/4/2017	6:52:00	SRSD-FL1-DEVELOPMENTMENSRR-LSINK-SRSD46	Lead, ppb	4.04	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD47	3/4/2017	6:52:00	SRSD-FL1-DEVELOPMENTMENSRR-RSINK-SRSD47	Lead, ppb	<1	Less than detection level
SRSD48	3/4/2017	6:53:00	SRSD-FL1-GIRLSRRNEARUSA-LSINK-SRSD48	Lead, ppb	<1	Less than detection level
SRSD49	3/4/2017	6:53:00	SRSD-FL1-GIRLSRRNEARUSA-RSINK-SRSD49	Lead, ppb	<1	Less than detection level
SRSD50	3/4/2017	6:55:00	SRSD-FL1-HOMEECINSIDEWALL-SINK-SRSD50	Lead, ppb	1.02	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

St. Rita School for the Deaf - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SRSD51	3/4/2017	6:55:00	SRSD-FL1-HOMEEOUTSIDEWALL-SINK-SRSD51	Lead, ppb	1.6	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD52	3/4/2017	6:57:00	SRSD-FL1-KIT-IM-SRSD52	Lead, ppb	<1	Less than detection level
SRSD53	3/4/2017	6:57:00	SRSD-FL1-KIT-SPRAYER-SRSD53	Lead, ppb	5.38	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD54	3/4/2017	6:57:00	SRSD-FL1-KIT3TUB-LSINK-SRSD54	Lead, ppb	1.98	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD55	3/4/2017	6:58:00	SRSD-FL1-KIT3TUB-RSINK-SRSD55	Lead, ppb	1.84	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD56	3/4/2017	6:58:00	SRSD-FL1-KIT2TUBNEARFRIDGE-SINK-SRSD56	Lead, ppb	2.31	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD57	3/4/2017	6:58:00	SRSD-FL1-KITISLANDNEARFRIDGE-SINK-SRSD57	Lead, ppb	1.02	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

St. Rita School for the Deaf - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SRSD58	3/4/2017	7:01:00	SRSD-FL1-KITSTOCKPOTFILLER-FAUCET-SRSD58	Lead, ppb	3.73	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD59	3/4/2017	7:00:00	SRSD-FL1-KITSTOCKPOTFILLER-HOSE-SRSD59	Lead, ppb	<1	Less than detection level
SRSD60	3/4/2017	7:02:00	SRSD-FL1-STAFFCAFE-JUICEMACHINE-SRSD60	Lead, ppb	3.24	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD61	3/4/2017	7:00:00	SRSD-FL1-KIT-HANDSINK-SRSD61	Lead, ppb	2.2	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD67	3/4/2017	7:10:00	SRSD-FL2-GIRLSDORMMRRNEAR235-FLSINK-SRSD67	Lead, ppb	<1	Less than detection level
SRSD68	3/4/2017	7:10:00	SRSD-FL2-GIRLSDORMMRRNEAR235-LSINK-SRSD68	Lead, ppb	<1	Less than detection level
SRSD69	3/4/2017	7:11:00	SRSD-FL2-GIRLSDORMMRRNEAR235-RSINK-SRSD69	Lead, ppb	<1	Less than detection level
SRSD70	3/4/2017	7:11:00	SRSD-FL2-GIRLSDORMMRRNEAR235-FRSINK-SRSD70	Lead, ppb	<1	Less than detection level
SRSD71	3/4/2017	7:12:00	SRSD-FL2-GIRLSDORMMRRNEARCOLLEGEDORM-FLSINK-SRSD71	Lead, ppb	2.57	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD72	3/4/2017	7:12:00	SRSD-FL2-GIRLSDORMMRRNEARCOLLEGEDORM-LSINK-SRSD72	Lead, ppb	3.64	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

St. Rita School for the Deaf - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SRSD73	3/4/2017	7:14:00	SRSD-FL2-GIRLSDORMRRNEARCOLLEGEDORM-RSINK-SRSD73	Lead, ppb	5.82	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD74	3/4/2017	7:14:00	SRSD-FL2-GIRLSDORMRRNEARCOLLEGEDORM-FRSINK-SRSD74	Lead, ppb	6.08	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD75	3/4/2017	7:15:00	SRSD-FL2-RAGIRLSDORMRR-SINK-SRSD75	Lead, ppb	<1	Less than detection level
SRSD78	3/4/2017	7:17:00	SRSD-FL2-CHAPELPRIEST-SINK-SRSD78	Lead, ppb	2.55	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD79	3/4/2017	7:19:00	SRSD-FL2-CHAPELSISTER-SINK-SRSD79	Lead, ppb	13.6	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD80	3/4/2017	7:18:00	SRSD-FL2-BOYSRRNEAR224-SINK-SRSD80	Lead, ppb	<1	Less than detection level
SRSD81	3/4/2017	7:19:00	SRSD-FL2-GIRLSRRNEAR224-SINK-SRSD81	Lead, ppb	<1	Less than detection level
SRSD82	3/4/2017	7:19:00	SRSD-FL2-GIRLSRR NEAR227-SINK-SRSD82	Lead, ppb	1.09	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD83	3/4/2017	7:24:00	SRSD-FL2-BOYSRRNEAR214-LSINK-SRSD83	Lead, ppb	2.35	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

St. Rita School for the Deaf - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SRSD84	3/4/2017	7:24:00	SRSD-FL2-BOYSRRNEAR214-RSINK-SRSD84	Lead, ppb	4.86	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD85	3/4/2017	7:21:00	SRSD-FL2-STAFFRRNEARBOOKRM-SINK-SRSD85	Lead, ppb	<1	Less than detection level
SRSD86	3/4/2017	7:20:00	SRSD-FL2-HALLWAYNEARBOOKRM-DF-SRSD86	Lead, ppb	<1	Less than detection level
SRSD87	3/4/2017	7:26:00	SRSD-FL2-LOFTRRNEAR206-LSINK-SRSD87	Lead, ppb	<1	Less than detection level
SRSD88	3/4/2017	7:27:00	SRSD-FL2-LOFTRRNEAR206-RSINK-SRSD88	Lead, ppb	<1	Less than detection level
SRSD89	3/4/2017	7:32:00	SRSD-FL3-CAREER1KIT-SINK-SRSD89	Lead, ppb	1.79	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD90	3/4/2017	7:32:00	SRSD-FL3-CAREER1RR-FLSINK-SRSD90	Lead, ppb	<1	Less than detection level
SRSD91	3/4/2017	7:32:00	SRSD-FL3-CAREER1RR-LSINK-SRSD91	Lead, ppb	<1	Less than detection level
SRSD92	3/4/2017	7:34:00	SRSD-FL3-CAREER1RR-RSINK-SRSD92	Lead, ppb	2.35	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD93	3/4/2017	7:34:00	SRSD-FL3-CAREER1RR-FRSINK-SRSD93	Lead, ppb	1.43	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD94	3/4/2017	7:33:00	SRSD-FL3-BOYSDORMRR-FLSINK-SRSD94	Lead, ppb	<1	Less than detection level
SRSD95	3/4/2017	7:34:00	SRSD-FL3-BOYSDORMRR-LSINK-SRSD95	Lead, ppb	2.37	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD96	3/4/2017	7:34:00	SRSD-FL3-BOYSDORMRR-RSINK-SRSD96	Lead, ppb	<1	Less than detection level

St. Rita School for the Deaf - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SRSD97	3/4/2017	7:34:00	SRSD-FL3-BOYSDORMRR-FRSINK-SRSD97	Lead, ppb	<1	Less than detection level
SRSD103	3/4/2017	7:38:00	SRSD-FL3-RABOYSDORMRR-SINK-SRSD103	Lead, ppb	4.54	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD106	3/4/2017	7:42:00	SRSD-FL3-CAREER2RR-SINK-SRSD106	Lead, ppb	<1	Less than detection level
SRSD109	3/4/2017	7:42:00	SRSD-FL3-CAREER2KIT-SINK-SRSD109	Lead, ppb	1.61	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD110	3/4/2017	7:44:00	SRSD-FL3-HALLWAYNEARINFIRMARYHALL-DF-SRSD110	Lead, ppb	2.92	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD111	3/4/2017	7:44:00	SRSD-FL3-INFIRMARYHALLRR-SINK-SRSD111	Lead, ppb	<1	Less than detection level
SRSD112	3/4/2017	7:44:00	SRSD-FL3-AUDIOLOGYRR-SINK-SRSD112	Lead, ppb	2.76	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD113	3/4/2017	7:44:00	SRSD-FL3-SPEECHRR-SINK-SRSD113	Lead, ppb	3.45	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD114	3/4/2017	7:46:00	SRSD-FL3-INFIRMARY-SINK-SRSD114	Lead, ppb	2.12	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

St. Rita School for the Deaf - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SRSD115	3/4/2017	7:47:00	SRSD-FL3-NURSERR-SINK-SRSD115	Lead, ppb	9.93	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD118	3/4/2017	7:49:00	SRSD-FL3-BOYSLOCK-FLSINK-SRSD118	Lead, ppb	2.5	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD119	3/4/2017	7:50:00	SRSD-FL3-BOYSLOCK-LSINK-SRSD119	Lead, ppb	2.23	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD120	3/4/2017	7:50:00	SRSD-FL3-BOYSLOCK-RSINK-SRSD120	Lead, ppb	1.47	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD121	3/4/2017	7:51:00	SRSD-FL3-BOYSLOCK-FRSINK-SRSD121	Lead, ppb	<1	Less than detection level
SRSD122	3/4/2017	7:52:00	SRSD-FL3-GIRLSLOCK-FLSINK-SRSD122	Lead, ppb	4.13	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD123	3/4/2017	7:52:00	SRSD-FL3-GIRLSLOCK-LSINK-SRSD123	Lead, ppb	1.52	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

St. Rita School for the Deaf - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SRSD124	3/4/2017	7:53:00	SRSD-FL3-GIRLSLOCK-RSINK-SRSD124	Lead, ppb	2.8	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD125	3/4/2017	7:53:00	SRSD-FL3-GIRLSLOCK-FRSINK-SRSD125	Lead, ppb	5.63	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD128	3/4/2017	7:54:00	SRSD-FL3-310RR-SINK-SRSD128	Lead, ppb	<1	Less than detection level
SRSD129	3/4/2017	7:55:00	SRSD-FL3-301ART-SINK-SRSD129	Lead, ppb	<1	Less than detection level
SRSD130	3/4/2017	7:54:00	SRSD-FL3-HALLWAYNEAR301-DF-SRSD130	Lead, ppb	<1	Less than detection level
SRSD131	3/4/2017	7:59:00	SRSD-FL4-423RR-SINK-SRSD131	Lead, ppb	<1	Less than detection level
SRSD132	3/4/2017	8:00:00	SRSD-FL4-422RR-SINK-SRSD132	Lead, ppb	<1	Less than detection level
SRSD135	3/4/2017	8:01:00	SRSD-FL4-GIRLSRR-FLSINK-SRSD135	Lead, ppb	<1	Less than detection level
SRSD136	3/4/2017	8:02:00	SRSD-FL4-GIRLSRR-LSINK-SRSD136	Lead, ppb	1.18	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD137	3/4/2017	8:03:00	SRSD-FL4-GIRLSRR-RSINK-SRSD137	Lead, ppb	<1	Less than detection level
SRSD138	3/4/2017	8:02:00	SRSD-FL4-GIRLSRR-FRSINK-SRSD138	Lead, ppb	<1	Less than detection level
SRSD139	3/4/2017	8:06:00	SRSD-FL4-BOYSRR-FLSINK-SRSD139	Lead, ppb	<1	Less than detection level
SRSD140	3/4/2017	8:06:00	SRSD-FL4-BOYSRR-LSINK-SRSD140	Lead, ppb	<1	Less than detection level
SRSD141	3/4/2017	8:06:00	SRSD-FL4-BOYSRR-RSINK-SRSD141	Lead, ppb	<1	Less than detection level
SRSD142	3/4/2017	8:06:00	SRSD-FL4-BOYSRR-FRSINK-SRSD142	Lead, ppb	2.09	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD143	3/4/2017	8:08:00	SRSD-FL4-410RR-SINK-SRSD143	Lead, ppb	<1	Less than detection level
SRSD146	3/4/2017	8:08:00	SRSD-FL4-402EASTEND-DF-SRSD146	Lead, ppb	<1	Less than detection level

St. Rita School for the Deaf - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SRSD147	3/4/2017	8:18:00	SRSDBH-UL-SHOPHALLWAY-DF-SRSD147	Lead, ppb	2.07	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD148	3/4/2017	8:18:00	SRSDBH-UL-SHOPRR-LSINK-SRSD148	Lead, ppb	5.22	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD149	3/4/2017	8:19:00	SRSDBH-UL-SHOPRR-RSINK-SRSD149	Lead, ppb	4.49	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD150	3/4/2017	8:19:00	SRSDBH-UL-SHOP-SINK-SRSD150	Lead, ppb	1.72	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD151	3/4/2017	8:20:00	SRSDBH-UL-LOFTSTAFFRR-SINK-SRSD151 (Daycare)	Lead, ppb	1.38	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD152	3/4/2017	8:22:00	SRSDBH-UL-LOFTKIT-SINK-SRSD152 (Daycare)	Lead, ppb	<1	Less than detection level
SRSD153	3/4/2017	8:21:00	SRSDBH-UL-LOFTINFENTSRM-SINK-SRSD153 (Daycare)	Lead, ppb	1.5	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD154	3/4/2017	8:21:00	SRSDBH-UL-LOFTRR-SINK-SRSD154 (Daycare)	Lead, ppb	<1	Less than detection level

St. Rita School for the Deaf - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SRSD155	3/4/2017	8:23:00	SRSDBH-ML-RR-SINK-SRSD155	Lead, ppb	7.69	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD156	3/4/2017	8:25:00	SRSDBH-OUTSIDE-GREENHOUSE-LHB-SRSD156	Lead, ppb	<1	Less than detection level
SRSD157	3/4/2017	8:25:00	SRSDBH-OUTSIDE-GREENHOUSE-MHB-SRSD157	Lead, ppb	6.73	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD158	3/4/2017	8:25:00	SRSDBH-OUTSIDE-GREENHOUSE-RHB-SRSD158	Lead, ppb	<1	Less than detection level
SRSD159	3/4/2017	8:37:00	SRSD-EASTHOUSEKITCHEN-SINK-SRSD159	Lead, ppb	<1	Less than detection level
SRSD160	3/4/2017	8:45:00	SRSD-MIDDLEHOUSEKITCHEN-SINK-SRSD160	Lead, ppb	<1	Less than detection level
SRSD161	3/4/2017	8:47:00	SRSD-WESTHOUSEKITCHEN-SINK-SRSD161	Lead, ppb	<1	Less than detection level
SRSD162	N/A	N/A	SRSD-LITTLEHOUSE-OUTSIDE-LDF-SRSD162	N/A	N/A	Turned off for the season. Will be sampled in the spring/fall when they are turned on and in normal use.
SRSD163	N/A	N/A	SRSD-LITTLEHOUSE-OUTSIDE-RDF-SRSD163	N/A	N/A	Turned off for the season. Will be sampled in the spring/fall when they are turned on and in normal use.
SRSD164	N/A	N/A	SRSD-LITTLEHOUSE-MENSRR-LSINK-SRSD164	N/A	N/A	Turned off for the season. Will be sampled in the spring/fall when they are turned on and in normal use.
SRSD165	N/A	N/A	SRSD-LITTLEHOUSE-MENSRR-MSINK-SRSD165	N/A	N/A	Turned off for the season. Will be sampled in the spring/fall when they are turned on and in normal use.

St. Rita School for the Deaf - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SRSD166	N/A	N/A	SRSD-LITTLEHOUSE-MENSRR-RSINK-SRSD166	N/A	N/A	Turned off for the season. Will be sampled in the spring/fall when they are turned on and in normal use.
SRSD167	N/A	N/A	SRSD-LITTLEHOUSE-WOMENSRR-LSINK-SRSD167	N/A	N/A	Turned off for the season. Will be sampled in the spring/fall when they are turned on and in normal use.
SRSD168	N/A	N/A	SRSD-LITTLEHOUSE-WOMENSRR-MSINK-SRSD168	N/A	N/A	Turned off for the season. Will be sampled in the spring/fall when they are turned on and in normal use.
SRSD169	N/A	N/A	SRSD-LITTLEHOUSE-WOMENSRR-RSINK-SRSD169	N/A	N/A	Turned off for the season. Will be sampled in the spring/fall when they are turned on and in normal use.
SRSD5	3/4/2017	6:39:00	SRSD-GFL-GIRLSLOCKLWALL-LSHOWER-SRSD5	Lead, ppb	132	Above 15ppb federal action level and the 20ppb trigger level to take action as explained in the USEPA 3Ts Guidelines for schools. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).

St. Rita School for the Deaf - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SRSD6	3/4/2017	6:39:00	SRSD-GFL-GIRLSLOCKLWALL-MSHOWER-SRSD6	Lead, ppb	35.9	Above 15ppb federal action level and the 20ppb trigger level to take action as explained in the USEPA 3Ts Guidelines for schools. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
SRSD7	3/4/2017	6:39:00	SRSD-GFL-GIRLSLOCKLWALL-RSHOWER-SRSD7	Lead, ppb	20	Above 15ppb federal action level and the 20ppb trigger level to take action as explained in the USEPA 3Ts Guidelines for schools. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
SRSD8	3/4/2017	6:38:00	SRSD-GFL-GIRLSLOCKRWALL-LSHOWER-SRSD8	Lead, ppb	304	Above 15ppb federal action level and the 20ppb trigger level to take action as explained in the USEPA 3Ts Guidelines for schools. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).

St. Rita School for the Deaf - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SRSD9	3/4/2017	6:38:00	SRSD-GFL-GIRLSLOCKRWALL-MSHOWER-SRSD9	Lead, ppb	52.1	Above 15ppb federal action level and the 20ppb trigger level to take action as explained in the USEPA 3Ts Guidelines for schools. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
SRSD10	3/4/2017	6:38:00	SRSD-GFL-GIRLSLOCKRWALL-RSHOWER-SRSD10	Lead, ppb	250	Above 15ppb federal action level and the 20ppb trigger level to take action as explained in the USEPA 3Ts Guidelines for schools. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
SRSD16	3/4/2017	6:32:00	SRSD-GFL-BOYSLOCKBWALL-LSHOWER-SRSD16	Lead, ppb	52.8	Above 15ppb federal action level and the 20ppb trigger level to take action as explained in the USEPA 3Ts Guidelines for schools. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).

St. Rita School for the Deaf - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SRSD17	3/4/2017	6:32:00	SRSD-GFL-BOYSLOCKBWALL-MSHOWER-SRSD17	Lead, ppb	155	Above 15ppb federal action level and the 20ppb trigger level to take action as explained in the USEPA 3Ts Guidelines for schools. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
SRSD18	3/4/2017	6:31:00	SRSD-GFL-BOYSLOCKBWALL-RSHOWER-SRSD18	Lead, ppb	43.7	Above 15ppb federal action level and the 20ppb trigger level to take action as explained in the USEPA 3Ts Guidelines for schools. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
SRSD19	3/4/2017	6:29:00	SRSD-GFL-BOYSLOCKRWALL-FLSHOWER-SRSD19	Lead, ppb	23.1	Above 15ppb federal action level and the 20ppb trigger level to take action as explained in the USEPA 3Ts Guidelines for schools. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).

St. Rita School for the Deaf - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SRSD20	3/4/2017	6:30:00	SRSD-GFL-BOYSLOCKRWALL-LSHOWER-SRSD20	Lead, ppb	51.1	Above 15ppb federal action level and the 20ppb trigger level to take action as explained in the USEPA 3Ts Guidelines for schools. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
SRSD21	3/4/2017	6:31:00	SRSD-GFL-BOYSLOCKRWALL-RSHOWER-SRSD21	Lead, ppb	102	Above 15ppb federal action level and the 20ppb trigger level to take action as explained in the USEPA 3Ts Guidelines for schools. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
SRSD22	3/4/2017	6:30:00	SRSD-GFL-BOYSLOCKRWALL-FRSHOWER-SRSD22	Lead, ppb	25.1	Above 15ppb federal action level and the 20ppb trigger level to take action as explained in the USEPA 3Ts Guidelines for schools. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
SRSD62	3/4/2017	7:06:00	SRSD-FL2-GIRLSDORMRRNEAR235-FLSHOWER-SRSD62	Lead, ppb	<1	Less than detection level
SRSD63	3/4/2017	7:09:00	SRSD-FL2-GIRLSDORMRRNEAR235-LSHOWER-SRSD63	Lead, ppb	<1	Less than detection level

St. Rita School for the Deaf - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SRSD64	3/4/2017	7:09:00	SRSD-FL2-GIRLSDORMRRNEAR235-MSHOWER-SRSD64	Lead, ppb	1.71	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD65	3/4/2017	7:09:00	SRSD-FL2-GIRLSDORMRRNEAR235-RSHOWER-SRSD65	Lead, ppb	5.6	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD66	3/4/2017	7:10:00	SRSD-FL2-GIRLSDORMRRNEAR235-FRSHOWER-SRSD66	Lead, ppb	26.9	Above 15ppb federal action level and the 20ppb trigger level to take action as explained in the USEPA 3Ts Guidelines for schools. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
SRSD76	3/4/2017	7:18:00	SRSD-FL2-RAGIRLSDORMRR-TUB-SRSD76	Lead, ppb	<1	Less than detection level
SRSD77	3/4/2017	7:16:00	SRSD-FL2-RAGIRLSDORMRR-SHOWER-SRSD77	Lead, ppb	1.95	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD98	3/4/2017	7:35:00	SRSD-FL3-BOYSDORMRR-FLSHOWER-SRSD98	Lead, ppb	5.52	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

St. Rita School for the Deaf - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SRSD99	3/4/2017	7:35:00	SRSD-FL3-BOYSDORMRR-LSHOWER-SRSD99	Lead, ppb	121	Above 15ppb federal action level and the 20ppb trigger level to take action as explained in the USEPA 3Ts Guidelines for schools. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
SRSD100	3/4/2017	7:35:00	SRSD-FL3-BOYSDORMRR-MSHOWER-SRSD100	Lead, ppb	32.8	Above 15ppb federal action level and the 20ppb trigger level to take action as explained in the USEPA 3Ts Guidelines for schools. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
SRSD101	3/4/2017	7:37:00	SRSD-FL3-BOYSDORMRR-RSHOWER-SRSD101	Lead, ppb	7.44	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD102	3/4/2017	7:37:00	SRSD-FL3-BOYSDORMRR-FRSHOWER-SRSD102	Lead, ppb	253	Above 15ppb federal action level and the 20ppb trigger level to take action as explained in the USEPA 3Ts Guidelines for schools. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).

St. Rita School for the Deaf - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SRSD104	3/4/2017	7:38:00	SRSD-FL3-RABOYSDORMRR-TUB-SRSD104	Lead, ppb	5.81	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD105	3/4/2017	7:39:00	SRSD-FL3-RABOYSDORMRR-SHOWER-SRSD105	Lead, ppb	<1	Less than detection level
SRSD107	3/4/2017	7:42:00	SRSD-FL3-CAREER2RR-TUB-SRSD107	Lead, ppb	154	Above 15ppb federal action level and the 20ppb trigger level to take action as explained in the USEPA 3Ts Guidelines for schools. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
SRSD108	3/4/2017	7:42:00	SRSD-FL3-CAREER2RR-SHOWER-SRSD108	Lead, ppb	2.57	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD116	3/4/2017	7:47:00	SRSD-FL3-NURSERR-TUB-SRSD116	Lead, ppb	166	Above 15ppb federal action level and the 20ppb trigger level to take action as explained in the USEPA 3Ts Guidelines for schools. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).

St. Rita School for the Deaf - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SRSD117	3/4/2017	7:47:00	SRSD-FL3-NURSERR-SHOWER-SRSD117	Lead, ppb	16.1	Above 15ppb federal action level. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
SRSD126	3/4/2017	7:54:00	SRSD-FL3-310RR-TUB-SRSD126	Lead, ppb	7.84	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD127	3/4/2017	7:54:00	SRSD-FL3-310RR-SHOWER-SRSD127	Lead, ppb	1.55	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD133	3/4/2017	8:01:00	SRSD-FL4-422RR-TUB-SRSD133	Lead, ppb	8.03	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD134	3/4/2017	8:05:00	SRSD-FL4-422RR-SHOWER-SRSD134	Lead, ppb	3.21	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SRSD144	3/4/2017	8:09:00	SRSD-FL4-410RR-TUB-SRSD144	Lead, ppb	1.93	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

St. Rita School for the Deaf - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SRSD145	3/4/2017	8:09:00	SRSD-FL4-410RR-SHOWER-SRSD145	Lead, ppb	1.45	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.