



July 7, 2017

St. Ursula Villa School
Kent Halaby
3660 Vineyard Place
Cincinnati, OH 45226

Dear Mr. Halaby,

Thank you for taking the responsibility seriously to protect the health of the children by voluntarily testing the water in your school for lead!

Attached please find the results of the lead analyses performed for St. Ursula Villa School by Greater Cincinnati Water Works (GCWW). The following comments speak to the process, samples analyzed and additional steps needed to help ensure the safety of all the students within the school.

Sampling Process and Results

The *USEPA 3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance Document (3Ts Guidelines)* is the process and guidelines used for assisting schools with testing for lead.

In May and June, one hundred and one (101) samples were collected from drinking fountains, cooking outlets and sinks throughout the school. The results show the following:

- 66 samples (65.35%), below the detection level (<1)
- 29 samples (28.71%), between 1ppb and 5ppb
- 3 samples (2.97%), between 5ppb and 10ppb
- 1 samples (.99%), between 10ppb and 15ppb
- 2 samples (1.98%) greater than 15ppb.

Ninety-eight percent (98.02%) of the sample results were below the detection level or below the federal action level.

Fifteen parts per billion (ppb) is the federal Lead and Copper Rule action level; desired results are below 15. The federal action level of 15ppb pertains to water utilities and the Greater Cincinnati Water Works review and comments are based on this action level. However, the USEPA 3Ts Guidelines document outlines practices for schools to put in place if samples are greater than 20 ppb.

While we strive to have results less than 15, we recognize that lead is a pervasive environmental contaminant, and no safe blood lead threshold has been identified in children or adults. Therefore, we provide recommendations to further reduce any lead levels discovered.

Next steps

GCWW has reviewed the results from your samples and provides some next-steps comments.

1. Most the drinking fountains and bottle fillers had results less than the detection level (<1). No further action is needed for these locations. A few had low lead values. To further reduce the risk



of lead at these locations, consider flushing the line (letting the water run) before use. Other than flushing, no further action is suggested.

2. A utility sink, SUV-MH3L-UTILITYCLOSETNEAR206-UTILITYSINK-SUV88, had a very high lead level. Based on the name, this is not a drinking water or cooking outlet. If this sink is not used on a regular basis, then the infrequent use may be contributing to the lead level. Post a sign above the location limiting the purpose of the sink ('hand washing only', 'work sink only'). Posting a sign will deter students and staff from potentially using the sinks to fill a water bottle, etc.
3. A restroom sink, had a high lead level as well. Two samples were collected in this restroom:
 - a. SUV-MAIN1L-BOYSRRNEAR119-FLSINK-SUV2 (47.2ppb)
 - b. SUV-MAIN1L-BOYSRRNEAR119-LSINK-SUV3 (1.59ppb)

If the SUV2 sink is not used on a regular basis, the infrequent use may be contributing to the lead level. This could certainly be the case if many students tend to use the left sink and not the far-left sink.

The aerator may be dirty in SUV2 sink. We have known and learned from other schools (that are participating in this program) that cleaning the faucet and aerator may reduce the lead levels. This is due to the cleaning that removes trapped particles on the aerator. Cleaning may help reduce the lead levels. Follow-up sampling can occur at these locations; GCWW can assist with this.

4. Although below the federal action level of 15ppb, a laundry utility sink had a higher lead level than other locations (13ppb). Again, infrequent use at this sink may be contributing to the lead level.
5. As mentioned before, cleaning the aerator may help reduce lead levels. This pertains to all locations with lead detections. If there is a chance that someone may attempt to fill a water bottle at any of these sinks with lead detections, then consider posting a sign above the locations limiting the purpose of these sinks ('hand washing only', 'work sink only').
6. *You might want to consider this for the results greater than 15ppb).* Consider completing a plumbing profile to review the fixtures in the school as some fixtures may be contributing to the lead detections in samples. If the fixtures are the source of the lead, plan to replace them. The USEPA 3Ts Guidelines outlines a great approach to creating and implementing a remediation plan. A copy of the Guidelines can be found on our website <http://www.cincinnati-oh.gov/water/assets/File/3T%20Guidance%20Manual%20for%20Schools.pdf>.

State funds are available through the new Lead Plumbing Fixture Replacement Assistance Grant Program established to provide reimbursement to eligible schools for the assessment and replacement of certain plumbing fixtures. The Program was established in House Bill 390 to provide \$12,000,000 in funding to eligible schools to reimburse for the sampling and replacement of drinking fountains, water coolers, plumbing fixtures, and limited connected piping. Schools built before 1990 can apply for reimbursement up to \$15,000 for sampling of eligible fixtures and the material costs to replace those fixtures if they are identified as being over the federal action level for lead. The program is open to traditional public schools, community schools, and chartered non-public schools. Program information can be found on the Ohio Facilities Construction Commission (OFCC) Services and Programs website <http://ofcc.ohio.gov/ServicesPrograms/LeadFixtureReplacementGrants.aspx>.

7. If it hasn't occurred already, a robust communications plan is suggested. Communications plan steps are outlined in the 3Ts Guidelines. This plan will inform the school community of the sampling work the school has done to date and the steps the school will take to correct any issues

discovered. GCWW employees can assist with this plan and are available to attend any school meetings to help explain our lead program, the sample results and our partnership with your school. Suggestions for language and a letter template can be provided if needed. Sampling results will be posted on the GCWW lead.mycgww.org website with other school sampling results.

Greater Cincinnati Water Works takes the presence of lead service lines and the removal of service lines in our system very seriously. In addition, minimizing the exposure of lead within our preschools, schools, and daycares is one of our highest priorities under our Enhanced Lead Program. We look forward to our continued partnership with your school. Our resources are available to assist in many ways. Please contact Jim Nelson at 591-6869 for further assistance.

Thanks again for your partnership with Greater Cincinnati Water Works and your work to further understand the water quality within your building. Your extra steps and care to keep the children in our community safe are appreciated!

Sincerely,

A handwritten signature in black ink that reads "Cathy B. Bailey". The signature is written in a cursive, flowing style.

Cathy B. Bailey
Director/Greater Cincinnati Water Works

Cc: Dr. Marilyn Crumpton, Cincinnati Health Department
Dr. Camille Jones, Cincinnati Health Department
Chuck DeJonckheere, Hamilton County Public Health
Sheila Hill-Christian, City of Cincinnati
Verna Arnette, Greater Cincinnati Water Works
Jeff Swertfeger, Greater Cincinnati Water Works
Jason DeLaet, Greater Cincinnati Water Works

Cincinnati Archdiocese - St. Ursula Villa School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SUV1	6/2/2017	6:42:00	SUV-MAIN1L-HALLWAYNEAR119-DF-SUV1	Lead, ppb	<1	Less than detection level
SUV2	5/31/2017	6:18:00	SUV-MAIN1L-BOYSRRNEAR119-FLSINK-SUV2	Lead, ppb	47.2	Above 15ppb federal action level and the 20ppb trigger level to take action as explained in the USEPA 3Ts Guidelines for schools. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
SUV3	5/31/2017	6:18:00	SUV-MAIN1L-BOYSRRNEAR119-LSINK-SUV3	Lead, ppb	1.59	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SUV4	5/31/2017	6:18:00	SUV-MAIN1L-BOYSRRNEAR119-RSINK-SUV4	Lead, ppb	<1	Less than detection level
SUV5	5/31/2017	6:18:00	SUV-MAIN1L-BOYSRRNEAR119-FRSINK-SUV5	Lead, ppb	1.59	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SUV6	5/31/2017	6:18:00	SUV-MAIN1L-GIRLSRRNEAR119-FLSINK-SUV6	Lead, ppb	7.44	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SUV7	5/31/2017	6:22:00	SUV-MAIN1L-GIRLSRRNEAR119-LSINK-SUV7	Lead, ppb	<1	Less than detection level
SUV8	5/31/2017	6:22:00	SUV-MAIN1L-GIRLSRRNEAR119-RSINK-SUV8	Lead, ppb	1.91	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SUV9	5/31/2017	6:22:00	SUV-MAIN1L-GIRLSRRNEAR119-FRSINK-SUV9	Lead, ppb	<1	Less than detection level
SUV10	6/2/2017	6:22:00	SUV-MAIN1L-207COMPUTERLAB-SINK-SUV10	Lead, ppb	<1	Less than detection level

Cincinnati Archdiocese - St. Ursula Villa School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SUV11	6/2/2017	6:48:00	SUV-MAIN1L-HALLWAYNEARRESOURCE-DF-SUV11	Lead, ppb	1.82	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SUV12	6/2/2017	6:48:00	SUV-MAIN1L-RESOURCELRR-SINK-SUV12	Lead, ppb	<1	Less than detection level
SUV13	6/2/2017	6:44:00	SUV-MAIN1L-RESOURCERRR-SINK-SUV13	Lead, ppb	<1	Less than detection level
SUV14	6/2/2017	6:44:00	SUV-MAIN1L-309WORKRM-BF-SUV14	Lead, ppb	1.93	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SUV15	6/2/2017	6:59:00	SUV-MAIN1L-HALLWAYNEAR214-DF-SUV15	Lead, ppb	<1	Less than detection level
SUV16	5/31/2017	6:58:00	SUV-MAIN1L-BOYSRRNEAR214-FLSINK-SUV16	Lead, ppb	<1	Less than detection level
SUV17	5/31/2017	6:46:00	SUV-MAIN1L-BOYSRRNEAR214-LSINK-SUV17	Lead, ppb	4.43	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SUV18	5/31/2017	6:46:00	SUV-MAIN1L-BOYSRRNEAR214-RSINK-SUV18	Lead, ppb	<1	Less than detection level
SUV19	5/31/2017	6:46:00	SUV-MAIN1L-BOYSRRNEAR214-FRSINK-SUV19	Lead, ppb	<1	Less than detection level
SUV20	5/31/2017	6:46:00	SUV-MAIN1L-GIRLSRRNEAR214-FLSINK-SUV20	Lead, ppb	<1	Less than detection level
SUV21	5/31/2017	6:44:00	SUV-MAIN1L-GIRLSRRNEAR214-LSINK-SUV21	Lead, ppb	<1	Less than detection level
SUV22	5/31/2017	6:44:00	SUV-MAIN1L-GIRLSRRNEAR214-RSINK-SUV22	Lead, ppb	<1	Less than detection level
SUV23	5/31/2017	6:44:00	SUV-MAIN1L-GIRLSRRNEAR214-FRSINK-SUV23	Lead, ppb	<1	Less than detection level
SUV24	5/31/2017	6:53:00	SUV-MAIN2L-HALLWAYNEAR218-DF-SUV24	Lead, ppb	<1	Less than detection level
SUV25	5/31/2017	6:37:00	SUV-MAIN2L-BOYSRRNEAR218-FLSINK-SUV25	Lead, ppb	2.27	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SUV26	5/31/2017	6:37:00	SUV-MAIN2L-BOYSRRNEAR218-LSINK-SUV26	Lead, ppb	1.45	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

Cincinnati Archdiocese - St. Ursula Villa School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SUV27	5/31/2017	6:37:00	SUV-MAIN2L-BOYSRRNEAR218-RSINK-SUV27	Lead, ppb	1.05	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SUV28	5/31/2017	6:37:00	SUV-MAIN2L-BOYSRRNEAR218-FRSINK-SUV28	Lead, ppb	<1	Less than detection level
SUV29	5/31/2017	6:35:00	SUV-MAIN2L-GIRLSRRNEAR218-FLSINK-SUV29	Lead, ppb	2.37	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SUV30	5/31/2017	6:35:00	SUV-MAIN2L-GIRLSRRNEAR218-LSINK-SUV30	Lead, ppb	<1	Less than detection level
SUV31	5/31/2017	6:35:00	SUV-MAIN2L-GIRLSRRNEAR218-RSINK-SUV31	Lead, ppb	<1	Less than detection level
SUV32	5/31/2017	6:35:00	SUV-MAIN2L-GIRLSRRNEAR218-FRSINK-SUV32	Lead, ppb	<1	Less than detection level
SUV33	5/31/2017	7:58:00	SUV-MAIN2L-ART-LSINK-SUV33	Lead, ppb	1.65	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SUV34	5/31/2017	7:58:00	SUV-MAIN2L-ART-MSINK-SUV34	Lead, ppb	2.34	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SUV35	5/31/2017	7:58:00	SUV-MAIN2L-ART-RSINK-SUV35	Lead, ppb	<1	Less than detection level
SUV36	6/2/2017	6:55:00	SUV-MAIN2L-STAIRWELLRRNEARART-SINK-SUV36	Lead, ppb	1.41	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SUV37	6/2/2017	6:56:00	SUV-MAIN2L-202NURSE-BF-SUV37	Lead, ppb	<1	Less than detection level
SUV38	6/2/2017	6:55:00	SUV-MAIN2L-HALLWAYNEARLIBRARY-DF-SUV38	Lead, ppb	<1	Less than detection level

Cincinnati Archdiocese - St. Ursula Villa School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SUV39	6/2/2017	6:57:00	SUV-MAIN2L-MAINOFF305RR-SINK-SUV39	Lead, ppb	1.56	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SUV40	6/2/2017	7:04:00	SUV-MAIN2L-MAINOFFCOUNSELOROFFRR-SINK-SUV40	Lead, ppb	1.85	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SUV41	5/31/2017	7:30:00	SUV-MAIN2L-MPR-DF-SUV41	Lead, ppb	<1	Less than detection level
SUV42	5/31/2017	7:30:00	SUV-MAIN2L-MPR-BF-SUV42	Lead, ppb	<1	Less than detection level
SUV43	5/31/2017	7:30:00	SUV-MAIN2L-KITCHEN-SINK-SUV43	Lead, ppb	<1	Less than detection level
SUV44	5/31/2017	7:30:00	SUV-MAIN2L-KITFRIDGE-IM-SUV44	Lead, ppb	<1	Less than detection level
SUV45	5/31/2017	7:30:00	SUV-MAIN2L-KITSTAFFRR-SINK-SUV45	Lead, ppb	<1	Less than detection level
SUV46	5/31/2017	8:13:00	SUV-OUTSIDE-VILLAWAY-LDF-SUV46	Lead, ppb	<1	Less than detection level
SUV47	5/31/2017	8:12:00	SUV-OUTSIDE-VILLAWAY-RDF-SUV47	Lead, ppb	1.23	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SUV48	5/31/2017	7:44:00	SUV-MAIN3L-LOUNGE-BF-SUV48	Lead, ppb	<1	Less than detection level
SUV49	5/31/2017	7:44:00	SUV-MAIN3L-LOUNGEKITCHEN-SINK-SUV49	Lead, ppb	1.16	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SUV50	5/31/2017	7:44:00	SUV-MAIN3L-RRNEARLOUNGE-SINK-SUV50	Lead, ppb	2.08	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

Cincinnati Archdiocese - St. Ursula Villa School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SUV51	5/31/2017	7:44:00	SUV-MAIN3L-RRNEARWORKRM-SINK-SUV51	Lead, ppb	6.45	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SUV52	6/2/2017	6:38:00	SUV-MAINGYM-001GYM-DF-SUV52	Lead, ppb	<1	Less than detection level
SUV53	5/31/2017	6:51:00	SUV-MAINGYM-BOYSRR-LSINK-SUV53	Lead, ppb	<1	Less than detection level
SUV54	5/31/2017	6:51:00	SUV-MAINGYM-BOYSRR-RSINK-SUV54	Lead, ppb	<1	Less than detection level
SUV55	5/31/2017	6:53:00	SUV-MAINGYM-GIRLSRR-LSINK-SUV55	Lead, ppb	<1	Less than detection level
SUV56	6/1/2017	6:53:00	SUV-MAINGYM-GIRLSRR-RSINK-SUV56	Lead, ppb	<1	Less than detection level
SUV57	6/1/2017	6:27:00	SUV-MH1L-LAUNDRY-UTILITYSINK-SUV57	Lead, ppb	13	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SUV58	6/1/2017	6:27:00	SUV-MH1L-ART-SINK-SUV58	Lead, ppb	<1	Less than detection level
SUV59	6/1/2017	6:27:00	SUV-MH1L-HALLWAY-DF-SUV59	Lead, ppb	1.11	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SUV60	6/1/2017	6:27:00	SUV-MH1L-UNIRRNEARMUSIC-SINK-SUV60	Lead, ppb	2.2	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SUV61	6/1/2017	6:27:00	SUV-MH1L-MUSCLERM-SINK-SUV61	Lead, ppb	1.93	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SUV62	6/1/2017	6:38:00	SUV-MH2L-STAIRWELLRRNEART3B-SINK-SUV62	Lead, ppb	<1	Less than detection level

Cincinnati Archdiocese - St. Ursula Villa School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SUV63	6/1/2017	6:39:00	SUV-MH2L-T3B-SINK-SUV63	Lead, ppb	1.09	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SUV64	6/1/2017	6:41:00	SUV-MH2L-BOYSRRNEART3B-SINK-SUV64	Lead, ppb	<1	Less than detection level
SUV65	6/1/2017	6:40:00	SUV-MH2L-GIRLSRRNEART3B-SINK-SUV65	Lead, ppb	<1	Less than detection level
SUV66	6/1/2017	6:41:00	SUV-MH2L-HALLWAYNEART3B-DF-SUV66	Lead, ppb	<1	Less than detection level
SUV67	5/31/2017	8:07:00	SUV-MH2L-DINING-SINK-SUV67	Lead, ppb	<1	Less than detection level
SUV68	5/31/2017	8:07:00	SUV-MH2L-OUTSIDEBACKENT-DF-SUV68	Lead, ppb	<1	Less than detection level
SUV69	6/1/2017	6:35:00	SUV-MH2L-STAIRWELLRRNEARLOBBY-SINK-SUV69	Lead, ppb	1.14	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SUV70	5/31/2017	8:05:00	SUV-MH2L-LOBBYRRNEARFRONTENT-SINK-SUV70	Lead, ppb	<1	Less than detection level
SUV71	5/31/2017	8:08:00	SUV-MH2L-2YORR-SINK-SUV71	Lead, ppb	<1	Less than detection level
SUV72	5/31/2017	8:10:00	SUV-MH2L-2YO-SINK-SUV72	Lead, ppb	5.36	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SUV73	6/1/2017	6:45:00	SUV-MH2L-MB-SINK-SUV73	Lead, ppb	<1	Less than detection level
SUV74	6/1/2017	6:45:00	SUV-MH2L-MBRR-SINK-SUV74	Lead, ppb	<1	Less than detection level
SUV75	6/1/2017	7:00:00	SUV-MH2L-MC-SINK-SUV75	Lead, ppb	<1	Less than detection level
SUV76	6/1/2017	7:00:00	SUV-MH2L-MCRR-SINK-SUV76	Lead, ppb	<1	Less than detection level
SUV77	6/1/2017	6:48:00	SUV-MH2L-T4A-SINK-SUV77	Lead, ppb	<1	Less than detection level
SUV78	6/1/2017	6:48:00	SUV-MH2L-T4ARR-SINK-SUV78	Lead, ppb	<1	Less than detection level
SUV79	6/1/2017	6:50:00	SUV-MH2L-T3A-SINK-SUV79	Lead, ppb	<1	Less than detection level
SUV80	6/1/2017	6:51:00	SUV-MH2L-T3ARR-SINK-SUV80	Lead, ppb	<1	Less than detection level
SUV81	6/1/2017	6:54:00	SUV-MH2L-T4B-SINK-SUV81	Lead, ppb	<1	Less than detection level
SUV82	6/1/2017	6:54:00	SUV-MH2L-T4BRR-SINK-SUV82	Lead, ppb	<1	Less than detection level
SUV83	6/1/2017	6:58:00	SUV-MH2L-MA-SINK-SUV83	Lead, ppb	<1	Less than detection level
SUV84	6/1/2017	6:58:00	SUV-MH2L-MARR-SINK-SUV84	Lead, ppb	<1	Less than detection level

Cincinnati Archdiocese - St. Ursula Villa School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SUV85	6/1/2017	7:13:00	SUV-MH3L-KITCHEN-SINK-SUV85	Lead, ppb	1.21	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SUV86	6/1/2017	7:14:00	SUV-MH3L-KITCHENBF-SUV86	Lead, ppb	<1	Less than detection level
SUV87	6/1/2017	7:08:00	SUV-MH3L-RRNEAR208-SINK-SUV87	Lead, ppb	1.91	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SUV88	6/1/2017	7:10:00	SUV-MH3L-UTILITYCLOSETNEAR206-UTILITYSINK-SUV88	Lead, ppb	453	Above 15ppb federal action level and the 20ppb trigger level to take action as explained in the USEPA 3Ts Guidelines for schools. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).
SUV89	5/31/2017	8:06:00	SUV-MH3L-AUCTIONRR-SINK-SUV89	Lead, ppb	2.35	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SUV90	6/2/2017	6:32:00	SUV-JH-SCIENCERM-LSINK-SUV90	Lead, ppb	2.86	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SUV91	6/2/2017	6:32:00	SUV-JH-SCIENCERM-MSINK-SUV91	Lead, ppb	3.09	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

Cincinnati Archdiocese - St. Ursula Villa School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER, CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SUV92	6/2/2017	6:32:00	SUV-JH-SCIENCERM-RSINK-SUV92	Lead, ppb	3.05	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SUV93	6/2/2017	6:30:00	SUV-JH-HALLWAYNEARELA-LDF-SUV93	Lead, ppb	<1	Less than detection level
SUV94	6/2/2017	6:30:00	SUV-JH-HALLWAYNEARELA-RDF-SUV94	Lead, ppb	<1	Less than detection level
SUV95	5/31/2017	6:56:00	SUV-JH-GIRLSRR-LSINK-SUV95	Lead, ppb	<1	Less than detection level
SUV96	5/31/2017	6:56:00	SUV-JH-GIRLSRR-MSINK-SUV96	Lead, ppb	<1	Less than detection level
SUV97	5/31/2017	6:56:00	SUV-JH-GIRLSRR-RSINK-SUV97	Lead, ppb	<1	Less than detection level
SUV98	5/31/2017	6:58:00	SUV-JH-BOYSRR-LSINK-SUV98	Lead, ppb	<1	Less than detection level
SUV99	5/31/2017	6:58:00	SUV-JH-BOYSRR-RSINK-SUV99	Lead, ppb	<1	Less than detection level
SUV100	6/12/2017	6:34:00	SUV-JH-STAFFWKRM-SINK-SUV100	Lead, ppb	<1	Less than detection level
SUV101	6/2/2017	6:34:00	SUV-JH-STAFFWKRM-BF-SUV101	Lead, ppb	<1	Less than detection level