



September 18, 2018

Cincinnati Public Schools  
Cynthia Eghbaltia  
2651 Burnet Avenue  
Cincinnati, OH 45219

## Westwood Resample

Dear Cynthia:

**Samples from one location was collected in a resample round** of lead analyses for Westwood School. Greater Cincinnati Water Works (GCWW) analyzed the samples and compared the results.

### School Sample Results

The *USEPA 3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance Document (3Ts Guidelines)* is the process and guidelines used for assisting schools with testing for lead. Sample results are below.

Cincinnati Public Schools - Westwood School					
Lead Testing Results-Resamples					
SAMPLE	Initial 1st Draw sample Date 1/20/17 Lead, ppb	Changes made after first round of sampling	1st Draw sample Date 5/11/18 Lead, ppb	30 second flush sample Date 5/11/18 Lead, ppb	60 second flush sample Date 5/11/18 Lead, ppb
WEST-FL3-3913GIRLSRR3018-RSINK-WEST99	18.9	Cleaned aerator; flushed the line	1.36	<1	<1

### Changes made and Next Steps

For the location in the resample round, the aerator was cleaned and the line was flushed with ample water before resampling. This greatly reduced the lead levels at this location; no further action is suggested.

Your work and changes in the school continue to improve the water quality for the students and staff. Your decisions and actions throughout this process speak to your care and commitment to ensure students and staff remain safe and healthy while attending your school.



We look forward to our continued partnership with Cincinnati Public Schools. Our resources are available to assist in many ways. Please contact Jim Nelson at 591-6869 if you have any questions.

Sincerely,

A handwritten signature in black ink that reads "Cathy B. Bailey". The signature is written in a cursive, flowing style.

Cathy B. Bailey

Director/Greater Cincinnati Water Works

Cc: Melba Moore, Cincinnati Health Department  
Dr. Camille Jones, Cincinnati Health Department  
Chuck DeJonckheere, Hamilton County Public Health  
Sheila Hill-Christian, City of Cincinnati  
Verna Arnette, Greater Cincinnati Water Works  
Jeff Swertfeger, Greater Cincinnati Water Works  
Jason DeLaet, Greater Cincinnati Water Works  
James Nelson, Greater Cincinnati Water Works