



January 27, 2017

Cincinnati Public Schools
Cynthia Eghbalnia
2651 Burnet Avenue
Cincinnati, OH 45219

**Sayler Park
School**

Dear Cynthia:

Thank you for taking the responsibility seriously to protect the health of the children by voluntarily testing the water in your school for lead!

Attached please find the results of the lead analyses performed for Sayler Park School by the Greater Cincinnati Water Works (GCWW). The following comments speak to the process, samples analyzed and additional steps needed to help ensure the safety of all the students within the school.

School Sampling Process and Results

GCWW and Cincinnati Public Schools (CPS) staff worked together to finalize a sampling plan for the school. The *USEPA 3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance Document (3Ts Guidelines)* is the process and guidelines used for assisting schools with testing for lead.

Earlier this month, one hundred, twelve (112) samples were collected from drinking fountains, sinks and cooking outlets throughout the school. Multiple sinks within the school were not initially considered for testing, however, key nearby indicators (coffee makers, drinking cups, plates, utensils, etc.) prompted additional locations to be tested in the schools. Including these sampling locations speaks to the proactive approach CPS continues to have towards understanding the water quality within the schools. The results show the following:

- 67 samples (59.82%), below the detection level (<1)
- 41 samples (36.61%), between 1ppb and 5ppb
- 4 samples (3.57%), between 5ppb and 10ppb

One hundred percent (100%) of the sample results were below the detection level or below the federal action level.

Fifteen parts per billion (ppb) is the federal Lead and Copper Rule action level; desired results are below 15. The federal action level of 15ppb pertains to water utilities and GCWW's review and comments are based on this action level. However, the USEPA 3Ts Guidelines document outlines practices for schools to put in place if samples are greater than 20 ppb.

While we strive to have results less than 15, we recognize that lead is a pervasive environmental contaminant, and no safe blood lead threshold has been identified in children or adults. Therefore, we provide recommendations to further reduce any lead levels discovered in your school.

Next steps

GCWW has reviewed the results from your samples and provides some next-steps comments:

1. Although lower than the 15 ppb action level, for samples with lead detections, consider flushing the lines before using the water. Refer to the USEPA 3Ts Guidelines for more information.



2. For sinks with lead detections, as a precautionary measure, consider signage limiting the purpose of the sink ('Hand Washing Only', 'utility sink/work area only', etc.) Refer to the USEPA 3Ts Guidelines for more information and recommendations on how to further reduce the risk of lead.
3. Review how water is being used within your facility. If water is not used on a regular basis at some of these outlets, the infrequent use at the outlet may be contributing to the lead detections. Again, signage at these locations may be helpful (hand washing only, etc.).
4. Although a number of samples had minimum lead detections, consider completing a plumbing profile to review the fixtures in the school as some fixtures may be contributing to the lead detections in samples. If the fixtures are the source of the lead, plan to replace them. The USEPA 3Ts Guidelines outlines a great approach to creating and implementing a remediation plan. A copy of the Guidelines can be found on our website <http://www.cincinnati-oh.gov/water/assets/File/3T%20Guidance%20Manual%20for%20Schools.pdf>.


State funds are available through the new Lead Plumbing Fixture Replacement Assistance Grant Program established to provide reimbursement to eligible schools for the assessment and replacement of certain plumbing fixtures. The program is open to traditional public schools, community schools, and chartered non-public schools. Program information can be found on the Ohio Facilities Construction Commission (OFCC) Services and Programs website <http://ofcc.ohio.gov/ServicesPrograms/LeadFixtureReplacementGrants.aspx>.

5. If it hasn't occurred already, a robust communications plan is suggested. Communications plan steps are outlined in the 3Ts Guidelines. This plan will inform the school community of the sampling work the school has done to date and the steps the school will take to correct any issues discovered. GCWW employees can assist with this plan and are available to attend any school meetings to help explain our lead program, the sample results and our partnership with CPS. Sampling results will be posted on the GCWW lead.mycww.org website.

Greater Cincinnati Water Works takes the presence of lead service lines and the removal of those service lines in our system very seriously. In addition, minimizing the exposure of lead within our preschools, schools, and daycares is one of our highest priorities under our Enhanced Lead Program. Please contact Jim Nelson at 591-6869 if you have any questions.

Thanks again for your partnership with Greater Cincinnati Water Works and your work to further understand the water quality within your building. Your extra steps and care to keep the children in our community safe are appreciated!

Sincerely,



Cathy B. Bailey
Director/Greater Cincinnati Water Works

Cc: Dr. Marilyn Crumpton, Cincinnati Health Department
Dr. Camille Jones, Cincinnati Health Department
Chuck DeJonckheere, Hamilton County Public Health
Sheila Hill-Christian, City of Cincinnati
Verna Arnette, Greater Cincinnati Water Works
Jeff Swertfeger, Greater Cincinnati Water Works
Jason DeLaet, Greater Cincinnati Water Works

Cincinnati Public Schools- Saylor Park School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SAYL1	1/5/2017	5:20:00	SAYL-KIT-STOCKPOT-FILLER-SAYL1	Lead, ppb	1.04	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL2	1/5/2017	5:25:00	SAYL-KIT-WASHRM-LSINK-SAYL2	Lead, ppb	<1	Less than detection level
SAYL3	1/5/2017	5:30:00	SAYL-KIT-WASHRM-RSINK-SAYL3	Lead, ppb	<1	Less than detection level
SAYL4	1/5/2017	5:32:00	SAYL-KIT-WASHRM-HANDSINK-SAYL4	Lead, ppb	1.21	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL5	1/5/2017	5:34:00	SAYL-KIT-NEARSERV-HANDSINK-SAYL5	Lead, ppb	3.73	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL6	1/5/2017	5:36:00	SAYL-KIT-NEAR1205-SINK-SAYL6	Lead, ppb	1.02	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL7	1/5/2017	5:37:00	SAYL-KIT-NEAR1205-HANDSINK-SAYL7	Lead, ppb	2.06	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL8	1/5/2017	5:39:00	SAYL-KIT-2TUBPRODUCE-SINK-SAYL8	Lead, ppb	<1	Less than detection level
SAYL9	1/5/2017	5:41:00	SAYL-KIT-1203RR-SINK-SAYL9	Lead, ppb	2.24	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL10	1/5/2017	5:43:00	SAYL-KIT-NEARSERV-SINK-SAYL10	Lead, ppb	<1	Less than detection level
SAYL11	1/5/2017	5:45:00	SAYL-FL1-1214RR-SINK-SAYL11	Lead, ppb	<1	Less than detection level
SAYL12	1/5/2017	5:47:00	SAYL-FL1-HALLWAYNEAR1214-LCOMBODF-SAYL12	Lead, ppb	<1	Less than detection level
SAYL13	1/5/2017	5:49:00	SAYL-FL1-HALLWAYNEAR1214-LCOMBOBF-SAYL13	Lead, ppb	<1	Less than detection level
SAYL14	1/5/2017	5:50:00	SAYL-FL1-HALLWAYNEAR1214-RDF-SAYL14	Lead, ppb	<1	Less than detection level
SAYL15	1/5/2017	5:52:00	SAYL-FL1-1216BOYSRR-LSINK-SAYL15	Lead, ppb	<1	Less than detection level
SAYL16	1/5/2017	5:53:00	SAYL-FL1-1216BOYSRR-MSINK-SAYL16	Lead, ppb	<1	Less than detection level
SAYL17	1/5/2017	5:54:00	SAYL-FL1-1216BOYSRR-RSINK-SAYL17	Lead, ppb	<1	Less than detection level
SAYL18	1/5/2017	5:56:00	SAYL-FL1-1218GIRLSRR-LSINK-SAYL18	Lead, ppb	<1	Less than detection level

Cincinnati Public Schools- Saylor Park School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SAYL19	1/5/2017	5:57:00	SAYL-FL1-1218GIRLSRR-MSINK-SAYL19	Lead, ppb	<1	Less than detection level
SAYL20	1/5/2017	5:58:00	SAYL-FL1-1218GIRLSRR-RSINK-SAYL20	Lead, ppb	<1	Less than detection level
SAYL21	1/5/2017	6:00:00	SAYL-FL1-HALLWAYNEAR1925-LDF-SAYL21	Lead, ppb	<1	Less than detection level
SAYL22	1/5/2017	6:01:00	SAYL-FL1-HALLWAYNEAR1925-RDF-SAYL22	Lead, ppb	<1	Less than detection level
SAYL23	1/5/2017	6:03:00	SAYL-FL1-1001-SINK-SAYL23	Lead, ppb	<1	Less than detection level
SAYL24	1/5/2017	6:04:00	SAYL-FL1-1001-DF-SAYL24	Lead, ppb	<1	Less than detection level
SAYL25	1/5/2017	6:05:00	SAYL-FL1-1001RR-SINK-SAYL25	Lead, ppb	<1	Less than detection level
SAYL26	1/5/2017	6:08:00	SAYL-FL1-1003-SINK-SAYL26	Lead, ppb	2.13	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL27	1/5/2017	6:09:00	SAYL-FL1-1003-DF-SAYL27	Lead, ppb	<1	Less than detection level
SAYL28	1/5/2017	6:12:00	SAYL-FL1-1107-SINK-SAYL28	Lead, ppb	1.76	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL29	1/5/2017	6:13:00	SAYL-FL1-1107-DF-SAYL29	Lead, ppb	<1	Less than detection level
SAYL30	1/5/2017	6:15:00	SAYL-FL1-1107RR-SINK-SAYL30	Lead, ppb	1.79	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL31	1/5/2017	6:17:00	SAYL-FL1-1105-SINK-SAYL31	Lead, ppb	<1	Less than detection level
SAYL32	1/5/2017	6:18:00	SAYL-FL1-1105-DF-SAYL32	Lead, ppb	<1	Less than detection level
SAYL33	1/5/2017	6:19:00	SAYL-FL1-1105RR-SINK-SAYL33	Lead, ppb	5.5	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL34	1/5/2017	6:21:00	SAYL-FL1-1100-SINK-SAYL34	Lead, ppb	2.38	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL35	1/5/2017	6:22:00	SAYL-FL1-1100-DF-SAYL35	Lead, ppb	<1	Less than detection level
SAYL36	1/5/2017	6:24:00	SAYL-FL1-1103-SINK-SAYL36	Lead, ppb	<1	Less than detection level
SAYL37	1/5/2017	6:25:00	SAYL-FL1-1103-DF-SAYL37	Lead, ppb	<1	Less than detection level
SAYL38	1/5/2017	6:26:00	SAYL-FL1-1103RR-SINK-SAYL38	Lead, ppb	<1	Less than detection level

Cincinnati Public Schools- Saylor Park School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SAYL39	1/5/2017	6:30:00	SAYL-FL1-1101-SINK-SAYL39	Lead, ppb	1.53	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL40	1/5/2017	6:31:00	SAYL-FL1-1101-DF-SAYL40	Lead, ppb	<1	Less than detection level
SAYL41	1/5/2017	6:33:00	SAYL-FL1-1101RR-SINK-SAYL41	Lead, ppb	5.04	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL42	1/5/2017	5:28:00	SAYL-FL1-1012GIRLSRR-FLSINK-SAYL42	Lead, ppb	1.19	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL43	1/5/2017	5:28:00	SAYL-FL1-1012GIRLSRR-LSINK-SAYL43	Lead, ppb	1.01	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL44	1/5/2017	5:28:00	SAYL-FL1-1012GIRLSRR-MSINK-SAYL44	Lead, ppb	1.1	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL45	1/5/2017	5:28:00	SAYL-FL1-1012GIRLSRR-RSINK-SAYL45	Lead, ppb	<1	Less than detection level
SAYL46	1/5/2017	5:28:00	SAYL-FL1-1012GIRLSRR-FRSINK-SAYL46	Lead, ppb	<1	Less than detection level
SAYL47	1/5/2017	5:28:00	SAYL-FL1-1014WSTAFFRR-SINK-SAYL47	Lead, ppb	1.68	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL48	1/5/2017	5:32:00	SAYL-FL1-1018BOYSRR-FLSINK-SAYL48	Lead, ppb	<1	Less than detection level
SAYL49	1/5/2017	5:32:00	SAYL-FL1-1018BOYSRR-LSINK-SAYL49	Lead, ppb	<1	Less than detection level
SAYL50	1/5/2017	5:32:00	SAYL-FL1-1018BOYSRR-MSINK-SAYL50	Lead, ppb	<1	Less than detection level
SAYL51	1/5/2017	5:32:00	SAYL-FL1-1018BOYSRR-RSINK-SAYL51	Lead, ppb	1.08	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL52	1/5/2017	5:32:00	SAYL-FL1-1018BOYSRR-FRSINK-SAYL52	Lead, ppb	<1	Less than detection level

Cincinnati Public Schools- Saylor Park School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SAYL53	1/5/2017	5:32:00	SAYL-FL1-1016MSTAFFRR-SINK-SAYL53	Lead, ppb	1.74	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL54	1/5/2017	5:38:00	SAYL-FL1-1013-SINK-SAYL54	Lead, ppb	3.9	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL55	1/5/2017	5:39:00	SAYL-FL1-1025MO-SINK-SAYL55	Lead, ppb	<1	Less than detection level
SAYL56	1/5/2017	5:39:00	SAYL-FL1-1027MORR-SINK-SAYL56	Lead, ppb	<1	Less than detection level
SAYL57	1/5/2017	5:40:00	SAYL-FL1-1022VISRR-SINK-SAYL57	Lead, ppb	<1	Less than detection level
SAYL58	1/5/2017	5:41:00	SAYL-FL1-HALLWAYNEAR1041-LDF-SAYL58	Lead, ppb	<1	Less than detection level
SAYL59	1/5/2017	5:41:00	SAYL-FL1-HALLWAYNEAR1041-RDF-SAYL59	Lead, ppb	<1	Less than detection level
SAYL60	1/5/2017	5:42:00	SAYL-FL1-1041RR-SINK-SAYL60	Lead, ppb	1.51	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL61	1/5/2017	5:44:00	SAYL-FL1-1043HEALTHCLINIC-LSINK-SAYL61	Lead, ppb	1.6	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL62	1/5/2017	5:44:00	SAYL-FL1-1043HEALTHCLINIC-RSINK-SAYL62	Lead, ppb	3.02	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL63	1/5/2017	5:44:00	SAYL-FL1-1043LROOM-SINK-SAYL63	Lead, ppb	1.41	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL64	1/5/2017	5:46:00	SAYL-FL1-1043MROOM-SINK-SAYL64	Lead, ppb	1.65	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL65	1/5/2017	5:46:00	SAYL-FL1-1043RROOM-SINK-SAYL65	Lead, ppb	<1	Less than detection level
SAYL66	1/5/2017	5:46:00	SAYL-FL1-1063-SINK-SAYL66	Lead, ppb	1.81	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

Cincinnati Public Schools- Saylor Park School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SAYL67	1/5/2017	5:48:00	SAYL-FL1-1065-SINK-SAYL67	Lead, ppb	3.59	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL68	1/5/2017	5:48:00	SAYL-FL1-1067-SINK-SAYL68	Lead, ppb	1.73	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL69	1/5/2017	5:50:00	SAYL-FL1-1066-SINK-SAYL69	Lead, ppb	<1	Less than detection level
SAYL70	1/5/2017	5:50:00	SAYL-FL2-2026-LSINK-SAYL70	Lead, ppb	<1	Less than detection level
SAYL71	1/5/2017	5:48:00	SAYL-FL2-2025-SINK-SAYL71	Lead, ppb	3.11	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL72	1/5/2017	5:50:00	SAYL-FL2-2025-DF-SAYL72	Lead, ppb	<1	Less than detection level
SAYL73	1/5/2017	6:04:00	SAYL-FL2-2027FRONTDESK-SINK-SAYL73	Lead, ppb	2.77	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL74	1/5/2017	6:04:00	SAYL-FL2-2027LEFTBACKWALL-LSINK-SAYL74	Lead, ppb	1.36	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL75	1/5/2017	6:04:00	SAYL-FL2-2027LEFTBACKWALL-RSINK-SAYL75	Lead, ppb	4.57	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL76	1/5/2017	6:04:00	SAYL-FL2-2027MIDDLEBACKWALL-LSINK-SAYL76	Lead, ppb	2.74	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL77	1/5/2017	6:04:00	SAYL-FL2-2027MIDDLEBACKWALL-RSINK-SAYL77	Lead, ppb	4.42	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL78	1/5/2017	6:04:00	SAYL-FL2-2027RIGHTBACKWALL-LSINK-SAYL78	Lead, ppb	3.72	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

Cincinnati Public Schools- Saylor Park School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SAYL79	1/5/2017	6:04:00	SAYL-FL2-2027RIGHTBACKWALL-RSINK-SAYL79	Lead, ppb	5.91	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL80	1/5/2017	6:16:00	SAYL-FL2-2022BOYSRR-FLSINK-SAYL80	Lead, ppb	1.15	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL81	1/5/2017	6:16:00	SAYL-FL2-2022BOYSRR-LSINK-SAYL81	Lead, ppb	<1	Less than detection level
SAYL82	1/5/2017	6:16:00	SAYL-FL2-2022BOYSRR-MSINK-SAYL82	Lead, ppb	<1	Less than detection level
SAYL83	1/5/2017	6:16:00	SAYL-FL2-2022BOYSRR-RSINK-SAYL83	Lead, ppb	<1	Less than detection level
SAYL84	1/5/2017	6:16:00	SAYL-FL2-2022BOYSRR-FRSINK-SAYL84	Lead, ppb	<1	Less than detection level
SAYL85	1/5/2017	6:18:00	SAYL-FL2-2024MSTAFFRR-SINK-SAYL85	Lead, ppb	1.06	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL86	1/5/2017	6:19:00	SAYL-FL2-HALLWAYNEAR2912-LDF-SAYL86	Lead, ppb	<1	Less than detection level
SAYL87	1/5/2017	6:19:00	SAYL-FL2-HALLWAYNEAR2912-RDF-SAYL87	Lead, ppb	<1	Less than detection level
SAYL88	1/5/2017	6:20:00	SAYL-FL2-2019-SINK-SAYL88	Lead, ppb	<1	Less than detection level
SAYL89	1/5/2017	6:21:00	SAYL-FL2-2017-SINK-SAYL89	Lead, ppb	1.03	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL90	1/5/2017	6:21:00	SAYL-FL2-2017-DF-SAYL90	Lead, ppb	<1	Less than detection level
SAYL91	1/5/2017	6:24:00	SAYL-FL2-2011-RSINK-SAYL91	Lead, ppb	1.79	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL92	1/5/2017	6:24:00	SAYL-FL2-2011-RDF-SAYL92	Lead, ppb	<1	Less than detection level
SAYL93	1/5/2017	6:24:00	SAYL-FL2-2011-LSINK-SAYL93	Lead, ppb	3.43	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL94	1/5/2017	6:24:00	SAYL-FL2-2011-LDF-SAYL94	Lead, ppb	1.2	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

Cincinnati Public Schools- Saylor Park School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
SAYL95	1/5/2017	6:26:00	SAYL-FL2-2016-SINK-SAYL95	Lead, ppb	1.56	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL96	1/5/2017	6:26:00	SAYL-FL2-2016-DF-SAYL96	Lead, ppb	<1	Less than detection level
SAYL97	1/5/2017	6:31:00	SAYL-FL2-HALLWAYNEAR2016-LDF-SAYL97	Lead, ppb	<1	Less than detection level
SAYL98	1/5/2017	6:31:00	SAYL-FL2-HALLWAYNEAR2016-RDF-SAYL98	Lead, ppb	<1	Less than detection level
SAYL99	1/5/2017	6:32:00	SAYL-FL2-2012GIRLSRR-FLSINK-SAYL99	Lead, ppb	<1	Less than detection level
SAYL100	1/5/2017	6:32:00	SAYL-FL2-2012GIRLSRR-LSINK-SAYL100	Lead, ppb	<1	Less than detection level
SAYL101	1/5/2017	6:32:00	SAYL-FL2-2012GIRLSRR-MSINK-SAYL101	Lead, ppb	<1	Less than detection level
SAYL102	1/5/2017	6:32:00	SAYL-FL2-2012GIRLSRR-RSINK-SAYL102	Lead, ppb	<1	Less than detection level
SAYL103	1/5/2017	6:32:00	SAYL-FL2-2012GIRLSRR-FRSINK-SAYL103	Lead, ppb	<1	Less than detection level
SAYL104	1/5/2017	6:34:00	SAYL-FL2-2012WSTAFFRR-SINK-SAYL104	Lead, ppb	<1	Less than detection level
SAYL105	1/5/2017	6:35:00	SAYL-FL2-2001-SINK-SAYL105	Lead, ppb	4.18	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL106	1/5/2017	6:35:00	SAYL-FL2-2001-DF-SAYL106	Lead, ppb	<1	Less than detection level
SAYL107	1/5/2017	6:37:00	SAYL-FL2-2003-SINK-SAYL107	Lead, ppb	5.74	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
SAYL108	1/5/2017	6:37:00	SAYL-FL2-2003-DF-SAYL108	Lead, ppb	<1	Less than detection level
SAYL109	1/5/2017	6:38:00	SAYL-FL2-2009-SINK-SAYL109	Lead, ppb	<1	Less than detection level
SAYL110	1/5/2017	6:38:00	SAYL-FL2-2009-DF-SAYL110	Lead, ppb	<1	Less than detection level
SAYL111	1/5/2017	6:39:00	SAYL-FL2-2026-MSINK-SAYL111	Lead, ppb	<1	Less than detection level
SAYL112	1/5/2017	6:39:00	SAYL-FL2-2026-RSINK-SAYL112	Lead, ppb	<1	Less than detection level