



January 31, 2017

St. Ignatius School  
Kathy Reder  
5222 North Bend Rd  
Cincinnati, OH 45247

Dear Ms. Reder:

Thank you for taking the responsibility seriously to protect the health of the children by voluntarily testing the water in your school for lead!

Attached please find the results of the lead analyses performed for St. Ignatius School by the Greater Cincinnati Water Works (GCWW). The following comments speak to the process, samples analyzed and additional steps needed to help ensure the safety of all the students within the school.

### **School Sampling Process and Results**

The *USEPA 3Ts for Reducing Lead in Drinking Water in Schools: Revised Technical Guidance Document (3Ts Guidelines)* is the process and guidelines used for assisting schools with testing for lead.

In December, one hundred, nineteen (119) samples were collected from drinking fountains and sinks throughout the school. The results show the following:

- 97 samples (81.51%), below the detection level (<1)
- 18 samples (15.13%), between 1ppb and 5ppb
- 3 samples (2.52%), between 5ppb and 10ppb
- 0 samples (0%), between 10ppb and 15ppb
- 1 sample (0.84%) greater than 15ppb.

Ninety-nine percent (99.16%) of the samples were below the detection level or below the federal action level.

Fifteen parts per billion (ppb) is the federal Lead and Copper Rule action level; desired results are below 15. The federal action level of 15ppb pertains to water utilities and the Greater Cincinnati Water Works review and comments are based on this action level. However, the USEPA 3Ts Guidelines document outlines practices for schools to put in place if samples are greater than 20 ppb.

While we strive to have results less than 15, we recognize that lead is a pervasive environmental contaminant, and no safe blood lead threshold has been identified in children or adults. Therefore, we provide recommendations to further reduce any lead levels discovered at drinking water and cooking outlets.

### **Next steps**

GCWW has reviewed the results from your samples and provides some next-steps comments:

1. There was one high lead level (sink in wildcat room). Based on the sample name, it is assumed this is not a drinking water or cooking outlet. Although the location is not used for these purposes, consider immediate remedies such as taking the sample location out of service until a more defined plan can be created OR post a sign above the location limiting the purpose of this sink ('hand washing only', 'work sink only'). Posting a sign will deter students and staff from potentially using the sink to fill a water bottle, etc. For more



information, refer to the 3Ts Guidelines that suggest shutting off or disconnecting problem outlets until the problem is resolved.

2. Although lower than the 15 ppb action level, for samples with lead detections, consider flushing the lines before using the water. Refer to the USEPA 3Ts Guidelines for more information.
3. As an added precaution, consider posting signs at sink locations indicating 'hand washing only' (or other specific purposes) as these locations should not to be used as drinking water or cooking outlets. Refer to the USEPA 3Ts Guidelines for more information and suggestions on signage.
4. Review how water is being used within your facility. If water is not used on a regular basis at some of these outlets, the infrequent use at the outlet may be contributing to the lead detections. Again, signage at these locations may be helpful (hand washing only, etc.).
5. Consider completing a plumbing profile to review the fixtures in the school as some fixtures may be contributing to the lead detections in samples. If the fixtures are the source of the lead, plan to replace them. GCWW is available to assist with follow-up/repeat sampling related to this.
6. If it hasn't occurred already, a robust communications plan is suggested. Communications plan steps are outlined in the 3Ts Guidelines. This plan will inform the school community of the sampling work the school has done to date and the steps the school will take to correct any issues discovered. GCWW employees can assist with this plan and are available to attend any school meetings to help explain our lead program, the sample results and our partnership with your school. Suggestions for language and a letter template can be provided if needed. Sampling results will be posted on the GCWW [lead.mycww.org](http://lead.mycww.org) website with other school sampling results.

Greater Cincinnati Water Works takes the presence of lead service lines and the removal of those service lines in our system very seriously. In addition, minimizing the exposure of lead within our preschools, schools, and daycares is one of our highest priorities under our Enhanced Lead Program. We look forward to our continued partnership with St. Ignatius School. Our resources are available to assist in many ways. Please contact Jim Nelson at 591-6869 for further assistance.

Thanks again for your partnership with Greater Cincinnati Water Works and your work to further understand the water quality within your building. Your extra steps and care to keep the children in our community safe are appreciated!

Sincerely,



Cathy B. Bailey  
Director/Greater Cincinnati Water Works

Cc: Dr. Marilyn Crumpton, Cincinnati Health Department  
Dr. Camille Jones, Cincinnati Health Department  
Chuck DeJonckheere, Hamilton County Public Health  
Sheila Hill-Christian, City of Cincinnati  
Verna Arnette, Greater Cincinnati Water Works  
Jeff Swertfeger, Greater Cincinnati Water Works  
Jason DeLaet, Greater Cincinnati Water Works

### Cincinnati Archdiocese - St. Ignatius School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
STI1	12/21/2016	8:07:00	STI-LL-STAFFRR-SINK-STI1	Lead, ppb	<1	Less than detection level
STI2	12/21/2016	8:07:00	STI-LL-HALLWAYNEAR104-DF-STI2	Lead, ppb	<1	Less than detection level
STI3	12/21/2016	8:09:00	STI-LL-BOYSRRNEAR104-LSINK-STI3	Lead, ppb	1.17	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
STI4	12/21/2016	8:09:00	STI-LL-BOYSRRNEAR104-RSINK-STI4	Lead, ppb	<1	Less than detection level
STI5	12/21/2016	8:11:00	STI-LL-105-SINK-STI5	Lead, ppb	<1	Less than detection level
STI6	12/21/2016	8:10:00	STI-LL-GIRLSRRNEAR107-LSINK-STI6	Lead, ppb	<1	Less than detection level
STI7	12/21/2016	8:10:00	STI-LL-GIRLSRRNEAR107-RSINK-STI7	Lead, ppb	<1	Less than detection level
STI8	12/21/2016	8:12:00	STI-LL-107-SINK-STI8	Lead, ppb	<1	Less than detection level
STI9	12/21/2016	8:12:00	STI-LL-HALLWAYNEAR107-DF-STI9	Lead, ppb	<1	Less than detection level
STI10	12/21/2016	8:15:00	STI-LL-HALLWAYNEAR113-COMBODF-STI10	Lead, ppb	<1	Less than detection level
STI11	12/21/2016	8:15:00	STI-LL-HALLWAYNEAR113-COMBOBF-STI11	Lead, ppb	<1	Less than detection level
STI12	12/20/2016	8:00:00	STI-LL-116ART-FLSINK-STI12	Lead, ppb	<1	Less than detection level
STI13	12/20/2016	8:00:00	STI-LL-116ART-LSINK-STI13	Lead, ppb	<1	Less than detection level
STI14	12/20/2016	8:00:00	STI-LL-116ART-RSINK-STI14	Lead, ppb	<1	Less than detection level
STI15	12/20/2016	8:00:00	STI-LL-116ART-FRSINK-STI15	Lead, ppb	1.8	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
STI16	12/21/2016	8:17:00	STI-LL-HALLWAYNEARGYM-DF-STI16	Lead, ppb	<1	Less than detection level
STI17	12/21/2016	8:18:00	STI-LL-GIRLSRRNEARGYM-LSINK-STI17	Lead, ppb	<1	Less than detection level
STI18	12/21/2016	8:18:00	STI-LL-GIRLSRRNEARGYM-RSINK-STI18	Lead, ppb	<1	Less than detection level
STI19	12/21/2016	8:19:00	STI-LL-BOYSRRNEARGYM-LSINK-STI19	Lead, ppb	1.68	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
STI20	12/21/2016	8:19:00	STI-LL-BOYSRRNEARGYM-RSINK-STI20	Lead, ppb	<1	Less than detection level
STI21	12/21/2016	8:22:00	STI-LL-GYM-DF-STI21	Lead, ppb	<1	Less than detection level
STI22	12/21/2016	8:23:00	STI-LL-35GYM-IM-STI22	Lead, ppb	<1	Less than detection level
STI23	12/21/2016	8:28:00	STI-ML-202RR-SINK-STI23	Lead, ppb	<1	Less than detection level
STI24	12/21/2016	8:30:00	STI-ML-MAINOFF-SINK-STI24	Lead, ppb	<1	Less than detection level
STI25	12/21/2016	8:30:00	STI-ML-MAINOFFRR-SINK-STI25	Lead, ppb	<1	Less than detection level
STI26	12/21/2016	8:28:00	STI-ML-STAFFRRNEAR203-SINK-STI26	Lead, ppb	<1	Less than detection level
STI27	12/21/2016	8:31:00	STI-ML-BOYSRRNEAR204-LSINK-STI27	Lead, ppb	<1	Less than detection level

### Cincinnati Archdiocese - St. Ignatius School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
STI28	12/21/2016	8:31:00	STI-ML-BOYSRRNEAR204-RSINK-STI28	Lead, ppb	<1	Less than detection level
STI29	12/21/2016	8:32:00	STI-ML-HALLWAYNEAR205-DF-STI29	Lead, ppb	<1	Less than detection level
STI30	12/21/2016	8:35:00	STI-ML-GIRLSRRNEAR207-LSINK TI30	Lead, ppb	<1	Less than detection level
STI31	12/21/2016	8:35:00	STI-ML-GIRLSRRNEAR207-RSINK-STI31	Lead, ppb	<1	Less than detection level
STI32	12/21/2016	8:36:00	STI-ML-HALLWAYNEAR207-COMBODF-STI32	Lead, ppb	<1	Less than detection level
STI33	12/21/2016	8:36:00	STI-ML-HALLWAYNEAR207-COMBOBF-STI33	Lead, ppb	<1	Less than detection level
STI34	12/21/2016	8:37:00	STI-ML-HALLWAYNEAR213-DF-STI34	Lead, ppb	<1	Less than detection level
STI35	12/21/2016	8:40:00	STI-ML-HALLWAYNEAR215-COMBODF-STI35	Lead, ppb	<1	Less than detection level
STI36	12/21/2016	8:40:00	STI-ML-HALLWAYNEAR215-COMBOBF-STI36	Lead, ppb	<1	Less than detection level
STI37	12/21/2016	8:41:00	STI-ML-BOYSRRNEAR216-LSINK-STI37	Lead, ppb	<1	Less than detection level
STI38	12/21/2016	8:41:00	STI-ML-BOYSRRNEAR216-MSINK-STI38	Lead, ppb	<1	Less than detection level
STI39	12/21/2016	8:41:00	STI-ML-BOYSRRNEAR216-RSINK-STI39	Lead, ppb	<1	Less than detection level
STI40	12/21/2016	8:42:00	STI-ML-GIRLSRRNEAR216-LSINK-STI40	Lead, ppb	<1	Less than detection level
STI41	12/21/2016	8:42:00	STI-ML-GIRLSRRNEAR216-MSINK-STI41	Lead, ppb	<1	Less than detection level
STI42	12/21/2016	8:42:00	STI-ML-GIRLSRRNEAR216-RSINK-STI42	Lead, ppb	<1	Less than detection level
STI43	12/21/2016	8:44:00	STI-ML-STAFFMENSRRNEARLOUNGE-SINK-STI43	Lead, ppb	<1	Less than detection level
STI44	12/21/2016	8:44:00	STI-ML-STAFFWOMENSRRNEARLOUNGE-SINK-STI44	Lead, ppb	<1	Less than detection level
STI45	12/21/2016	8:45:00	STI-ML-STAFFLOUNGE-DF-STI45	Lead, ppb	<1	Less than detection level
STI46	12/21/2016	8:46:00	STI-ML-STAFFLOUNGE-SINK-STI46	Lead, ppb	1.72	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
STI47	12/21/2016	8:48:00	STI-ML-HALLWAYNEAR222-LDF-STI47	Lead, ppb	<1	Less than detection level
STI48	12/21/2016	8:48:00	STI-ML-HALLWAYNEAR222-RDF-STI48	Lead, ppb	<1	Less than detection level
STI49	12/21/2016	8:50:00	STI-ML-BOYSRRNEAR219-LSINK-STI49	Lead, ppb	<1	Less than detection level
STI50	12/21/2016	8:50:00	STI-ML-BOYSRRNEAR219-RSINK-STI50	Lead, ppb	<1	Less than detection level
STI51	12/21/2016	8:51:00	STI-ML-GIRLSRRNEAR219-LSINK-STI51	Lead, ppb	<1	Less than detection level
STI52	12/21/2016	8:51:00	STI-ML-GIRLSRRNEAR219-RSINK-STI52	Lead, ppb	<1	Less than detection level
STI53	12/21/2016	8:54:00	STI-ML-CAFERR-SINK-STI53	Lead, ppb	<1	Less than detection level
STI54	12/21/2016	8:54:00	STI-ML-CAFÉ-DF-STI54	Lead, ppb	<1	Less than detection level
STI55	12/21/2016	8:56:00	STI-ML-KITCHENWASH-LSINK-STI55	Lead, ppb	<1	Less than detection level
STI56	12/21/2016	8:56:00	STI-ML-KITCHENWASH-RSINK-STI56	Lead, ppb	2.94	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
STI57	12/21/2016	8:57:00	STI-ML-KITCHENISLAND-SINK-STI57	Lead, ppb	<1	Less than detection level

### Cincinnati Archdiocese - St. Ignatius School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
STI58	12/21/2016	8:58:00	STI-ML-KITCHEN-HANDSINK-STI58	Lead, ppb	<1	Less than detection level
STI59	12/21/2016	8:58:00	STI-ML-KITCHEN-IM-STI59	Lead, ppb	<1	Less than detection level
STI60	12/21/2016	8:59:00	STI-ML-KITCHENSTAFFRR-SINK-STI60	Lead, ppb	<1	Less than detection level
STI61	12/21/2016	9:09:00	STI-UL-STAFFWOMENSRRNEAR303-SINK-STI61	Lead, ppb	<1	Less than detection level
STI62	12/21/2016	9:09:00	STI-UL-STAFFMENSRRNEAR303-SINK-STI62	Lead, ppb	<1	Less than detection level
STI63	12/21/2016	9:17:00	STI-UL-BOYSRRNEAR304-LSINK-STI63	Lead, ppb	2.91	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
STI64	12/21/2016	9:17:00	STI-UL-BOYSRRNEAR304-RSINK-STI64	Lead, ppb	<1	Less than detection level
STI65	12/21/2016	9:18:00	STI-UL-HALLWAYNEAR304A-DF-STI65	Lead, ppb	1.81	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
STI66	12/21/2016	9:21:00	STI-UL-GIRLSRRNEAR307-LSINK-STI66	Lead, ppb	<1	Less than detection level
STI67	12/21/2016	9:21:00	STI-UL-GIRLSRRNEAR307-RSINK-STI67	Lead, ppb	<1	Less than detection level
STI68	12/21/2016	9:23:00	STI-UL-HALLWAYNEAR307-COMBODF-STI68	Lead, ppb	<1	Less than detection level
STI69	12/21/2016	9:23:00	STI-UL-HALLWAYNEAR307-COMBOBF-STI69	Lead, ppb	<1	Less than detection level
STI70	12/21/2016	9:27:00	STI-UL-312-SINK-STI70	Lead, ppb	<1	Less than detection level
STI71	12/21/2016	9:27:00	STI-UL-HALLWAYNEAR313-DF-STI71	Lead, ppb	<1	Less than detection level
STI72	12/21/2016	9:30:00	STI-UL-BOYSRRNEAR316-LSINK-STI72	Lead, ppb	2.94	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
STI73	12/21/2016	9:30:00	STI-UL-BOYSRRNEAR316-MSINK-STI73	Lead, ppb	<1	Less than detection level
STI74	12/21/2016	9:30:00	STI-UL-BOYSRRNEAR316-RSINK-STI74	Lead, ppb	<1	Less than detection level
STI75	12/21/2016	9:31:00	STI-UL-GIRLSRRNEAR316-LSINK-STI75	Lead, ppb	<1	Less than detection level
STI76	12/21/2016	9:31:00	STI-UL-GIRLSRRNEAR316-MSINK-STI76	Lead, ppb	<1	Less than detection level
STI77	12/21/2016	9:31:00	STI-UL-GIRLSRRNEAR316-RSINK-STI77	Lead, ppb	<1	Less than detection level
STI78	12/21/2016	9:33:00	STI-UL-HALLWAYNEAR316-COMBODF-STI78	Lead, ppb	<1	Less than detection level
STI79	12/21/2016	9:33:00	STI-UL-HALLWAYNEAR316-COMBOBF-STI79	Lead, ppb	<1	Less than detection level
STI80	12/21/2016	9:34:00	STI-UL-316-SINK-STI80	Lead, ppb	<1	Less than detection level
STI81	12/21/2016	9:36:00	STI-UL-319-SINK-STI81	Lead, ppb	<1	Less than detection level
STI82	12/21/2016	9:54:00	STI-CHURCH-CRYRMRR-SINK-STI82	Lead, ppb	<1	Less than detection level

### Cincinnati Archdiocese - St. Ignatius School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
STI83	12/22/2016	7:55:00	STI-CHURCH-WOMENSRR-SINK-STI83	Lead, ppb	6.41	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
STI84	12/21/2016	9:39:00	STI-CHURCH-MENSRR-SINK-STI84	Lead, ppb	<1	Less than detection level
STI85	12/21/2016	9:39:00	STI-CHURCH-HALLWAY-DF-STI85	Lead, ppb	<1	Less than detection level
STI86	12/21/2016	9:49:00	STI-CHURCH-SACRISTY-SINK-STI86	Lead, ppb	<1	Less than detection level
STI87	12/21/2016	9:47:00	STI-PARISHOFF-HALLWAY-DF-STI87	Lead, ppb	<1	Less than detection level
STI88	12/21/2016	9:43:00	STI-PARISHOFF-COFFEERM-SINK-STI88	Lead, ppb	1.74	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
STI89	12/21/2016	9:48:00	STI-PARISHOFF-WOMENSRR-LSINK-STI89	Lead, ppb	<1	Less than detection level
STI90	12/21/2016	9:48:00	STI-PARISHOFF-WOMENSRR-MSINK-STI90	Lead, ppb	<1	Less than detection level
STI91	12/21/2016	9:48:00	STI-PARISHOFF-WOMENSRR-RSINK-STI91	Lead, ppb	<1	Less than detection level
STI92	12/21/2016	9:50:00	STI-PARISHOFF-MENSRR-LSINK-STI92	Lead, ppb	<1	Less than detection level
STI93	12/21/2016	9:50:00	STI-PARISHOFF-MENSRR-MSINK-STI93	Lead, ppb	<1	Less than detection level
STI94	12/21/2016	9:50:00	STI-PARISHOFF-MENSRR-RSINK-STI94	Lead, ppb	<1	Less than detection level
STI95	12/21/2016	9:51:00	STI-PARISHOFF-BEHLERRM-SINK-STI95	Lead, ppb	<1	Less than detection level
STI96	12/20/2016	15:58:00	STI-HILVERTHALL-SERVERY-SINK-STI96	Lead, ppb	<1	Less than detection level
STI97	12/20/2016	15:59:00	STI-HILVERTHALL-SERVERY-IM-STI97	Lead, ppb	<1	Less than detection level
STI98	12/20/2016	16:00:00	STI-HILVERTHALL-DF-STI98	Lead, ppb	<1	Less than detection level
STI99	12/20/2016	16:02:00	STI-HILVERTHALL-MENSRR-LSINK-STI99	Lead, ppb	2.51	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
STI100	12/20/2016	16:02:00	STI-HILVERTHALL-MENSRR-MSINK-STI100	Lead, ppb	<1	Less than detection level
STI101	12/20/2016	16:02:00	STI-HILVERTHALL-MENSRR-RSINK-STI101	Lead, ppb	1.08	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
STI102	12/20/2016	16:05:00	STI-HILVERTHALL-WOMENSRR-LSINK-STI102	Lead, ppb	1.06	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.

### Cincinnati Archdiocese - St. Ignatius School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
STI103	12/20/2016	16:05:00	STI-HILVERTHALL-WOMENSRR-MSINK-STI103	Lead, ppb	1.08	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
STI104	12/20/2016	16:05:00	STI-HILVERTHALL-WOMENSRR-RSINK-STI104	Lead, ppb	1.6	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
STI105	12/21/2016	9:58:00	STI-RECTORY-KITCHEN-SINK -STI105	Lead, ppb	<1	Less than detection level
STI106	12/21/2016	9:59:00	STI-RECTORY-RR-SINK-STI106	Lead, ppb	<1	Less than detection level
STI107	12/21/2016	9:59:00	STI-RECTORY-FRIDGE-WATER-STI107	Lead, ppb	<1	Less than detection level
STI108	12/21/2016	10:04:00	STI-RECTORY-RM1-SINK-STI108	Lead, ppb	3.21	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
STI109	12/21/2016	10:04:00	STI-RECTORY-RM1RR-SINK-STI109	Lead, ppb	<1	Less than detection level
STI110	12/21/2016	10:04:00	STI-RECTORY-RM2-SINK-STI110	Lead, ppb	1.12	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
STI111	12/21/2016	10:06:00	STI-RECTORY-RM2RR-SINK-STI111	Lead, ppb	<1	Less than detection level
STI112	12/21/2016	10:08:00	STI-RECTORY-RM3-SINK-STI112	Lead, ppb	6.93	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
STI113	12/21/2016	10:08:00	STI-RECTORY-RM3RR-SINK-STI113	Lead, ppb	<1	Less than detection level
STI114	12/21/2016	10:24:00	STI-ATHLETICS-CONCESSION-SINK-STI114	Lead, ppb	4.41	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
STI115	12/21/2016	10:24:00	STI-ATHLETICS-CONCESSION-UTILITYSINK-STI115	Lead, ppb	7.26	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
STI116	12/21/2016	10:21:00	STI-ATHLETICS-WILDCATRM-SINK-STI116	Lead, ppb	16.6	Above 15ppb federal action level. Until a defined remediation plan is created, immediately remove from service (tag out of service and/or disconnect the water supply to this location).

### Cincinnati Archdiocese - St. Ignatius School - Lead Testing Results

SAMPLE #	SAMPLE DATE	SAMPLE TIME	SAMPLE	PARAMETER CODE	AMOUNT	GCWW COMMENTS/REVIEW/RECOMMENDATIONS REGARDING RESULTS
STI117	12/21/2016	10:15:00	STI-ATHLETICS-WILDCATRM-IM-STI117	Lead, ppb	<1	Less than detection level
STI118	12/21/2016	10:20:00	STI-ATHLETICS-NEARFIELD6-DF-STI118	Lead, ppb	2.89	Lead detected; less than 15ppb action level. Review 3Ts Guidelines to understand options to further reduce the risk of lead.
STI119	12/21/2016	10:13:00	STI-ATHLETICS-NEARFIELD2-DF-STI119	Lead, ppb	<1	Less than detection level