

1,4-Dioxane		
SAMPLE DATE	Richard Miller Treatment Plant	
	UNTREATED OHIO RIVER WATER	DRINKING WATER
	concentration in parts per billion (µg/L)	
11/3/2025	0.15	-
7/2/2025	ND	-
6/4/2025	ND	ND
5/7/2025	ND	ND
4/2/2024	0.23	0.23
1/2/2024	0.14	0.44
10/10/2023	1.10	0.76
7/5/2023	0.61	0.32
4/4/2023	0.08	0.10
3/28/2022	0.41	0.30
10/19/2021	ND	0.63
7/12/2021	0.20	ND
3/29/2021	0.15	0.16
1/11/2021	0.19	0.18
10/6/2020	0.88	0.58
7/9/2020	ND	ND
3/25/2020	ND	0.085
1/28/2020	ND	ND
10/1/2019	0.33	0.15
3/26/2019	ND	ND
1/23/2019	0.07	0.14
12/10/2018	0.18	0.14
5/30/2018	ND	-
4/12/2018	ND	ND
2/6/2018	ND	ND
10/3/2017	0.74	0.71
3/28/2017	0.08	0.09
6/7/2016	0.36	0.25
2/22/2016	0.16	0.09
4/14/2015	ND	ND
6/7/2014	0.36	0.25
2/26/2014	0.10	0.26
10/16/2013	-	0.58

Values with ND indicate non detectable based on analytical
- indicates no sample collected

1,4-Dioxane		
SAMPLE DATE	Charles M. Bolton Treatment Plant	
	UNTREATED GROUNDWATER	DRINKING WATER
	concentration in parts per billion (µg/L)	
11/3/2025	0.3	-
7/1/2025	0.14	-
4/1/2025	0.23	0.14
1/22/2025	0.2	0.23
7/12/2024	0.18	0.21
4/9/2024	0.32	0.29
1/2/2024	0.44	0.42
10/10/2023	0.17	0.17
7/5/2023	0.14	0.20
4/4/2023	0.17	0.25
3/28/2022	0.16	0.15
11/17/2021	0.23	0.22
7/12/2021	ND	ND
3/29/2021	0.21	0.24
1/11/2021	0.24	0.22
10/6/2020	0.43	0.28
7/9/2020	0.22	0.18
3/25/2020	0.30	0.32
1/28/2020	0.22	0.22
10/1/2019	0.11	0.19
4/2/2019	ND	0.15
3/26/2019	0.12	0.11
1/23/2019	0.13	0.16
12/10/2018	0.14	0.13
5/30/2018	0.15	-
5/1/2018	0.11	0.19
2/6/2018	0.19	0.30
10/3/2017	0.24	0.30
3/28/2017	0.36	0.30
6/7/2016	0.37	0.30
2/22/2016	0.35	0.35
6/7/2014	0.37	0.30
2/26/2014	0.36	0.32

Values with ND indicate non detectable based on analytical
- indicates no sample collected