

GREATER CINCINNATI WATER WORKS
Unregulated Contaminants Monitoring Rule #3 (UCMR3) Results

Substance	Miller Plant			Bolton Plant		
	Minimum Level Detected (ug/L)	Maximum Level Detected (ug/L)	Average Level Detected (ug/L)	Minimum Level Detected (ug/L)	Maximum Level Detected (ug/L)	Average Level Detected (ug/L)
1,4-Dioxane	ND	0.575	0.326	0.276	0.814	0.545
Chromium	ND	0.56	ND	0.24	0.33	0.29
Cobalt	ND	ND	ND	ND	ND	ND
Molybdenum	1	2.9	1.6	3.5	4.9	4.2
Strontium	170	240	204	160	180	170
Vanadium	ND	0.56	0.26	0.6	0.72	0.64
Hexavalent Chromium (Dissolved)	0.048	0.099	0.071	0.2	0.22	0.21
Chlorate	ND	41	23	ND	ND	ND
17 alpha -ethynylestradiol	ND	ND	ND	ND	ND	ND
17-beta-Estradiol	ND	ND	ND	ND	ND	ND
4-androstene-3,17-dione	ND	ND	ND	ND	ND	ND
Equilin	ND	ND	ND	ND	ND	ND
Estril	ND	ND	ND	ND	ND	ND
Estrone	ND	ND	ND	ND	ND	ND
Testosterone	ND	ND	ND	ND	ND	ND
Perfluoro octanesulfonic acid (PFOS)	ND	ND	ND	ND	ND	ND
Perfluoro-1-butanesulfonic acid (PFBS)	ND	ND	ND	ND	ND	ND
Perfluoro-1-hexanesulfonic acid (PFHxS)	ND	ND	ND	ND	ND	ND
Perfluoroheptanoic acid (PFHpA)	ND	ND	ND	ND	ND	ND
Perfluoro-n-nonanoic acid (PFNA)	ND	ND	ND	ND	ND	ND
Perfluorooctanoic acid (PFOA)	ND	ND	ND	ND	ND	ND
1,1-Dichloroethane	ND	ND	ND	ND	ND	ND
1,2,3-Trichloropropane	ND	ND	ND	ND	ND	ND
1,3-Butadiene	ND	ND	ND	ND	ND	ND
Bromochloromethane	ND	ND	ND	ND	ND	ND
Bromomethane (Methyl Bromide)	ND	ND	ND	ND	ND	ND
Chlorodifluoromethane	ND	ND	ND	ND	ND	ND
Chloromethane (Methyl Chloride)	ND	ND	ND	ND	ND	ND

ND = not detected